

October 28, 2021

Donna Ogilvie  
NAS Lemoore  
750 Enterprise Ave  
Lemoore, CA 93246

**RE: Notice of Final Action - Authorities to Construct**  
**Facility Number: C-2106**  
**Project Number: C-1211083**

Dear Ms. Ogilvie:

The Air Pollution Control Officer has issued the Authority to Construct permits to NAS Lemoore for a 1,195 horsepower Tier 2 certified diesel engine and a 903 horsepower Tier 2 certified diesel engine to provide emergency power in the event of an electrical outage, at 750 Enterprise Ave, Lemoore, CA. Enclosed are the Authority to Construct permits and a copy of the notice of final action that has been posted on the District's website ([www.valleyair.org](http://www.valleyair.org)).

Notice of the District's preliminary decision to issue the Authority to Construct permits was posted on September 23, 2021. The District's analysis of the proposal was also sent to CARB on September 27, 2021. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas at (559) 230-6000.

Sincerely,



Brian Clements  
Director of Permit Services

BC:mh  
Enclosures

cc: Courtney Graham, CARB (w/ enclosure) via email

**Samir Sheikh**

Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: (661) 392-5500 FAX: (661) 392-5585



Facility # C-2106  
NAS LEMOORE  
BUILDING 750 CODE 50800  
LEMOORE, CA 93246-5001

## **AUTHORITY TO CONSTRUCT (ATC)**

### **QUICK START GUIDE**

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Modify Your Title V Permit.** Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at <http://www.valleyair.org/permits/TVforms>.
3. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
4. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
5. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
6. **Source Test:** Schedule and perform any required source testing. See [http://www.valleyair.org/busind/comply/source\\_testing.htm](http://www.valleyair.org/busind/comply/source_testing.htm) for source testing resources.
7. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at [http://www.valleyair.org/busind/comply/compliance\\_forms.htm](http://www.valleyair.org/busind/comply/compliance_forms.htm).

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at  
any of the telephone numbers listed below.**

# AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-2106-193-0

**ISSUANCE DATE:** 10/28/2021

**LEGAL OWNER OR OPERATOR:** NAS LEMOORE  
**MAILING ADDRESS:** BUILDING 750 CODE 50800  
LEMOORE, CA 93246-5001

**LOCATION:** NAVAL AIR STATION LEMOORE  
750 ENTERPRISE AVE  
LEMOORE, CA 93246-5001

**EQUIPMENT DESCRIPTION:**  
1,195 BHP (INTERMITTENT) KOHLER MODEL KD27V12 TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

## CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO



Brian Clements, Director of Permit Services

C-2106-193-0 : Oct 28 2021 9:38AM -- HONGM : Joint Inspection NOT Required

8. Emissions from this IC engine shall not exceed any of the following limits: 4.20 g-NO<sub>x</sub>/bhp-hr, 0.42 g-CO/bhp-hr, or 0.05 g-VOC/bhp-hr. [District Rules 2201 and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed 0.04 g-PM<sub>10</sub>/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
10. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
11. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
12. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours in any rolling 12 month period. [District Rules 2201, 4102, and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
16. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
17. On a monthly basis, the permittee shall calculate and record the hours of operation for the rolling 12 month period. The hours of operation shall be calculated by summing the hours of operation from the previous 12 months. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

# AUTHORITY TO CONSTRUCT

**PERMIT NO:** C-2106-194-0

**ISSUANCE DATE:** 10/28/2021

**LEGAL OWNER OR OPERATOR:** NAS LEMOORE  
**MAILING ADDRESS:** BUILDING 750 CODE 50800  
LEMOORE, CA 93246-5001

**LOCATION:** NAVAL AIR STATION LEMOORE  
750 ENTERPRISE AVE  
LEMOORE, CA 93246-5001

**EQUIPMENT DESCRIPTION:**

903 BHP (INTERMITTENT) VOLVO MODEL TWD1643GE TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

## CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO



Brian Clements, Director of Permit Services

C-2106-194-0 : Oct 28 2021 9:39AM -- HONGM : Joint Inspection NOT Required

8. Emissions from this IC engine shall not exceed any of the following limits: 4.0 g-NO<sub>x</sub>/bhp-hr, 0.5 g-CO/bhp-hr, or 0.06 g-VOC/bhp-hr. [District Rules 2201 and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed 0.08 g-PM<sub>10</sub>/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
10. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
11. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
12. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours in any rolling 12 month period. [District Rules 2201,4102, and 4702, and 17 CCR 93115 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
16. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
17. On a monthly basis, the permittee shall calculate and record the hours of operation for the rolling 12 month period. The hours of operation shall be calculated by summing the hours of operation from the previous 12 months. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit