

February 10, 2022

Mary Beth Thomas
UPF Corp
3801 Standard Street
Bakersfield, CA 93308

Re: Notice of Preliminary Decision – Emission Reduction Credits
Facility Number: S-1126
Project Number: S-1211795

Dear Ms. Thomas:

Enclosed for your review and comment is the District's analysis of UPF Corp's application for Emission Reduction Credits (ERCs) resulting from shutdown of a fiberglass filament manufacturing facility, at 3747 Standard Street, Bakersfield, CA. The quantity of ERCs proposed for banking is 2,951 lb-NOx/yr, 7,428 lb-PM10/yr, 2,242 lb-CO/yr and 8,354 lb-VOC/yr.

The notice of preliminary decision for this project has been posted on the District's website (www.valleyair.org). After addressing all comments made during the 30-day public notice comment period, the District intends to issue the ERCs. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Dan Klevann of Permit Services at (661) 392-5500.

Sincerely,



Brian Clements
Director of Permit Services

BC:dk

Enclosures

cc: Courtney Graham, CARB (w/ enclosure) via email
cc: Laura Yannayon, EPA (w/ enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

EMISSION REDUCTION CREDIT BANKING APPLICATION REVIEW

Facility Name: UPF Corp
Mailing Address: 3747 Standard Street
Bakersfield, CA 93308

Contact Name: Mary Beth Thomas
Telephone: (805) 320-9220

Facility: S-1126

ERC Certificate Numbers: S-5256-1, S-5256-2, S-5256-3, S-5256-4
Project Number: S-1211795

Date Received: April 28, 2021
Date Complete: June 10, 2021

Engineer: Dan Klevann
Date: 1/18/22

Lead Engineer: Leonard Scandura, Permit Services Manager
LS 2/10/22

I. SUMMARY:

UPF Corp (UPF) is a fiberglass filament manufacturing facility that has shutdown operation and permanently closed the facility.

UPF operated a fiberglass forming furnace (PTO S-1126-12) and fiberglass forming and curing operation (PTO S-1126-13). The process melts silica into molten glass, which flows out holes in a trough into a chamber. The air hardens the glass, which snaps into fibers. The fibers travel down a chute where they are picked up onto a thin mat. The thin mat is used for purposes such as filter media and airplane insulation. UPF has requested ERCs for VOC, NOx, CO, and PM10 emission reductions.

UPF is not requesting emissions reduction credits (ERC) from any other permitted equipment at the facility, i.e. raw materials handling operations or the emergency generator.

UPF has applied for emission reduction credits for the greenhouse gas (GHG) emissions from the reduced electricity usage by shutting down the facility. However, GHG emission reduction credits are not available for facilities who are purchasing electricity from the power grid and using the electric power. The electricity that was once sold to UPF is now sold to someone else, as such the emission reduction is not real or permanent.

Therefore, no GHG ERCs will be granted for the electrical usage. No further discussion is required.

Following the shutdown of the facility on March 12, 2021, UPF submitted an application to bank the emission reduction credits (ERCs) for the emissions. Based on the historical operating data prior to the shutdown, and considering any discounts for the emission limit requirements of current or pending District Rules, the amounts of bankable Actual Emission Reductions (AER) for NO_x, VOC, CO, and PM₁₀ emissions are as shown in the table below. These values are calculated in Section V of this document:

| Project Bankable Emission Reduction Credits (lbs/Qtr) | | | | | |
|--|----------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Pollutant | Certificate # | 1st Qtr | 2nd Qtr | 3rd Qtr | 4th Qtr |
| VOC | S-5256-1 | 2,274 | 2,151 | 1,940 | 1,989 |
| NO _x | S-5256-2 | 801 | 757 | 688 | 705 |
| CO | S-5256-3 | 678 | 640 | 437 | 486 |
| PM ₁₀ | S-5256-4 | 2,044 | 1,935 | 1,726 | 1,724 |

II. APPLICABLE RULES:

Rule 2201 New and Modified Stationary Source Review Rule (August 15, 2019)
 Rule 2301 Emission Reduction Credit Banking (August 15, 2019)
 Rule 4354 Glass Melting Furnaces (May 19, 2011)

III. LOCATION OF REDUCTION:

3747 Standard Street
 Bakersfield, CA 93308

IV. METHOD OF GENERATING EMISSION REDUCTIONS:

Actual emission reductions are being generated by shutdown of a fiberglass filament manufacturing facility that has shutdown operation and permanently closed. The facility shutdown operations on March 12, 2021.

Equipment Removed:

| PTO | Equipment |
|--------------|---|
| S-1126-12-9 | 4.25 MMBTU/HR MIXED BATCH FEEDING AND FURNACE AREA OPERATION CONSISTING OF A 4.25 MMBTU/HR GLASS MELTING FURNACE AND ENCLOSED MIXED BATCH FEED HOPPER WITH BIN VENT FILTER |
| S-1126-13-10 | 12.6 MMBTU/HR FIBERIZING, FIBER FORMING, CURING AND PACKAGING OPERATION CONSISTING OF FOUR 2.16 MMBTU/HR GLASS ATTENUATION BURNERS, FLARE TOWER, FIBER SLITTERS AND CHOPPERS, AND 3.9 MMBTU/HR CURING OVEN WITH AFTERBURNER |

V. CALCULATIONS:

A. Assumptions and Emission Factors

The actual emissions will be calculated for each of the calendar quarters in the baseline period. The Historical Actual Emissions (HAE) will be calculated using the fuel usage and the appropriate source test emissions or the permitted emission factors.

Fuel Usage Calculations:

UPF provided monthly fuel usage for the facility (see Appendix B). They do not have individual fuel meters for the equipment. The fuel usage is split between the furnace (permit '-12) and the curing oven/ attenuation burners (permit '-13). As a continuous process, the furnace runs fully loaded 100% of the time year round as to prevent the glass from solidifying in the furnace itself. However, UPF has stipulated that rare reductions in operations do occur and thus a 98% annual uptime with 95% load is assumed for the glass furnace.

Permit S-1126-12 Glass furnace:
Max heat input is 4.25 MMBtu/hr

Assume furnace operates 98% of the time (358 days/year- down for 7 days/year) and it ran at 95% of the permitted load.

Permit S-1126-12 Annual uptime = 8760 hrs/yr * 98% = 8592 hrs/yr operation
95% load = 4.25 MMBtu/hr * 0.95 = 4.0375 MMBtu/hr

So the maximum annual fuel usage for the furnace permit S-1126-12 is
Max fuel usage = 8592 hrs/yr operation * 4.0375 MMBtu/hr
= 34,690.2 MMBtu/yr

Fuel records are only available for the whole facility. There are no meters for the individual equipment. Assume glass furnace (Permit '12) ran as calculated above. Subtract the glass furnace gas usage from the whole facility gas usage to find the permit '13 (attenuation and afterburner) fuel usage.

Maximum fuel annual fuel usage for permit S-1126-13 is calculated by subtracting the fuel used in the furnace S-1126-12 from the total annual fuel usage. The fuel usage calculation is shown in Appendix D.

Emission factors for permit S-1126-12 (fiberglass furnace):

NO_x:

There are no source tests for NO_x for permit S-1126-12. Therefore the permitted NO_x emission limit and the furnace fuel usage rating will be used to calculate an emission factor for NO_x.

Current NO_x emission rate 0.17 lb NO_x/hr
Heat input of furnace 4.25 MMBtu/hr
NO_x emission factor = 0.17 lb NO_x/hr / 4.25 MMBtu/hr
= 0.04 lb NO_x/ MMBtu

District Rule 4354 was amended in December 2021. Under the amended rule the glass furnace lost its exemption from the NO_x requirements of the Rule. The NO_x requirement fiberglass furnaces for NO_x is as low as 1.3 lb/ton. The current permit limits for the furnace are 0.17 lb NO_x/hr with a production limit of 0.146 ton glass/, which equates to 1.16 lb NO_x/ ton. This level is less than the rule limit. Therefore, no adjustment of the NO_x emissions is required.

PM₁₀:

There were no source tests for the PM₁₀ from the furnace alone. PM₁₀ emissions for the furnace are limited by the permit to 0.0422 lb/MMBtu. Therefore we will use the permitted emission factor for PM₁₀.

VOC:

There were no source tests for the VOC emissions from the furnace. Similar to the NO_x calculations, the permitted VOC emission limit (0.41 lb VOC/hr) will be used to calculate the emission factor by dividing by the heat input of the furnace to get 0.096 lb VOC/MMBtu. We will use the permitted emission factor for VOC.

CO:

There were source test for the CO emissions during the baseline period. The source tests (0.01-0.04 lb/hr) were lower than the permitted level of 0.21 lb/hr. Therefore the source test results will be used for the emission factor. The lb/hr emissions are divided by the heat input of the furnace to find the emission factor (0.002 - 0.009 lb/MMBtu) during the baseline period.

Emission factors for permit S-1126-13 (fiber forming/curing):

Permit S-1126-13 has multiple emission units associated with it. The four 2.16 MMBtu/hr attenuation burners and one 3.9 MMBtu/hr afterburner. The emissions are sent to shared stacks. The emission factors for the attenuation burners and the afterburner will be determined similar to permit S-1126-12.

NOx:

Source testing for NOx for permit S-1126-13 was not required beyond 1999 as UPF had shown compliance with the permitted limits by a significant amount and source testing was not required to show continued compliance as there was not an applicable rule limit at that time. The last source test for the permit '-13 forming stacks and curing oven stack showed NOx emissions of 0.579 lb/hr. The permitted limit is 1.04 lb/hr. Therefore, the source test result will be used to determine a NOx emission factor for permit '-13. The total heat input of the burners is used to calculate the emission factor that will be used for the attenuation burners and the afterburner as shown below.

Attenuation/ Curing oven burners

Source test 0.579 lb NOx/hr

Heat input of attenuation/curing oven burners 12.6 MMBtu/hr

$$\begin{aligned} \text{NOx emission factor} &= 0.579 \text{ lb NOx/hr} / 12.6 \text{ MMBtu/hr} \\ &= 0.046 \text{ lb NOx/ MMBtu} \end{aligned}$$

VOC:

There were no source tests for the VOC from the attenuation burners and curing oven burner. VOC emissions are limited by the permit to 1.81 lb VOC/hr. Therefore we will use the permitted emission rate and the heat input of the burners to calculate the emission factor for VOC.

Attenuation/ curing oven burners

Permit limit 1.81 lb VOC/hr

Heat input of attenuation/ curing oven burners 12.6 MMBtu/hr

$$\begin{aligned} \text{VOC emission factor} &= 1.81 \text{ lb VOC/hr} / 12.6 \text{ MMBtu/hr} \\ &= 0.144 \text{ lb VOC/ MMBtu} \end{aligned}$$

PM10:

The attenuation/ curing oven burners were source tested for PM10. The source test showed emissions ranging from 1.8 - 2.19 lb PM10/ hr during the baseline period. The source test results and the heat input will be used to calculate the PM10 emission factor for the attenuation burners during the baseline period. The emission factor will vary depending on the associated source test. A sample calculation is shown for the applicable source test during the start of the baseline period.

Attenuation/ curing oven burners

Source test 1.8 lb PM10/hr

Heat input of attenuation/curing oven burners 12.6 MMBtu/hr

$$\begin{aligned} \text{PM10 emission factor} &= 1.8 \text{ lb PM10/hr} / 12.6 \text{ MMBtu/hr} \\ &= 0.143 \text{ lb PM10/ MMBtu} \end{aligned}$$

CO:

The attenuation/ curing oven burners were source tested for CO. The source test showed emissions ranging from 0.33 – 0.87 lb CO/ hr during the baseline period. The source test results and the heat input will be used to calculate the CO emission factor for the attenuation burners during the baseline period. The emission factor will vary depending on the associated source test. A sample calculation is shown for the applicable source test during the start of the baseline period.

Attenuation/ curing oven burners

Source test 0.33 lb CO/hr

Heat input of attenuation/curing oven burners 12.6 MMBtu/hr

$$\begin{aligned} \text{CO emission factor} &= 0.33 \text{ lb CO/hr} / 12.6 \text{ MMBtu/hr} \\ &= 0.026 \text{ lb CO/ MMBtu} \end{aligned}$$

Emission factor summary:

| Furnace Emission Factors | | | |
|--------------------------|------------------|------------------------|-------------------------|
| Unit | Pollutant | Emission Factor | Source |
| S-1126-12 | VOC | 0.096 lb/MMBtu | Permit |
| | NO _x | 0.04 lb/MMBtu | Permit |
| | PM ₁₀ | 0.0422 lb/MMBtu | Permit |
| | CO | 0.002 - 0.009 lb/MMBtu | Source tests 2016- 2018 |

| Attenuation/ Curing oven burners Emission Factors | | | |
|--|------------------|------------------------|-------------------------|
| Unit | Pollutant | Emission Factor | Source |
| S-1126-13 | VOC | 0.144 lb/ MMBtu | Permit |
| | NO _x | 0.046 lb/MMBtu | Source test |
| | PM ₁₀ | 0.143 - 0.174 lb/MMBtu | Source tests 2015- 2018 |
| | CO | 0.026 - 0.069 lb/MMBtu | Source tests 2015- 2018 |

B. Baseline Period Determination

Per the following sections of Rule 2201, baseline period is defined as:

- 3.9.1 two consecutive years of operation immediately prior to submission of the complete application; or
- 3.9.2 another time period of at least two consecutive years within the five years immediately prior to submission of the complete application as determined by the APCO as more representative of normal operation;

The facility was shut down in March 2021. Due to operational issues, the facility has proposed an alternate baseline period of January 1, 2018 thru December 31, 2019 as more representative of normal source operations. The facility had a protracted maintenance turnaround that took place in early 2020, and the Covid-19 pandemic also caused issues for the maintenance turnaround as well as standard operations in the remainder of 2020.

The facility provided monthly fuel usage data for the facility from 2014 to 2021. The District used the provided monthly fuel usage data to determine the normal operation from the fuel usage data. The District, as per section 3.9.2, used the provided fuel usage data to find a time period that was closest to the average normal source operation of the facility. Each consecutive two, three, and four-year period are compared with the total normal source operating average. The period that is closest to the normal source operation is determined to be the baseline period. It was shown that the thirty-six month time period from July 2016 through June 2019 was closest to the average normal operation for the facility (see fuel usage calculations Appendix D). Therefore, a three year baseline period will be used from July 2016 through June 2019.

C. Historical Actual Emissions (HAE)

HAE was calculated using the fuel usage and the actual emission factor for the fuel burning equipment.

To be the most conservative, we will use the lowest emission factor on a pollutant by pollutant basis to determine the breakdown of fuel usage for each emission unit on permit '13.

HAE calculation spreadsheets are shown in the Appendix D. A sample calculation is shown below.

$$(\text{Heat Input [MMBtu/month]}) * (\text{Emission Factor [lb-Pollutant/MMBtu]}) = \text{Emissions [lb-Pollutant/month]}$$

Example – June 2019 unit '12:
(2,106 MMBtu)(0.04 lb-NOx/MMBtu) = 84.2 lbs-NOx/month

| HAE PTOs S-1126-12 and '13 Furnace + Attenuation/Curing (lbs/Qtr) | | | | |
|--|----------------|----------------|----------------|----------------|
| Pollutant | 1st Qtr | 2nd Qtr | 3rd Qtr | 4th Qtr |
| VOC | 2,527 | 2,389 | 2,156 | 2,210 |
| NO _x | 890 | 842 | 764 | 783 |
| PM ₁₀ | 2,271 | 2,150 | 1,918 | 1,915 |
| CO | 754 | 711 | 486 | 540 |

D. Adjustments to HAE

Pursuant to Section 3.23 of Rule 2201, Historical Actual Emissions must be discounted for any emissions reduction, which is:

- 3.23.1 Any emissions reductions required or encumbered by any laws, rules, regulations, agreements, orders, or permits; and
- 3.23.2 Any emissions reductions attributed to a control measure noticed for workshop, or proposed or contained in a State Implementation Plan, and
- 3.23.3 Any emissions reductions proposed in the District air quality plan for attaining the annual reductions required by the California Clean Air Act, and
- 3.23.4 Any Actual Emissions in excess of those required or encumbered by any laws, rules, regulations, orders, or permits. For units covered by a Specific Limiting Condition (SLC), the total overall HAE for all units covered by SLC must be discounted for any emissions in excess of that allowed by the SLC.

The emission factors above were used to calculate HAE. The subject units were found to be in compliance with all applicable prohibitory rules.

Rule 4354 was amended in December 2021. This was after the banking application was deemed complete. Therefore, the Rule 4354 exemption changes would not affect this facility for the ERC banking application.

The resulting emissions would be surplus of any applicable rules, regulations, plans, or permits. No adjustments to the HAE were required.

E. Actual Emissions Reductions (AER)

Pursuant to Section 3.2 of Rule 2201, Actual Emissions Reduction (AER): the decrease of actual emissions, compared to the Baseline Period, from an emissions unit and selected for use as emission offsets or ERC banking. AER shall meet the following criteria:

- 3.2.1 Shall be real, enforceable, quantifiable, surplus, and permanent.
- 3.2.2 To be considered surplus, AER shall be in excess, at the time the application for an Emission Reduction Credit or an Authority to Construct authorizing such reductions is deemed complete, of any emissions reduction which:
 - 3.2.2.1 Is required or encumbered by any laws, rules, regulations, agreements, orders, or
 - 3.2.2.2 Is attributed to a control measure noticed for workshop, or proposed or contained in a State Implementation Plan, or
 - 3.2.2.3 Is proposed in the APCO's adopted air quality plan pursuant to the California Clean Air Act.

The key factor for VOC emissions in this project is with AER is section 3.2.2, the date the application is deemed complete. For this ERC banking project, the application was deemed complete June 10, 2021. The rules, regulations, plans, noticed or in effect on that day are what are used to determine whether the emissions are surplus.

The 2018 PM2.5 plan adopted in 2018 included commitments to review Rule 4354 for potential NOx reductions. In December 2020, there was a scoping meeting for Rule 4354. In the scoping meeting, only NOx, SOx and PM emissions were listed as pollutants to be evaluated for possible changes.

The first workshop of Rule 4354 was noticed on September 16, 2021 as reducing NOx, SOx, PM during the rulemaking. This was after the banking application was deemed complete as well as not mentioning VOC as a pollutant of interest. As VOC was not listed as a pollutant of interest, there were no rules, regulations, or plans were noticed or in effect that were reducing VOC emissions. Therefore, the VOC rule changes are not applicable to the ERC banking project. The current furnace meets the applicable rule requirements for NOx, SOx, CO and PM.

One note, while the banking project is not affected by the Rule 4354 VOC exemption change, once the amended rule is federally approved by EPA the VOC emissions will not be surplus of rule requirements.

Per Rule 2201, Section 4.12, the Actual Emissions Reductions due to shutdown of emissions units shall be calculated, on a pollutant-by-pollutant basis, as follows:

$$\text{AER} = \text{HAE} - \text{PE2}$$

Where:

HAE = Historic Actual Emissions

PE2 = Post-project Potential to Emit

Because the facility is permanently shut down, PE2 = 0.

Therefore, AER = HAE – 0, or AER = HAE

| AER Furnace + Attenuation/Curing (lbs/Qtr) | | | | |
|---|----------------|----------------|----------------|----------------|
| Pollutant | 1st Qtr | 2nd Qtr | 3rd Qtr | 4th Qtr |
| VOC | 2,527 | 2,389 | 2,156 | 2,210 |
| NOx | 890 | 842 | 764 | 783 |
| PM10 | 2,271 | 2,150 | 1,918 | 1,915 |
| CO | 754 | 711 | 486 | 540 |

F. Air Quality Improvement Deduction (AQID)

Actual Emission Reductions must be discounted by 10% for Air Quality Improvement.

Sample calculation:

$$\begin{aligned} \text{Q1 VOC lb} &= \text{AER} \times (0.1) \\ &= (2,004 \text{ lb}) \times (0.1) \\ &= 200.4 \text{ lb} \\ &= 200 \text{ lb} \end{aligned}$$

| Air Quality Improvement Deduction (AQID) | | | | |
|---|--|--|--|--|
| Pollutant | 1st Qtr. AQID (lb/qtr) | 2nd Qtr. AQID (lb/qtr) | 3rd Qtr. AQID (lb/qtr) | 4th Qtr. AQID (lb/qtr) |
| VOC | 253 | 239 | 216 | 221 |
| NOx | 89 | 84 | 76 | 78 |
| PM10 | 227 | 215 | 192 | 192 |
| CO | 75 | 71 | 49 | 54 |

G. Increases in Permitted Emissions

The facility has been shut down. The permit to operate have been surrendered and canceled. There are no increases in emissions from this project.

H. Bankable Emissions Reductions Credits

The bankable emissions reduction credits, presented in following table, are determined by subtraction of the Air Quality Improvement Deduction (discussed above) from the AER.

| Bankable Emission Reductions Credit (ERC) | | | | |
|--|---|---|---|---|
| Pollutant | 1st Qtr. ERC (lb/qtr) | 2nd Qtr. ERC (lb/qtr) | 3rd Qtr. ERC (lb/qtr) | 4th Qtr. ERC (lb/qtr) |
| VOC | 2,274 | 2,151 | 1,940 | 1,989 |
| NOx | 801 | 757 | 688 | 705 |
| PM10 | 2,044 | 1,935 | 1,726 | 1,724 |
| CO | 678 | 640 | 437 | 486 |

VI. COMPLIANCE:

To be eligible for banking, emission reduction credits (ERC's) must be verified as being real, enforceable, quantifiable, permanent, and surplus pursuant to District Rules 2201 and 2301. In addition, the application must be submitted within the timeline specified in Rule 2301.

A. Real

The emission reductions were generated by the permanent shutdown of the fiberglass manufacturing plant permits S-1126-12 and S-1126-13.

The permanent cessation of emissions from the facility is March 12, 2021. The application to bank ERCs was received on April 28, 2021. Therefore, the emission reductions are real.

B. Enforceable

The components authorized by the permit have been removed from service and the Permit to Operate has been canceled. Therefore, the emission reductions are enforceable.

C. Quantifiable

Reduction amounts were calculated from historic process data, and accepted emission factors that consider any discounting requirements for banking emissions from the burners. Therefore, the emission reductions are quantifiable.

D. Permanent

The applicant has removed the components from service and canceled the permit to operate associated with the facility. Therefore, the AER is permanent.

E. Surplus

To be considered a surplus actual emission reduction (pursuant to Rule 2201 section 3.2.2), the emission reduction must be in excess of any emissions reduction which is:

- 1) required or encumbered by any laws, rules, regulations, agreements, orders,
- 2) attributed to a control measure noticed for workshop, or proposed or contained in a State implementation Plan, or
- 3) proposed in the APCO's adopted air quality plan pursuant to the California Clean Air Act

The discussion below evaluates if the emission reductions resulting from the shutdown of the fiberglass plant meets the criteria above:

The glass plant was subject to the following current District prohibitory rules

Rule 4102 – Nuisance

This rule is to limit the emissions from sources such that the emissions do not cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public or which endanger the comfort, repose, health or safety of any such person or the public or which cause or have a natural tendency to cause injury or damage to business or property. The facility was required to operate the electro static precipitator and NaOH wet scrubbing system. There were no emission limits with those requirements.

Rule 4001 – New Source Performance Standards

The NSPS CC- Standards of Performance for Glass Manufacturing Plants is applicable to the UPF glass plant. The requirements of CC are for PM₁₀ emissions. The facility currently meets the NSPS requirement of 0.5 gm-PM/kg-glass with the limit on condition 14.

PM₁₀ Emissions:

Source test information for PM₁₀ during the chosen baseline period shows the facility meets the NSPS CC PM₁₀ emission limit. Therefore, the emission reduction is surplus of the emissions allowable by District, or any other, applicable rules and regulations, or source test data.

Rule 4354 - Glass *Melting Furnaces*

UPF was previously exempt from Rule 4354 per Section 4.2 as the facility potential to emit for both NO_x and VOC was less than 10 tons/yr.

The emission reduction is in excess of any emission reduction attributed to a control measure noticed for workshop, or proposed or contained in a State implementation Plan

The glass plant was exempt from Rule 4354 before the shutdown. Rule 4354 was amended in December 2021. The rule exemptions were revised such that the exemption for the facility being under 10 tons/yr for NO_x and VOC is no longer available. However, the banking action was deemed complete on June 10, 2021. This date is what sets the applicable rules and regulations that are used to determine surplus. The PM_{2.5} plan adopted in 2018 and the workshop in December 2020 both mentioned Rule 4354 as a rule to be workshopped. However, the only pollutants that were noticed to be looked at were NO_x, SO_x, and PM. As there was not a notice to workshop VOC emissions until November 2021, the VOC reductions are not to be considered in determining surplus for this banking action. Note that once the December 2021 Rule 4354 amendment is federally approved, the VOC credits may not be completely surplus at that time.

UPF would still be able to enjoy the exemption from SO_x and PM₁₀ emission limits as the facility has permitted glass production capacity of less than 5 tons/day, and the actual NO_x and VOC emissions are less than 8 tons/yr. However, UPF would now be subject to the NO_x limits in section 5.1 and the CO and VOC limits in section 5.2. Currently the facility meets the NO_x and CO limits. The emissions are surplus of any control measure noticed for workshop, proposed or contained in a State Implementation Plan.

The emission reduction is in excess of any emission reduction that is proposed in the APCO's adopted air quality plan pursuant to the California Clean Air Act.

A review of the 2016 ozone and 2018 PM_{2.5} attainment plans revealed that the 2018 PM_{2.5} plan includes a commitment to investigate further NO_x, SO_x, and PM₁₀ reductions from Rule 4354 for glass melting furnaces. As discussed above the emission reductions are surplus of the emission limits in the amended Rule 4354.

As discussed above, the emission reduction meets the criterial for a surplus actual emission reduction.

Rule 2301 – Emission Reduction Banking:

Section 5.5 states that ERC certificate applications for reductions shall be submitted within 180 days after the emission reduction occurs. UPF permanently ceased operation on March 12, 2021. The ERC application was received on April 28, 2021, within the 180-day timeframe allowed. Therefore, the application was submitted in a timely fashion.

Section 6.1.2 states that if the emission reductions were created as a result of the shutdown of a permitted emissions unit, the relevant Permit(s) to Operate has been surrendered and voided. UPF has surrendered and canceled the PTO's for their facility.

VII. RECOMMENDATION:

After public notice, comments and review, issue ERCs to UPF in the amounts shown below and on the draft ERC certificates contained in Appendix E:

| | | ----- ERC (lb) ----- | | | |
|----------|------|----------------------|-------|-------|-------|
| ERC # | | Q1 | Q2 | Q3 | Q4 |
| S-5256-1 | VOC | 2,274 | 2,151 | 1,940 | 1,989 |
| S-5256-2 | NOx | 801 | 757 | 688 | 705 |
| S-5256-3 | CO | 678 | 640 | 437 | 486 |
| S-5256-4 | PM10 | 2,044 | 1,935 | 1,726 | 1,724 |

Appendix A
Permits
S-1126-12, S-1126-13

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: S-1126-12-9

EXPIRATION DATE: 02/29/2024

SECTION: NW23 **TOWNSHIP:** 29S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

4.25 MMBTU/HR MIXED BATCH FEEDING AND FURNACE AREA OPERATION CONSISTING OF A 4.25 MMBTU/HR GLASS MELTING FURNACE AND ENCLOSED MIXED BATCH FEED HOPPER WITH BIN VENT FILTER

PERMIT UNIT REQUIREMENTS

1. Furnace shall include provisions to feed continuous filaments to attenuation burners listed on S-1126-13. [District Rule 2201]
2. Mixed batch silo shall be pneumatically filled and material shall be transported from mixed batch silo to melting furnace with screw feeder. Material collected in bin vent filter shall discharge to mixed batch silo only. [District Rule 2201]
3. Furnace exhaust shall be served by McGill electrostatic precipitator (ESP) exhausting to 27 inch dia. by 50 ft. tall stack equipped with continuously recording opacity meter and temperature indicator. [District Rule 2201]
4. There shall be no provisions for introduction of dilution air into furnace exhaust. [District Rule 1110]
5. This unit shall be fired on Public Utility Commission (PUC) regulated natural gas only. [District Rule 2201]
6. Melting capacity of furnace shall not exceed 7,000 lbs/day. [District Rule 2201]
7. NaOH injection monitor shall be set to trigger alarms when low flow, as determined by source test showing compliance with emission limits, or no flow conditions exist. [District Rules 2080, 2201 and 4102]
8. Wet scrubbing system shall inject NaOH at a rate equivalent to at least a 20% dial setting on the metering pump. [District Rule 2201]
9. ESP exhaust stack gas temperature shall be at least 160 degrees F at discharge point. [District Rule 2201]
10. Overall control efficiency for scrubber and ESP shall be at least a 98% for particulate matter (PM10). [District Rule 2201]
11. ESP and NaOH wet scrubbing system shall be operated whenever furnace S-1126-12 is operating. [District Rules 2201 and 4102]
12. Permittee shall comply with all applicable provisions of Rule 4001 including but not limited to 40 CFR 60 Subparts A and CC. [District Rule 4001]
13. Mixed batch silo emissions shall not exceed 0.5 lb PM-10/day. [District Rule 2201]
14. Emission rate of particulate matter shall not exceed 0.5 gram/kilogram glass produced. [District Rule 4001, Subpart CC]
15. Emissions of particulate matter (PM10) shall not exceed 2.56 lb/hr for all combustion equipment associated with permit units S-1126-12 and S-1126-13 except the curing oven w/afterburner on unit S-1126-13. [District Rule 2201]
16. Particulate matter (as PM10) emission rates from furnace on line F1 (S-1126-12) shall not exceed 0.0422 lb/MMBtu. [District Rule 2201]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. Emission rates from F1 furnace shall not exceed any of the following limits: SO_x (as SO₂): 0.22 lb/hr, NO_x (as NO₂): 0.17 lb/hr, VOC: 0.41 lb/hr or CO: 0.21 lb/hr. [District Rule 2201]
18. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]
19. Compliance source test for PM₁₀ & CO emission limits shall be conducted annually. [District Rule 2201]
20. Source testing shall be conducted with all equipment operating in a mode representative of normal operation. [District Rule 1081]
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
22. The following test methods shall be used: PM - EPA Method 5, PM₁₀ - EPA Method 201, CO - ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4001]
23. Permittee shall demonstrate daily compliance with facility wide PM₁₀ emission limit by maintaining accurate daily records of fuel usage and production throughput of permit units S-1126-12 and S-1126-13. [District Rule 2201]
24. Permittee shall maintain daily records of NaOH injection rate, fuel usage, product throughput, and PM₁₀ emissions and shall make such records readily available for District inspection for a period of five years. [District Rules 1070 and 2201]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1126-13-10

EXPIRATION DATE: 02/29/2024

SECTION: 23 **TOWNSHIP:** 29S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

12.6 MMBTU/HR FIBERIZING, FIBER FORMING, CURING AND PACKAGING OPERATION CONSISTING OF FOUR 2.16 MMBTU/HR GLASS ATTENUATION BURNERS, FLARE TOWER, FIBER SLITTERS AND CHOPPERS, AND 3.9 MMBTU/HR CURING OVEN WITH AFTERBURNER

PERMIT UNIT REQUIREMENTS

1. Flare tower shall be utilized only during start-up of attenuation burners. [District Rule 2201]
2. Liquid utilized in wash-water spray operation shall not be composed of volatile organic materials. [District Rule 2201]
3. This unit shall be fired on Public Utility Commission (PUC) regulated natural gas or propane only. [District Rule 2201]
4. Emissions of particulate matter (PM10) shall not exceed 2.56 lb/hr for all combustion equipment associated with permit units S-1126-12 and S-1126-13 except for curing oven w/afterburner on unit S-1126-13. [District Rule 2201]
5. Emission rates from curing oven w/afterburner shall not exceed any of the following limits: PM10: 0.13 lb/hr or CO: 0.83 lb/hr. [District Rule 2201]
6. Emission rate from attenuation burners shall not exceed the following limit: CO: 8.56 lb/hr. [District Rule 2201]
7. Emission rates from attenuation burners/curing oven w/afterburner shall not exceed any of the following limits: SOx (as SO2): 0.041 lb/MMBtu, NOx (as NO2): 1.04 lb/hr, or VOC: 1.81 lb/hr. [District Rule 2201]
8. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]
9. Compliance source test for PM10 and CO emission limits shall be conducted annually on the attenuation burners only. [District Rule 2201]
10. Source testing shall be conducted with all equipment operating in a mode representative of normal operation. [District Rule 1081]
11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
12. The following test methods shall be used: PM10 - EPA Method 201, CO - ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rule 1081]
13. Permittee shall demonstrate daily compliance with facility wide PM10 emission limit by maintaining accurate daily records of fuel usage and production throughput of permit units S-1126-12, and S-1126-13. [District Rule 2201]
14. Permittee shall maintain daily records of fuel usage, product throughput, and PM10 emissions and shall make such records readily available for District inspection for a period of five years. [District Rules 1070 and 2201]

These terms and conditions are part of the Facility-wide Permit to Operate.

Appendix B
Fuel Use Data

Fuel gas burned

UPF Corporation

8/25/21

Gas was used in permit units S1126-12-9 and 13-10

Data from PG&E gas bill

| Year | 2021 | 2020 | 2019 | 2018 | 2017 | 2016 | 2015 | 2014 | 2013 | 2012 | 2011 | 2010 | Average/month |
|------------------|---------|---------|---------|---------|---------|---------|---------|---------|-------|-------|-------|-------|---------------|
| Month | | | | | | | | | | | | | |
| January | 51,946 | 78,196 | 70,277 | 73,805 | 56,423 | 57,506 | 87,381 | 58,406 | | | | | 66,743 |
| February | 47,114 | 63,468 | 71,973 | 66,602 | 73,347 | 76,211 | 75,274 | 61,803 | | | | | 66,974 |
| March | 26,183 | 3,355 | 72,359 | 53,989 | 76,280 | 75,724 | 76,265 | 57,455 | | | | | 55,201 |
| April | | 0 | 76,537 | 65,150 | 61,227 | 61,043 | 62,566 | 75,052 | | | | | 57,368 |
| May | | 40,299 | 70,201 | 70,712 | 68,578 | 41,841 | 49,641 | 71,254 | | | | | 58,932 |
| June | | 68,840 | 50,934 | 49,933 | 68,355 | 43,441 | 48,879 | 75,776 | | | | | 58,023 |
| July | | 66,052 | 73,032 | 59,372 | 66,507 | 55,406 | 58,668 | 71,962 | | | | | 64,428 |
| August | | 67,147 | 69,208 | 52,999 | 63,074 | 67,259 | 59,771 | 78,142 | | | | | 65,371 |
| September | | 68,695 | 65,838 | 72,004 | 56,159 | 37,116 | 56,296 | 74,399 | | | | | 61,501 |
| October | | 70,077 | 54,138 | 76,211 | 38,356 | 45,808 | 84,071 | 73,400 | | | | | 63,152 |
| November | | 57,069 | 70,756 | 79,342 | 71,291 | 72,457 | 68,984 | 83,681 | | | | | 71,940 |
| December | | 63,231 | 73,615 | 58,819 | 51,806 | 49,169 | 69,107 | 76,398 | | | | | 63,164 |
| Total for year | 125,243 | 646,429 | 818,868 | 778,938 | 751,403 | 682,981 | 796,903 | 857,728 | 1,000 | 1,000 | 1,000 | 1,000 | 752,796 |
| BTU/MSCF content | | 1,022 | 1,027 | 1,015 | 1,015 | 1,031 | 1,029 | 1,023 | 1,000 | 1,000 | 1,000 | 1,000 | |
| Conversion- MSCF | | 63,251 | 79,734 | 76,743 | 74,030 | 66,245 | 77,444 | 83,844 | 0 | 0 | 0 | 0 | |

APCD Annual Report (MMSCF)

| | 2020 | 2019 | 2018 | 2017 | 2016 | 2015 | 2014 | 2013 | 2012 | 2011 | 2010 | Average/year |
|---------------------|-------|-------|-------|-------|-------|-------|-------|------|-------|-------|-------|--------------|
| -12-9 Process 1 | 28.77 | 34.66 | 34.66 | 33.01 | 48.07 | 53.04 | 54.87 | | 53.20 | 50.16 | 46.20 | 43.66 |
| -13-10 Process 1 | 34.48 | 45.71 | 40.17 | 40.06 | 18.37 | 24.71 | 29.28 | | 18.30 | 33.44 | 30.80 | 31.53 |
| Totals APCD reports | 63.25 | 80.37 | 74.83 | 73.07 | 66.44 | 77.75 | 84.15 | | 71.50 | 83.60 | 77.00 | 75.20 |

On 2019 APCD report, the Process 3 gas was included in Process 1 gas reported

| | |
|-------------------|-------|
| Average 2019-2020 | 71.81 |
| Average 2018-2019 | 77.60 |
| Average 2017-2018 | 73.95 |
| Average 2016-2017 | 69.76 |



ENERGY STATEMENT

www.pge.com/MyEnergy

Account No: 5876747845-4

Statement Date: 02/02/2021

Due Date: 02/19/2021

Details of Gas Charges

12/31/2020 - 01/31/2021 (31 billing days)

Service For: GIBSON ST & TURCON AVE

Service Agreement ID: 5876747005 GAS FIBER CLASS MFG PLANT

12/31/2020 – 01/31/2021

Rate Schedule: GNT

Rate Description: Gas Transportation Service to Noncore End-Use Customers

Net Charges \$216.73

12/31/2020 – 01/31/2021

Rate Schedule: GNTT

Rate Description: Transmission Service Level

Net Charges \$10,523.22

12/31/2020 – 01/31/2021

Franchise Fee Surcharge \$136.10

Gas PPP Surcharge 2,755.74

Total Gas Charges \$13,631.79

Service Information

Meter # 52796568

Total Usage 51,946.000000 Therms

Serial F

Additional Messages

Detailed bill calculation: For more information, including a detailed explanation of how your bill was calculated, log in to My Energy at www.pge.com/MyEnergy.



ENERGY STATEMENT

www.pge.com/MyEnergy

Account No: 5876747845-4

Statement Date: 03/08/2021

Due Date: 03/25/2021

Details of Gas Charges

01/31/2021 - 02/28/2021 (28 billing days)

Service For: GIBSON ST & TURCON AVE

Service Agreement ID: 5876747845 GAS FIBERGLASS MFG PLANT

01/31/2021 - 02/28/2021

Rate Schedule: GNT

Rate Description: Gas Transportation Service to Noncore End-Use Customers

Net Charges \$195.75

01/31/2021 - 02/28/2021

Rate Schedule: GNTT

Rate Description: Transmission Service Level

Net Charges \$9,544.35

01/31/2021 - 02/28/2021

Franchise Fee Surcharge \$124.85

Gas PPP Surcharge 2,499.40

Total Gas Charges \$12,364.35

Service Information

Meter # 5279656

Total Usage 47,114.000000 Therms

Serial F

Additional Messages

Detailed bill calculation For more information, including a detailed explanation of how your bill was calculated, log in to My Energy at www.pge.com/MyEnergy.



ENERGY STATEMENT

www.pge.com/MyEnergy

Account No: 5876747845-4

Statement Date: 04/01/2021

Due Date: 04/19/2021

Details of Gas Charges

02/28/2021 - 03/31/2021 (31 billing days)

Service For: GIBSON ST & TURCON AVE

Service Agreement ID: 5876747005 GAS FIBERGLASS MFG PLANT

02/28/2021 - 03/31/2021

Rate Schedule: GNT

Rate Description: Gas Transportation Service to Noncore End-Use Customers

Net Charges \$216.73

02/28/2021 - 03/31/2021

Rate Schedule: GNTT

Rate Description: Transmission Service Level

Net Charges \$5,612.85

02/28/2021 - 03/31/2021

Franchise Fee Surcharge \$73.57

Gas PPP Surcharge 1,389.01

Total Gas Charges \$7,292.16

Service Information


Meter # 52796568

Total Usage 26,183.000000 Therms

Serial F

Additional Messages

Detailed bill calculation For more information, including a detailed explanation of how your bill was calculated, log in to My Energy at www.pge.com/MyEnergy.



End User

Bill Period: 11/30/20 - 12/31/20

Service Agreement ID. 5876747005

UPF CORP

Meter Information

| | | | | | | | |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| | | | | | | |
|-------------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|
| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered |
| 52796568 | 11/30/20 | 12/31/20 | 6,187 | 1.022 MCF | | 63,231 |
| Total Therms Delivered | | | | | | 63,231 |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 01/31/20 | 1.000 | 78,196 |
| 02/29/20 | 1.000 | 63,468 |
| 03/31/20 | 1.000 | 3,355 |
| 04/30/20 | 1.000 | 0 |
| 05/31/20 | 1.000 | 40,299 |
| 06/30/20 | 1.000 | 68,840 |
| 07/31/20 | 1.000 | 66,052 |
| 08/31/20 | 1.000 | 67,147 |
| 09/30/20 | 1.000 | 68,695 |
| 10/31/20 | 1.000 | 70,077 |
| 11/30/20 | 1.000 | 57,069 |
| 12/31/20 | 1.000 | 63,231 |
| Total | | 646,429 |
| Average Monthly Use | | 53,869 |


Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| | | | | | | |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NRI) | Per Day Rate | Amount |
| G-NTT | 52796568 | 11/01/20 | 31 | 53,869 | 7.09611 | \$219,98 |
| Total | | | | | | \$219,98 |

Transportation Charge (based on therms)

| | | | | | |
|--------------|----------|---------------------|------------------|-------------------------------|--------------------|
| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
| G-NTT | 52796568 | 11/01/20 | 63,231 | \$0.16560 | \$10,471.05 |
| Total | | | 63,231 | | \$10,471.05 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

UPF CORP

Bill Period: 11/30/19 - 12/31/19

Service Agreement ID. 5876747005

Meter Information

| | | | | | | | |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| | | | | | | |
|-------------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|
| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered |
| 52796568 | 11/30/19 | 12/31/19 | 7,168 | 1.027 MCF | | 73,615 |
| Total Therms Delivered | | | | | | |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 01/31/19 | 1.000 | 70,277 |
| 02/28/19 | 1.000 | 71,973 |
| 03/31/19 | 1.000 | 72,359 |
| 04/30/19 | 1.000 | 76,537 |
| 05/31/19 | 1.000 | 70,201 |
| 06/30/19 | 1.000 | 50,934 |
| 07/31/19 | 1.000 | 73,032 |
| 08/31/19 | 1.000 | 69,208 |
| 09/30/19 | 1.000 | 65,838 |
| 10/31/19 | 1.000 | 54,138 |
| 11/30/19 | 1.000 | 70,756 |
| 12/31/19 | 1.000 | 73,615 |
| Total | | 818,868 |
| Average Monthly Use | | 68,239 |

Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NRI) | Per Day Rate | Amount |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| G-NTT | 52796568 | 11/01/19 | 31 | 68,239 | 7.16548 | \$222.13 |
| Total | | | | | | \$222.13 |

Transportation Charge (based on therms)

| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
|--------------|----------|---------------------|------------------|-------------------------------|--------------------|
| G-NTT | 52796568 | 11/01/19 | 73,615 | \$0.16626 | \$12,239.23 |
| Total | | | 73,615 | | \$12,239.23 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

UPF CORP

Bill Period: 11/30/18 - 12/31/18

Service Agreement ID. 5876747005

Meter Information

| | | | | | | | |
|------------|----------|-------------|----------------|---------------|----------------------------|--------------------|------------------------------------|
| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
| PRIMARY | 52796568 | AMR | 1001780410E255 | | No | No | T |

Meter Reads

| | | | | | | | |
|------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|--------|
| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered | |
| 52796568 | 11/30/18 | 12/31/18 | 5,795 | 1.015 MCF | | 58,819 | |
| Total Therms Delivered | | | | | | | 58,819 |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 01/31/18 | 1.000 | 73,805 |
| 02/28/18 | 1.000 | 66,602 |
| 03/31/18 | 1.000 | 53,989 |
| 04/30/18 | 1.000 | 65,150 |
| 05/31/18 | 1.000 | 70,712 |
| 06/30/18 | 1.000 | 49,933 |
| 07/31/18 | 1.000 | 59,372 |
| 08/31/18 | 1.000 | 52,999 |
| 09/30/18 | 1.000 | 72,004 |
| 10/31/18 | 1.000 | 76,211 |
| 11/30/18 | 1.000 | 79,342 |
| 12/31/18 | 1.000 | 58,819 |
| Total | | 778,938 |
| Average Monthly Use | | 64,912 |

Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| | | | | | | |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NRI) | Per Day Rate | Amount |
| G-NTT | 52796568 | 11/01/18 | 31 | 64,912 | 8.06762 | \$250.10 |
| Total | | | | | | \$250.10 |

Transportation Charge (based on therms)

| | | | | | |
|--------------|----------|---------------------|------------------|-------------------------------|-------------------|
| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
| G-NTT | 52796568 | 11/01/18 | 58,819 | \$0.16445 | \$9,672.78 |
| Total | | | 58,819 | | \$9,672.78 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

UPF CORP

Bill Period: 11/30/17 - 12/31/17

Service Agreement ID: 5876747005

Meter Information

| | | | | | | | |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| | | | | | | |
|-------------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|
| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered |
| 52796568 | 11/30/17 | 12/31/17 | 5,104 | 1.015 MCF | | 51,806 |
| Total Therms Delivered | | | | | | 51,806 |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 01/31/17 | 1.000 | 56,423 |
| 02/28/17 | 1.000 | 73,347 |
| 03/31/17 | 1.000 | 76,280 |
| 04/30/17 | 1.000 | 61,227 |
| 05/31/17 | 1.000 | 68,578 |
| 06/30/17 | 1.000 | 68,355 |
| 07/31/17 | 1.000 | 66,507 |
| 08/31/17 | 1.000 | 63,074 |
| 09/30/17 | 1.000 | 56,159 |
| 10/31/17 | 1.000 | 38,356 |
| 11/30/17 | 1.000 | 71,291 |
| 12/31/17 | 1.000 | 51,806 |
| Total | | 751,403 |
| Average Monthly Use | | 62,617 |


Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| | | | | | | |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NR1) | Per Day Rate | Amount |
| G-NTT | 52796568 | 11/01/17 | 31 | 62,617 | 8.46148 | \$262.31 |
| Total | | | | | | \$262.31 |

Transportation Charge (based on therms)

| | | | | | |
|--------------|----------|---------------------|------------------|-------------------------------|-------------------|
| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
| G-NTT | 52796568 | 11/01/17 | 51,806 | \$0.11225 | \$5,815.22 |
| Total | | | 51,806 | | \$5,815.22 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

Bill Period: 11/30/16 - 12/31/16

Service Agreement ID. 5876747005

UPF CORP

Meter Information

| | | | | | | | |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| | | | | | | |
|-------------------------------|-----------------|-------------------|------------------------|--------------------|--------------|------------------|
| Meter ID | Prior Read Date | Current Read Date | Meter Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered |
| 52796568 | 11/30/16 | 12/31/16 | 4,797 | 1.025 | MCF | 49,169 |
| Total Therms Delivered | | | | | | |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 01/31/16 | 1.000 | 57,506 |
| 02/29/16 | 1.000 | 76,211 |
| 03/31/16 | 1.000 | 75,724 |
| 04/30/16 | 1.000 | 61,043 |
| 05/31/16 | 1.000 | 41,841 |
| 06/30/16 | 1.000 | 43,441 |
| 07/31/16 | 1.000 | 55,406 |
| 08/31/16 | 1.000 | 67,259 |
| 09/30/16 | 1.000 | 37,116 |
| 10/31/16 | 1.000 | 45,808 |
| 11/30/16 | 1.000 | 72,457 |
| 12/31/16 | 1.000 | 49,169 |
| Total | | 682,981 |
| Average Monthly Use | | 56,915 |

Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| | | | | | | |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NRI) | Per Day Rate | Amount |
| G-NTT | 52796568 | 11/01/16 | 31 | 56,915 | 8.91321 | \$276.31 |
| Total | | | | | | \$276.31 |

Transportation Charge (based on therms)

| | | | | | |
|--------------|----------|---------------------|------------------|-------------------------------|-------------------|
| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
| G-NTT | 52796568 | 11/01/16 | 49,169 | \$0.11980 | \$5,890.45 |
| Total | | | 49,169 | | \$5,890.45 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

UPF CORP

Bill Period: 06/30/16 - 07/31/16

Service Agreement ID. 5876747005

Meter Information

| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered |
|-------------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|
| 52796568 | 06/30/16 | 07/31/16 | 5,374 | 1.031 MCF | | 55,406 |
| Total Therms Delivered | | | | | | 55,406 |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 08/31/15 | 1.000 | 59,771 |
| 09/30/15 | 1.000 | 56,296 |
| 10/31/15 | 1.000 | 84,071 |
| 11/30/15 | 1.000 | 68,984 |
| 12/31/15 | 1.000 | 69,107 |
| 01/31/16 | 1.000 | 57,506 |
| 02/29/16 | 1.000 | 76,211 |
| 03/31/16 | 1.000 | 75,344 |
| 04/30/16 | 1.000 | 61,043 |
| 05/31/16 | 1.000 | 41,841 |
| 06/30/16 | 1.000 | 43,441 |
| 07/31/16 | 1.000 | 55,406 |
| Total | | 749,401 |
| Average Monthly Use | | 62,450 |

Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NRI) | Per Day Rate | Amount |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| G-NTT | 52796568 | 04/01/16 | 31 | 62,450 | 14.85962 | \$460.65 |
| Total | | | | | | \$460.65 |

Transportation Charge (based on therms)

| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
|--------------|----------|---------------------|------------------|-------------------------------|-------------------|
| G-NTT | 52796568 | 04/01/16 | 55,406 | \$0.04468 | \$2,475.54 |
| Total | | | 55,406 | | \$2,475.54 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

UPF CORP

Bill Period: 10/31/15 - 11/30/15

Service Agreement ID. 5876747005

Meter Information

| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (T01) | Meter Volume | Therms Delivered |
|-------------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|
| 52796568 | 10/31/15 | 11/30/15 | 6,704 | 1.029 MCF | | 68,984 |
| Total Therms Delivered | | | | | | 68,984 |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 12/31/14 | 1.000 | 76,398 |
| 01/31/15 | 1.000 | 87,381 |
| 02/28/15 | 1.000 | 75,274 |
| 03/31/15 | 1.000 | 76,265 |
| 04/30/15 | 1.000 | 62,566 |
| 05/31/15 | 1.000 | 49,641 |
| 06/30/15 | 1.000 | 48,879 |
| 07/31/15 | 1.000 | 58,668 |
| 08/31/15 | 1.000 | 59,771 |
| 09/30/15 | 1.000 | 56,296 |
| 10/31/15 | 1.000 | 84,071 |
| 11/30/15 | 1.000 | 68,984 |
| Total | | 804,194 |
| Average Monthly Use | | 67,016 |

Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NRI) | Per Day Rate | Amount |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| G-NTT | 52796568 | 11/01/15 | 30 | 67,016 | 14.85962 | \$445.79 |
| Total | | | | | | \$445.79 |

Transportation Charge (based on therms)

| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
|--------------|----------|---------------------|------------------|-------------------------------|-------------------|
| G-NTT | 52796568 | 11/01/15 | 68,984 | \$0.03758 | \$2,592.42 |
| Total | | | 68,984 | | \$2,592.42 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.



End User

Bill Period: 11/30/14 - 12/31/14

Service Agreement ID: 5876747005

UPF CORP

Meter Information

| Meter Type | Meter ID | Device Type | Usage Account | AIS Site ID # | Does Meter Serve Gen Load? | Is Gen Load Cogen? | Transmission/Distribution/Backbone |
|------------|----------|-------------|-----------------|---------------|----------------------------|--------------------|------------------------------------|
| PRIMARY | 52796568 | AMR | 1001780410 E255 | | No | No | T |

Meter Reads

| Meter ID | Prior Read Date | Current Read Date | Corrected Volume | Therm Factor (101) | Meter Volume | Therms Delivered |
|-------------------------------|-----------------|-------------------|------------------|--------------------|--------------|------------------|
| 52796568 | 11/30/14 | 12/31/14 | 7,468 | 1.023 MCF | | 76,398 |
| Total Therms Delivered | | | | | | 76,398 |

Therms Delivered = Corrected Volumes (MCF) x Therm Factor x 10

Average Monthly Use Calculation

| Service to Date | Billing Factor | Therms Delivered |
|----------------------------|----------------|------------------|
| 01/31/14 | 1.000 | 58,406 |
| 02/28/14 | 1.000 | 61,803 |
| 03/31/14 | 1.000 | 57,455 |
| 04/30/14 | 1.000 | 75,052 |
| 05/31/14 | 1.000 | 71,254 |
| 06/30/14 | 1.000 | 75,776 |
| 07/31/14 | 1.000 | 71,962 |
| 08/31/14 | 1.000 | 78,142 |
| 09/30/14 | 1.000 | 74,399 |
| 10/31/14 | 1.000 | 73,400 |
| 11/30/14 | 1.000 | 83,681 |
| 12/31/14 | 1.000 | 76,398 |
| Total | | 857,728 |
| Average Monthly Use | | 71,477 |

Customer Access Charge / Customer Charge (Billing Factor = 1.000)

| Schedule | Meter ID | Rate Effective Date | Days in Period | Noncore Average Monthly Use / Highest Average Daily Use (G-NR1) | Per Day Rate | Amount |
|--------------|----------|---------------------|----------------|---|--------------|-----------------|
| G-NTT | 52796568 | 11/01/14 | 31 | 71,477 | 14.56833 | \$451.62 |
| Total | | | | | | \$451.62 |

Transportation Charge (based on therms)

| Schedule | Meter ID | Rate Effective Date | Therms Delivered | Transportation per Therm Rate | Amount |
|--------------|----------|---------------------|------------------|-------------------------------|-------------------|
| G-NTT | 52796568 | 11/01/14 | 76,398 | \$0.06194 | \$4,732.09 |
| Total | | | 76,398 | | \$4,732.09 |

The Summer season begins April 1 and ends on October 31. The Winter season begins November 1 and ends on March 31.

Appendix C
Source tests

Company: UPF CORP

Test Date: 10/30/2018

Pass Fail

Permit#: S-1126-12-9

FacilityID: 1126

Unit ID: ESP

Witnessed By:

Area Inspector: AGUIRRET

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: ENVIRONMENTAL SERVICES & TESTING Project Number: EST-1126-103018

Next Test: 10/17/2021

Test Company Contact: Mr. James Taplin

Equipment: ESP SERVING 4.25 MMBTU GLASS MELTING FURNACE

Equipment Type: Other

Input Rate: 4.25 MMBTU

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: Nat. Gas

F-Factor:

BTU:

Fuel Rate:

Second Fuel:

O2 % Stack:

Stack Flow:

Process Rate:

Comments:

ESP STACK

Enforcement Action:

NOV#:

Report Rec: 12/26/2018

Reviewed By: AMBERGS

Results Sent Date: 01/03/2019

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|--------|--------|-------|---------------|--------|---------|
| CO | lbs/hr | 0.04 | 0.21 | | | ESP |
| PM10 | lbs/hr | 1.83 | 2.56 | | | ESP |

Company: UPF CORP

Test Date: 11/07/2017

Pass Fail

Permit#: S-1126-12-9

FacilityID: 1126

Unit ID: ESP

Witnessed By:

Area Inspector: BALLARDV

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: ENVIRONMENTAL SERVICES & TESTING Project Number: UPF Glass

Next Test: 10/17/2021

Test Company Contact: Mr. James Taplin

Equipment: ESP SERVING 4.25 MMBTU GLASS MELTING FURNACE

Equipment Type: Other

Input Rate: 4.25 MMBTU

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: Nat. Gas

F-Factor:

BTU:

Fuel Rate:

Second Fuel:

O2 % Stack:

Stack Flow:

Process Rate:

Comments:

ESP

Enforcement Action:

NOV#:

Report Rec: 01/08/2018

Reviewed By: DAWSONB

Results Sent Date: 05/31/2018

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|--------|--------|-------|---------------|--------|---------|
| CO | lbs/hr | 0.01 | 0.21 | | | ESP |
| PM10 | lbs/hr | 2.17 | 2.56 | | | ESP |

Company: UPF CORP

Test Date: 11/15/2016

Pass Fail

Permit#: S-1126-12-9

FacilityID: 1126

Unit ID: ESP

Witnessed By: OREGONA

Area Inspector: BALLARDV

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: ENVIRONMENTAL SERVICES & TESTING Project Number: EST-1126-101816

Next Test: 10/17/2021

Test Company Contact: Mr. James Taplin

Equipment: ESP SERVING 4.25 MMBTU GLASS MELTING FURNACE

Equipment Type: Other

Input Rate: 4.25 MMBTU

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: Nat. Gas F-Factor: BTU: Fuel Rate:
 Second Fuel: O2 % Stack: Stack Flow: Process Rate:

Comments:

ESP ANNUAL, PM10 FACILITY TOTAL

Enforcement Action: NOV#:

Report Rec: 01/17/2017

Reviewed By: OREGONA

Results Sent Date: 02/09/2017

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|--------|--------|-------|---------------|--------|---------|
| CO | lbs/hr | 0.01 | 0.21 | | | ESP |
| PM10 | lbs/hr | 0.21 | 2.56 | | | ESP |

Company: UPF CORP

Test Date: 06/24/1999

Pass Fail

Permit#: S-1126-13-6

FacilityID: 1126

Unit ID: FIBER CURING

Witnessed By:

Area Inspector:

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: PETRO CHEM

Project Number:

Next Test:

Test Company Contact:

Equipment: 12.6 MMBTU FIBER FORMING, CURING LINE WITH FOUR STACKS

Equipment Type: GLASS FORMING

Input Rate: 12.6

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: PUC GAS

F-Factor: 8710

BTU:

Fuel Rate:

Second Fuel:

O2 % Stack: 0.0

Stack Flow: 0

Process Rate:

Comments:

Enforcement Action:

NOV#:

Report Rec: 07/28/1999

Reviewed By: GLENN SLITOR

Results Sent Date:

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|-----------|--------|-------|---------------|--------|--------------|
| CO | lbs/MMBtu | 2.5 | 9.39 | | | FIBER CURING |
| NOx | lbs/MMBtu | 0.58 | 1.04 | | | FIBER CURING |

Company: UPF CORP

Test Date: 10/31/2018

Pass Fail

Permit#: S-1126-13-10

FacilityID: 1126

Unit ID: CURING STACKS

Witnessed By:

Area Inspector: AGUIRRET

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: ENVIRONMENTAL SERVICES & TESTING Project Number: EST-1126-103018

Next Test: 10/17/2021

Test Company Contact: Mr. James Taplin

Equipment: 12.6 (4*2.16) MMBTU GAS FIRED CURING OVEN AND 3.9 MMBTU AFTER BURNER

Equipment Type: Oven

Input Rate:

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: Nat. Gas F-Factor: BTU: Fuel Rate:
 Second Fuel: O2 % Stack: Stack Flow: Process Rate:

Comments:

CURING STACKS

Enforcement Action: NOV#:

Report Rec: 12/26/2018

Reviewed By: AMBERGS

Results Sent Date: 01/03/2019

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|--------|--------|-------|---------------|--------|---------|
| CO | lbs/hr | 0.87 | 8.56 | | | Default |
| PM10 | lbs/hr | 1.83 | 2.56 | | | Default |

Company: UPF CORP

Test Date: 11/08/2017

Pass Fail

Permit#: S-1126-13-10

FacilityID: 1126

Unit ID: CURING STACKS

Witnessed By:

Area Inspector: AGUIRRET

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: ENVIRONMENTAL SERVICES & TESTING Project Number: UPF Glass

Next Test: 10/17/2017

Test Company Contact: Mr. James Taplin

Equipment: 12.6 (4*2.16) MMBTU GAS FIRED CURING OVEN AND 3.9 MMBTU AFTER BURNER

Equipment Type: Oven

Input Rate: 3.9 MMBTU

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: Nat. Gas F-Factor: BTU: Fuel Rate:
 Second Fuel: O2 % Stack: 20.4 Stack Flow: 7259 Process Rate:

Comments:

FORMING CURING STACKS (4)

Enforcement Action: NOV#:

Report Rec: 01/08/2018

Reviewed By: DAWSONB

Results Sent Date: 05/31/2018

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|--------|--------|-------|---------------|--------|---------------|
| CO | lbs/hr | 0.57 | 8.56 | | | CURING STACKS |
| PM10 | lbs/hr | 2.17 | 2.56 | | | CURING STACKS |

Company: UPF CORP

Test Date: 11/15/2016

Pass Fail

Permit#: S-1126-13-10

FacilityID: 1126

Unit ID: CURING STACKS

Witnessed By: OREGONA

Area Inspector: BALLARDV

Reason For Testing:

Annual Initial CGA RATA Stationary/RATA QTR:
 ReTest RepTest AMS Dist Performed Unit Dormant
 Postponed

Test Company: ENVIRONMENTAL SERVICES & TESTING Project Number: EST-1126-101816

Next Test:

Test Company Contact: Mr. James Taplin

Equipment: 12.6 (4*2.16) MMBTU GAS FIRED CURING OVEN AND 3.9 MMBTU AFTER BURNER

Equipment Type: Oven

Input Rate:

Output Rate:

Control Equipment:

Catalyst Scrubber Baghouse FGR O2
 LoNOx Incin ESP H2O/Stm Inj NH3/SCR
 DLN PSC PCC Rich Burn Lean Burn
 Cyclone TEOR-Gas

Fuel Data And Operational Data:

Fuel Type: Nat. Gas F-Factor: BTU: Fuel Rate:
 Second Fuel: O2 % Stack: Stack Flow: Process Rate:

Comments:

ANNUAL, PM10 FACILITY TOTAL, 4 CURING STACKS

Enforcement Action: NOV#:

Report Rec: 01/17/2017

Reviewed By: OREGONA

Results Sent Date: 02/09/2017

Test Results:

| Pollutant | Unit | Result | Limit | O2 Correction | Failed | Unit ID |
|-----------|--------|--------|-------|---------------|--------|---------------|
| CO | lbs/hr | 0.87 | 8.56 | | | CURING STACKS |
| PM10 | lbs/hr | 2.19 | 2.56 | | | CURING STACKS |

Appendix D
Fuel Usage Calculations

Facility total Fuel burned (Therms)

| | Month | Fuel use | | Average operation (used to determine baseline) | | |
|----------------------------|-----------|----------|----------|--|----------|----------|
| | | therms | Quarters | 24 month | 36 month | 48 month |
| 2021 | March | 26183 | | | | |
| | February | 47114 | 125243 | | | |
| | January | 51946 | | | | |
| 2020 | December | 63231 | | | | |
| | November | 57069 | 190377 | | | |
| | October | 70077 | | | | |
| | September | 68695 | | | | |
| | August | 67147 | 201894 | | | |
| | July | 66052 | | | | |
| | June | 68840 | | | | |
| | May | 40299 | 109139 | | | |
| | April | 0 | | | | |
| | March | 3355 | | | | |
| | February | 63468 | 145019 | | | |
| | January | 78196 | | | | |
| 2019 | December | 73615 | | | | |
| | November | 70756 | 198509 | | | |
| | October | 54138 | | | | |
| | September | 65838 | | | | |
| | August | 69208 | 208078 | | | |
| | July | 73032 | | | | |
| | June | 50934 | | | | |
| | May | 70201 | 197672 | 16233 | | |
| | April | 76537 | | | | |
| | March | 72359 | | | | |
| | February | 71973 | 214609 | 5062 | | |
| | January | 70277 | | | | |
| 2018 | December | 58819 | | | | |
| | November | 79342 | 214372 | 2063 | | |
| | October | 76211 | | | | |
| | September | 72004 | | | | |
| | August | 52999 | 184375 | 4253 | | |
| | July | 59372 | | | | |
| | June | 49933 | | | | |
| | May | 70712 | 185795 | 5329 | 6967 | |
| | April | 65150 | | | | |
| | March | 53989 | | | | |
| | February | 66602 | 194396 | 11501 | 1205 | |
| | January | 73805 | | | | |
| 2017 | December | 51806 | | | | |
| | November | 71291 | 161453 | 6869 | 3615 | |
| | October | 38356 | | | | |
| | September | 56159 | | | | |
| | August | 63074 | 185740 | 4077 | 4961 | |
| | July | 66507 | | | | |
| | June | 68355 | | | | |
| | May | 68578 | 198160 | 4138 | 2457 | 6047 |
| | April | 61227 | | | | |
| | March | 76280 | | | | |
| | February | 73347 | 206050 | 3068 | 7543 | 4643 |
| | January | 56423 | | | | |
| 2016 | December | 49169 | | | | |
| | November | 72457 | 167434 | 2799 | 4954 | 2431 |
| | October | 45808 | | | | |
| | September | 37116 | | | | |
| | August | 67259 | 159781 | 5873 | 929 | 3961 |
| | July | 55406 | | | | |
| | June | 43441 | | | | |
| | May | 41841 | 146325 | 10807 | 3350 | 2739 |
| | April | 61043 | | | | |
| | March | 75724 | | | | |
| | February | 76211 | 209441 | | | |
| | January | 57506 | | | | |
| 2015 | December | 69107 | | | | |
| | November | 68984 | 222162 | | | |
| | October | 84071 | | | | |
| | September | 56296 | | | | |
| | August | 59771 | 174735 | | | |
| | July | 58668 | | | | |
| | June | 48879 | | | | |
| | May | 49641 | 161086 | | | |
| | April | 62566 | | | | |
| | March | 76265 | | | | |
| | February | 75274 | 238920 | | | |
| | January | 87381 | | | | |
| 2014 | December | 76398 | | | | |
| | November | 83681 | 233479 | | | |
| | October | 73400 | | | | |
| | September | 74399 | | | | |
| | August | 78142 | 224503 | | | |
| | July | 71962 | | | | |
| | June | 75776 | | | | |
| | May | 71254 | 222082 | | | |
| | April | 75052 | | | | |
| | March | 57466 | | | | |
| | February | 61803 | 177675 | | | |
| | January | 58406 | | | | |
| Average - normal operation | | 62741 | 188224 | | | |

Baseline period
July 2016 - June 2019

| | | Quarterly Emissions | | | |
|-------|-----------|---------------------|--------|-------|--------|
| | | Nox | PM10 | CO | VOC |
| Month | lb | lb | lb | lb | |
| 2019 | June | | | | |
| | May | 860.3 | 2026.1 | 873.6 | 2454.2 |
| | April | | | | |
| | March | | | | |
| 2018 | February | 934.0 | 2199.7 | 948.4 | 2664.5 |
| | January | | | | |
| | December | | | | |
| | November | 930.3 | 2268.2 | 794.1 | 2640.3 |
| | October | | | | |
| | September | | | | |
| | August | 800.1 | 2132.4 | 485.5 | 2270.8 |
| | July | | | | |
| | June | | | | |
| | May | 806.3 | 2148.8 | 489.3 | 2288.3 |
| | April | | | | |
| | March | | | | |
| 2017 | February | 843.6 | 2248.2 | 511.9 | 2394.2 |
| | January | | | | |
| | December | | | | |
| | November | 699.1 | 1839.0 | 465.1 | 1976.5 |
| | October | | | | |
| | September | | | | |
| | August | 804.3 | 2131.2 | 722.1 | 2273.8 |
| | July | | | | |
| | June | | | | |
| | May | 858.1 | 2273.7 | 770.4 | 2425.9 |
| | April | | | | |
| | March | | | | |
| 2016 | February | 892.2 | 2364.3 | 801.1 | 2522.4 |
| | January | | | | |
| | December | | | | |
| | November | 720.6 | 1638.9 | 361.7 | 2014.5 |
| | October | | | | |
| | September | | | | |
| 2016 | August | 687.7 | 1490.3 | 249.9 | 1922.5 |
| | July | | | | |

| Average Quarter Emissions | | | | |
|---------------------------|-----|------|-----|------|
| Quarter | Nox | PM10 | CO | VOC |
| 1 | 890 | 2271 | 754 | 2527 |
| 2 | 842 | 2150 | 711 | 2389 |
| 3 | 764 | 1918 | 486 | 2156 |
| 4 | 783 | 1915 | 540 | 2210 |

| AQID 10% | | | | |
|----------|-----|------|----|-----|
| Quarter | Nox | PM10 | CO | VOC |
| 1 | 89 | 227 | 75 | 253 |
| 2 | 84 | 215 | 71 | 239 |
| 3 | 76 | 192 | 49 | 216 |
| 4 | 78 | 192 | 54 | 221 |

| Bankable Emissions Reductions | | | | |
|-------------------------------|-----|------|-----|------|
| Quarter | Nox | PM10 | CO | VOC |
| 1 | 801 | 2044 | 678 | 2274 |
| 2 | 757 | 1935 | 640 | 2151 |
| 3 | 688 | 1726 | 437 | 1940 |
| 4 | 705 | 1724 | 486 | 1989 |

| | | | | |
|----------|------|------|------|------|
| Year lb | 2951 | 7428 | 2242 | 8354 |
| year ton | 1.5 | 3.7 | 1.1 | 4.2 |

Appendix E
Draft ERC Certificates S-5256

*San Joaquin Valley
Air Pollution Control District*

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308

Emission Reduction Credit Certificate

DRAFT
S-5256-1

ISSUED TO: UPF CORP
ISSUED DATE: <DRAFT>
LOCATION OF REDUCTION: 3747 STANDARD ST
BAKERSFIELD, CA 93308

For VOC Reductions In The Amount Of:

| Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 |
|-----------|-----------|-----------|-----------|
| 2,274 lbs | 2,151 lbs | 1,940 lbs | 1,989 lbs |

Method Of Reduction

- Shutdown of Entire Stationary Source
- Shutdown of Emissions Units
- Other

Shutdown of fiberglass filament manufacturing facility

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services

*San Joaquin Valley
Air Pollution Control District*

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308

Emission Reduction Credit Certificate

S-5256-2

DRAFT

ISSUED TO: UPF CORP
ISSUED DATE: <DRAFT>
LOCATION OF REDUCTION: 3747 STANDARD ST
BAKERSFIELD, CA 93308

For NOx Reductions In The Amount Of:

| Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 |
|-----------|-----------|-----------|-----------|
| 801 lbs | 757 lbs | 688 lbs | 705 lbs |

Method Of Reduction

- Shutdown of Entire Stationary Source
- Shutdown of Emissions Units
- Other

Shutdown of fiberglass filament manufacturing facility

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services

*San Joaquin Valley
Air Pollution Control District*

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308

Emission Reduction Credit Certificate

S-5256-3

DRAFT

ISSUED TO: UPF CORP
ISSUED DATE: <DRAFT>
LOCATION OF REDUCTION: 3747 STANDARD ST
BAKERSFIELD, CA 93308

For CO Reductions In The Amount Of:

| Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 |
|-----------|-----------|-----------|-----------|
| 678 lbs | 640 lbs | 437 lbs | 486 lbs |

Method Of Reduction

- Shutdown of Entire Stationary Source
- Shutdown of Emissions Units
- Other

Shutdown of fiberglass filament manufacturing facility

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services

*San Joaquin Valley
Air Pollution Control District*

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308

Emission Reduction Credit Certificate

S-5256-4

DRAFT

ISSUED TO: UPF CORP
ISSUED DATE: <DRAFT>
LOCATION OF REDUCTION: 3747 STANDARD ST
BAKERSFIELD, CA 93308

For PM10 Reductions In The Amount Of:

| Quarter 1 | Quarter 2 | Quarter 3 | Quarter 4 |
|-----------|-----------|-----------|-----------|
| 2,044 lbs | 1,935 lbs | 1,726 lbs | 1,724 lbs |

Method Of Reduction

- Shutdown of Entire Stationary Source
- Shutdown of Emissions Units
- Other

Shutdown of fiberglass filament manufacturing facility

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services