

**NOTICE OF PRELIMINARY DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
THE PROPOSED SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed significant modification of Stockton RWCF at 2500 Navy Drive Stockton, California. This project is proposing to install a 4,332 bhp Tier 2 emergency standby engine powering an electrical generator.

The District's analysis of the legal and factual basis for this proposed action, project # N-1212743, is available for public inspection at any District office and at http://www.valleyair.org/notices/public_notices_idx.htm. The emission increases associated with this project is/are: 1,115 lb-NOx/year, 1 lb-SOx/year, 23 lb-PM10/year, 23 lb-PM2.5/year, 221 lb-CO/year and 123 lb-VOC/year. This will be the public's only opportunity to comment on the specific conditions of the modification. If requested, the District will hold a public hearing regarding issuance of this modification. For additional information, please contact the District at (209) 557-6400. Written comments on this project must be sent or postmarked by May 12, 2022 to publicnotices@valleyair.org or **BRIAN CLEMENTS, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356.**