

October 5, 2022

Ted Guth
Scale Microgrid Solutions Inc
51-53 Broad St
Ridgewood, NJ 07450

RE: Notice of Final Action - Authority to Construct
Facility Number: C-10086
Project Number: C-1221881

Dear Mr. Guth:

The Air Pollution Control Officer has issued the Authority to Construct permits to Scale Microgrid Solutions Inc for the installation of two 1,676 brake horsepower lean-burn natural gas-fired IC engines powering electrical generators, at 2647 Condor Rd in Madera, CA. Enclosed are the Authority to Construct permits and a copy of the notice of final action that has been posted on the District's website (www.valleyair.org).

Notice of the District's preliminary decision to issue the Authority to Construct permits was posted on August 25, 2022. The District's analysis of the proposal was also sent to CARB on August 25, 2022. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas at (559) 230-6000.

Sincerely,



Brian Clements
Director of Permit Services

BC:mh

Enclosures

cc: Courtney Graham, CARB (w/ enclosure) via email
cc: Howard Goodman, Scale Microgrid Solutions (w/ enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

Facility # C-10086
SCALE MICROGRID SOLUTIONS, LLC
51-53 S BROAD ST
RIDGEWOOD, NJ 07450

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
3. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
4. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
5. **Source Test:** Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source_testing.htm for source testing resources.
6. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at http://www.valleyair.org/busind/comply/compliance_forms.htm.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at
any of the telephone numbers listed below.**

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

AUTHORITY TO CONSTRUCT

PERMIT NO: C-10086-1-0

ISSUANCE DATE: 10/05/2022

LEGAL OWNER OR OPERATOR: SCALE MICROGRID SOLUTIONS, LLC

MAILING ADDRESS: 51-53 S BROAD ST
RIDGEWOOD, NJ 07450

LOCATION: 2647 CONDOR RD
MADERA, CA 93637

EQUIPMENT DESCRIPTION:

1,676 BHP (CONTINUOUS) MITSUBISHI MODEL GS16R2PTK LEAN-BURN NATURAL GAS-FIRED IC ENGINE WITH A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST SYSTEM POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
6. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
7. This engine shall be operated within the ranges that the source testing has shown result in pollution concentrations within the emissions limits as specified on this permit. [District Rule 4702]
8. The SCR catalyst shall be maintained and replaced in accordance with the recommendations of the catalyst manufacturer or emission control supplier. Records of catalyst maintenance and replacement shall be maintained. [District Rules 2201 and 4702]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO



Brian Clements, Director of Permit Services

C-10086-1-0 : Oct 5 2022 8:00AM -- HONGM : Joint Inspection NOT Required

9. Emissions from this IC engine shall not exceed any of the following limits: 0.030 g-NO_x/bhp-hr (equivalent to 2.5 ppmv @ 15% O₂), 0.033 g-PM₁₀/bhp-hr, 1.965 g-CO/bhp-hr (equivalent to 270 ppmv @ 15% O₂), or 0.042 g-VOC/bhp-hr (equivalent to 10 ppmv @ 15% O₂). [District Rules 2201 and 4702]
10. Ammonia (NH₃) emissions from this engine shall not exceed 10 ppmvd @ 15% O₂. [District Rule 2201]
11. This IC engine shall be fired only on PUC-quality natural gas. [District Rules 2201, 4702, and 4801]
12. Source testing to measure NO_x, CO, VOC, and ammonia (NH₃) emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 1081, 2201, and 4702]
13. Source testing to measure NO_x, CO, and ammonia (NH₃) emissions from this unit shall be conducted at least once every 24 months. [District Rules 1081, 2201, and 4702]
14. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702]
15. The results of each source test shall be submitted to the District within 60 days after completion of the source test. [District Rule 1081]
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
17. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. NO_x, CO, VOC, and NH₃ concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702]
18. The following methods shall be used for source testing: NO_x (ppmv) - EPA Method 7E; CO (ppmv) - EPA Method 10; VOC (ppmv) - EPA Method 18, or 25A or 25B; stack gas oxygen - EPA Method 3 or 3A; stack gas velocity/volumetric flowrate - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4; NH₃ - BAAQMD ST-1B or SCAQMD Method 207-1. Alternative test methods as approved by EPA and the District may be used to address the source testing requirements of this permit. [District Rules 1081, 2201, and 4702]
19. The Higher Heating Value (HHV) of the fuel gas shall be determined using ASTM D1826, ASTM 1945 in conjunction with ASTM D3588, or an alternative method approved by EPA and the District. [District Rules 2201 and 4702]
20. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with an in-line NO_x and O₂ analyzer and a portable CO analyzer during District inspections. The sampling ports shall be located in accordance with the California Air Resources Board (CARB) document titled Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Emission Monitoring and Testing. [District Rule 1081]
21. The permittee shall monitor and record the catalyst inlet and outlet temperatures and ammonia injection rate at least once per week. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702]
22. The minimum acceptable catalyst temperature differential and ammonia injection rate shall be established by source testing this unit. [District Rules 4701 and 4702]

23. If either the catalyst temperature differential or ammonia injection rate is lower than the normal range/level, the permittee shall return the temperature differential and/or ammonia injection rate to the normal range/level as soon as possible, but no longer than 8 hours after detection. If the catalyst temperature differential rate or ammonia injection rate is not returned to the normal range/level within 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new temperature differential or ammonia injection rate. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702]
24. The permittee shall maintain records of: (1) the date and time of temperature and ammonia injection rate measurements, (2) the measured temperatures and ammonia injection rate, and (3) a description of any corrective action taken to maintain the temperature differential and/or the ammonia injection rate within the acceptable range. [District Rules 4701 and 4702]
25. The permittee shall monitor and record the stack concentration of NO_x and O₂ at least once every month (in which a source test is not performed) using an in-line emission monitor that meets District specifications [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
26. The permittee shall monitor and record the stack concentration of CO at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
27. The permittee shall monitor and record the stack concentration of NH₃ at least once every month in which a source test is not performed. NH₃ monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 2201]
28. If the NO_x and NH₃ concentrations corrected to 15% O₂, as measured by the in-line analyzer or the District-approved ammonia monitoring equipment, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the in-line analyzer or ammonia monitoring equipment readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]

29. If the CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule]
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702]
31. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702]
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702]
33. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type of fuel used, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rules 2201 and 4702]
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 1070 and 4702]

AUTHORITY TO CONSTRUCT

PERMIT NO: C-10086-2-0

ISSUANCE DATE: 10/05/2022

LEGAL OWNER OR OPERATOR: SCALE MICROGRID SOLUTIONS, LLC

MAILING ADDRESS: 51-53 S BROAD ST
RIDGEWOOD, NJ 07450

LOCATION: 2647 CONDOR RD
MADERA, CA 93637

EQUIPMENT DESCRIPTION:

1,676 BHP (CONTINUOUS) MITSUBISHI MODEL GS16R2PTK LEAN-BURN NATURAL GAS-FIRED IC ENGINE WITH A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST SYSTEM POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
6. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
7. This engine shall be operated within the ranges that the source testing has shown result in pollution concentrations within the emissions limits as specified on this permit. [District Rule 4702]
8. The SCR catalyst shall be maintained and replaced in accordance with the recommendations of the catalyst manufacturer or emission control supplier. Records of catalyst maintenance and replacement shall be maintained. [District Rules 2201 and 4702]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO



Brian Clements, Director of Permit Services

C-10086-2-0: Oct 5 2022 8:01AM -- HONGM : Joint Inspection NOT Required

9. Emissions from this IC engine shall not exceed any of the following limits: 0.030 g-NO_x/bhp-hr (equivalent to 2.5 ppmv @ 15% O₂), 0.033 g-PM₁₀/bhp-hr, 1.965 g-CO/bhp-hr (equivalent to 270 ppmv @ 15% O₂), or 0.042 g-VOC/bhp-hr (equivalent to 10 ppmv @ 15% O₂). [District Rules 2201 and 4702]
10. Ammonia (NH₃) emissions from this engine shall not exceed 10 ppmvd @ 15% O₂. [District Rule 2201]
11. This IC engine shall be fired only on PUC-quality natural gas. [District Rules 2201, 4702, and 4801]
12. Source testing to measure NO_x, CO, VOC, and ammonia (NH₃) emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 1081, 2201, and 4702]
13. Source testing to measure NO_x, CO, and ammonia (NH₃) emissions from this unit shall be conducted at least once every 24 months. [District Rules 1081, 2201, and 4702]
14. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702]
15. The results of each source test shall be submitted to the District within 60 days after completion of the source test. [District Rule 1081]
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
17. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. NO_x, CO, VOC, and NH₃ concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702]
18. The following methods shall be used for source testing: NO_x (ppmv) - EPA Method 7E; CO (ppmv) - EPA Method 10; VOC (ppmv) - EPA Method 18, or 25A or 25B; stack gas oxygen - EPA Method 3 or 3A; stack gas velocity/volumetric flowrate - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4; NH₃ - BAAQMD ST-1B or SCAQMD Method 207-1. Alternative test methods as approved by EPA and the District may be used to address the source testing requirements of this permit. [District Rules 1081, 2201, and 4702]
19. The Higher Heating Value (HHV) of the fuel gas shall be determined using ASTM D1826, ASTM 1945 in conjunction with ASTM D3588, or an alternative method approved by EPA and the District. [District Rules 2201 and 4702]
20. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with an in-line NO_x and O₂ analyzer and a portable CO analyzer during District inspections. The sampling ports shall be located in accordance with the California Air Resources Board (CARB) document titled Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Emission Monitoring and Testing. [District Rule 1081]
21. The permittee shall monitor and record the catalyst inlet and outlet temperatures and ammonia injection rate at least once per week. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702]
22. The minimum acceptable catalyst temperature differential and ammonia injection rate shall be established by source testing this unit. [District Rules 4701 and 4702]

23. If either the catalyst temperature differential or ammonia injection rate is lower than the normal range/level, the permittee shall return the temperature differential and/or ammonia injection rate to the normal range/level as soon as possible, but no longer than 8 hours after detection. If the catalyst temperature differential rate or ammonia injection rate is not returned to the normal range/level within 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new temperature differential or ammonia injection rate. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702]
24. The permittee shall maintain records of: (1) the date and time of temperature and ammonia injection rate measurements, (2) the measured temperatures and ammonia injection rate, and (3) a description of any corrective action taken to maintain the temperature differential and/or the ammonia injection rate within the acceptable range. [District Rules 4701 and 4702]
25. The permittee shall monitor and record the stack concentration of NO_x and O₂ at least once every month (in which a source test is not performed) using an in-line emission monitor that meets District specifications [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
26. The permittee shall monitor and record the stack concentration of CO at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
27. The permittee shall monitor and record the stack concentration of NH₃ at least once every month in which a source test is not performed. NH₃ monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 2201]
28. If the NO_x and NH₃ concentrations corrected to 15% O₂, as measured by the in-line analyzer or the District-approved ammonia monitoring equipment, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the in-line analyzer or ammonia monitoring equipment readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]

29. If the CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule]
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702]
31. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702]
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702]
33. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type of fuel used, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rules 2201 and 4702]
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 1070 and 4702]