



March 7, 2023

Mr. Tim Braly
Sycamore Cogeneration Facility
PO Box 81438
Bakersfield, CA 93380

Re: Proposed ATC / Certificate of Conformity (Significant Mod)
Facility Number: S-511
Project Number: S-1223126

Dear Mr. Braly:

Enclosed for your review is the District's analysis of an application for Authorities to Construct for the facility identified above. You requested that Certificates of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. The modification authorizes the removal of a condition requiring PM₁₀ source testing from four cogeneration units under PTOs S-511-1 through 4 that is not applicable to the units.

The notice of preliminary decision for this project has been posted on the District's website (www.valleyair.org). After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authorities to Construct with Certificates of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authorities to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Erin Scott, Permit Services Manager, at (559) 230-5900.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

Mr. Tim Braly
Page 2

Thank you for your cooperation in this matter.

Sincerely,

A handwritten signature in cursive script, appearing to read "Brian Clements".

Brian Clements
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: Laura Yannayon, EPA (w/enclosure) via EPS

San Joaquin Valley Air Pollution Control District

Authority to Construct Application Review

Remove Source Testing Condition from Permits to Operate

Facility Name: Sycamore Cogeneration Facility Date: February 7, 2023
Mailing Address: PO Box 81438, Bakersfield, CA 93380 Engineer: Silvana Procopio
Lead Engineer: Steven Davidson
Contact Person: Tim Braly
Telephone: 661.770.6543
E-Mail: timbraly@chevron.com
Application #(s): S-511-1 through '-4
Project #: S-1223126
Deemed Complete: 8/17/2022

I. Proposal

Sycamore Cogeneration has requested an Authority to Construct (ATC) permit for a permit modification to remove a condition requiring PM10 source testing from the four cogeneration units under PTOs S-511-1 through '-4, which reads as follows:

- The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)]*

The condition was originally added under project S-961010, based on the assumption that cogeneration units with a capacity greater than 75 MW could go over the established limit of 5 lb-PM10/hr. Source testing has been performed since 2008, demonstrating continued compliance with the permit limit of 5.0 lb-PM10/hr (see Appendix A). Furthermore, source testing of PM10 emissions is not required by any District Rule that these units are subject to, nor by any requirements under CFR. Therefore, the removal of this condition does not violate any applicable federally enforceable local or federal requirement.

Sycamore Cogeneration received their Title V Permit on October 7, 1999. This modification can be classified as a Title V significant modification pursuant to Rule 2520, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. Sycamore Cogeneration must apply to administratively amend their Title V permit.

II. Applicable Rules

Rule 2201	New and Modified Stationary Source Review Rule (8/15/19)
Rule 2520	Federally Mandated Operating Permits (8/15/19)
Rule 4001	NSPS Subpart GG – Standards of Performance for Stationary Gas Turbines (04/14/99)
Rule 4101	Visible Emissions (02/17/05)
Rule 4102	Nuisance (12/17/92)
Rule 4201	Particulate Matter Concentration (12/17/92)
Rule 4301	Fuel Burning Equipment (12/17/92)
Rule 4703	Stationary Gas Turbines (9/20/07)
Rule 4801	Sulfur Compounds (12/17/92)
CH&SC 41700	Health Risk Assessment
CH&SC 42301.6	School Notice

Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines

III. Project Location

This facility is located at 1546 China Grade Loop, in Bakersfield, CA. The cogeneration units are part of the Heavy Oil Central stationary source, ¼ S32, T28S, R28E. The equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. Process Description

Cogeneration plants produce high quality steam for injection into the oil producing strata to enhance oil production and to produce electricity for use in the oil field. Sycamore sells excess power to Southern California Edison Company.

V. Equipment Listing

Pre-Project Equipment Description:

S-511-1-20: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1)

S-511-2-21: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2)

S-511-3-21: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3)

S-511-4-20: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4)

Proposed Modification:

S-511-1-21: MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1): **REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10**

S-511-2-22: MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2): **REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10**

S-511-3-22: MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3): **REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10**

S-511-4-21: MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4): **REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10**

Post-Project Equipment Description:

S-511-1-21: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1)

S-511-2-22: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2)

S-511-3-22: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3)

S-511-4-21: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4)

VI. Emission Control Technology Evaluation

The combustion turbines utilize GE's proprietary Dry Low NO_x (DLN1+) technology. The DLN1+ technology employs lean premixed combustion to stage combustion, resulting in reduced NO_x formation. The DLN1+ technology is expected to achieve a 3-hour average NO_x limit of 3 ppmv, dry at 15% oxygen. No post-combustion emission control for either NO_x or CO is required with this system.

DLN1+ controls and emissions monitoring sensors allow the gas turbine to maintain a fixed level of NO_x emissions by automatically adjusting the gas turbine fuel splits to compensate for ambient temperature changes and/or hardware degradation over time. Additionally, Combustion Dynamics Monitoring (CDM) is used to verify dynamics levels are within acceptable limits whenever the combustion system is running.

No changes in the existing control technology are proposed.

VII. General Calculations

As shown below in Section VIII of this evaluation, this project does not constitute an NSR modification; therefore, calculations are not required.

VIII. Compliance Determination

Rule 2201 New and Modified Stationary Source Review Rule

This rule applies to all new stationary sources and all modifications to existing stationary sources which are subject to the District permit requirements and after construction emit or may emit one or more affected pollutant.

3.25.1 A modification is an action including at least one of the following items:

3.25.1.1 Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.

This project will not result in a change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.

- 3.25.1.2 Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change

This project will not result in any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions.

- 3.25.1.3 An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.

This project will not result in an increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation

- 3.25.1.4 Addition of any new emissions unit, which is subject to District permitting requirements.

This project will not result in the addition of any new emissions unit which is subject to District permitting requirements.

This project is not a Modification and the facility is not a new stationary source; therefore, the project is not subject to Rule 2201 and no further discussion is required.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule, and has received their Title V Operating Permit. A significant permit modification is defined as a “permit amendment that does not qualify as a minor permit modification or administrative amendment.”

Minor permit modifications do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions. The facility will no longer be required to do source testing for PM10 emissions and submit the associated records to the District, which is a relaxation in monitoring conditions. As a result, the proposed project constitutes a Significant Modification to the Title V Permit.

As discussed above, the facility has applied for a Certificate of Conformity (COC); therefore, the facility must apply to modify their Title V permit with an administrative amendment, prior to operating with the proposed modifications. Continued compliance with this rule is expected. The facility shall not implement the changes requested until the final permit is issued.

The following conditions will be added to the ATCs to ensure compliance:

- *{1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201]*
- *{1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520]*

Rule 4001 NSPS Subpart GG – Standards of Performance for Stationary Gas Turbines

The provisions of this subpart are applicable to all stationary gas turbines with a heat input at peak load equal to or greater than 10 MMBtu/hr, based on the lower heating value of the fuel fired.

The turbines in this project are subject to Subpart GG, which limits oxides of nitrogen and sulfur from stationary gas turbines. The current operating permits include NO_x and SO_x limits that meet the standards of Subpart GG. These operating permit limits will not be changed with this proposal. Furthermore, reporting and notification requirements specified in Subpart A are also contained in the current operating permits. The following condition is included on the current PTOs:

- *This facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 84-01]*

Therefore, continued compliance is expected and no further discussion is necessary.

Rule 4101 Visible Emissions

The provisions of this rule apply to any source operation which emits or may emit air contaminants. The current permit unit requirements limit visible emissions greater than 20% opacity (No. 1 Ringelmann) to periods less than three minutes in any one hour period. The following condition will remain on their PTOs:

- *No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (12/17/92), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101]*

Continued compliance is expected.

Rule 4102 Nuisance

Section 4.0 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 – Risk Management Policy for Permitting New and Modified Sources specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

As demonstrated above, there are no increases in emissions associated with this project; therefore, a health risk assessment is not necessary and no further risk analysis is required.

Rule 4201 Particulate Matter Concentration

This rule limits PM emissions from any source operation to less than 0.1 gr/dscf. The current operating permit limits PM emissions to less than 0.0072 gr/scf at 12% CO₂ for each turbine. The proposed modifications will not alter this limit. The following condition will remain on the PTOs:

- *Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District Rule 2201]*

Therefore, continued compliance is expected and no further discussion is necessary.

Rule 4301 Fuel Burning Equipment

The provisions of this rule apply to any fuel burning equipment except air pollution control equipment. Fuel burning equipment is defined as any furnace, boiler, apparatus, stack, and all appurtenances thereto, used in the process of burning fuel for the primary purpose of producing heat or power by indirect heat transfer.

The cogeneration units involved in this project produce power primarily by mechanical means, not through indirect heat transfer. Therefore, this rule does not apply.

Rule 4703 Stationary Gas Turbines

The provisions of this rule apply to all stationary gas turbine systems, which are subject to District permitting requirements, and with ratings equal to or greater than 0.3 MW or a maximum heat input rating of more than 3 MMBtu/hr.

The cogeneration units in this project have a rating of 75 MW and this rule applies. The proposed changes will not affect compliance with the requirements of this rule. Therefore, no further discussion is necessary.

Rule 4801 Sulfur Compounds

The provisions of this rule shall apply to any discharge to the atmosphere of sulfur compounds, which would exist as a liquid or gas at standard conditions.

The rule limits sulfur compound emission to 0.2% (2,000 ppm) dry volume. SO_x emissions from the turbines are based on combusting natural gas with a fuel sulfur content limited by the operating permit at 0.3 gr/100 scf or less. This fuel S content (assuming 1020 Btu/scf, LHV) results in a SO_x emission concentration of approximately 0.2 ppmvd @ 15% O₂. The modifications in this project do not affect compliance with this rule. Therefore, continued compliance is expected.

California Health & Safety Code 42301.6 (School Notice)

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

Greenhouse Gas (GHG) Significance Determination

District is a Lead Agency & Facility is Subject to Cap-and-Trade

It is determined that no other agency has prepared or will prepare an environmental review document for the project. Thus, the District is the Lead Agency for this project.

On December 17, 2009, the District's Governing Board adopted a policy, APR 2005, *Addressing GHG Emission Impacts for Stationary Source Projects Under CEQA When Serving as the Lead Agency*, for addressing GHG emission impacts when the District is Lead Agency under CEQA and approved the District's guidance document for use by other agencies when addressing GHG impacts as lead agencies under CEQA. Under this policy, the District's determination of significance of project-specific GHG emissions is founded on the principle that projects with GHG emission reductions consistent with AB 32 emission reduction targets are considered to have a less than significant impact on global climate change. Consistent with District Policy 2005, projects complying with an approved GHG emission reduction plan or GHG mitigation program, which avoids or substantially reduces GHG emissions within the geographic area in which the project is located, would be determined to have a less than significant individual and cumulative impact for GHG emission.

The California Air Resources Board (ARB) adopted a Cap-and-Trade regulation as part one of the strategies identified for AB 32. This Cap-and-Trade regulation is a statewide plan, supported by a CEQA compliant environmental review document, aimed at reducing or mitigating GHG emissions from targeted industries. Facilities subject to the Cap-and-Trade regulation are subject to an industry-wide cap on overall GHG emissions. Any growth in emissions must be accounted for under that cap such that a corresponding and equivalent reduction in emissions must occur to allow any increase. Further, the cap decreases over time, resulting in an overall decrease in GHG emissions.

Under District policy APR 2025, *CEQA Determinations of Significance for Projects Subject to ARB's GHG Cap-and-Trade Regulation*, the District finds that the Cap-and-Trade is a regulation plan approved by ARB, consistent with AB32 emission reduction targets, and supported by a CEQA compliant environmental review document. As such, consistent with District Policy 2005, projects complying with Cap-and-Trade requirements are determined to have a less than significant individual and cumulative impact for GHG emissions.

Industries covered by Cap-and-Trade are identified in the regulation under Section 95811, Covered Entities¹:

1. Group 1: Large industrial facilities

These types of facilities are subject to Cap and Trade, and the specific companies covered are listed at <http://www.arb.ca.gov/cc/capandtrade/capandtrade.htm>,

¹ https://ww2.arb.ca.gov/sites/default/files/2021-02/ct_reg_unofficial.pdf

Section 95811 (a), under the “Publicly Available Market Information” section (list maintained by the California Air Resources Board).

2. Group 2: Electricity generation facilities located in California, or electricity importers
These types of facilities are subject to Cap and Trade (section 95811, b).
3. Group 3: Suppliers of Natural Gas, Suppliers of Reformulated Gasoline Blendstock for Oxygenate Blending and Distillate Fuel Oil, Suppliers of Liquefied Petroleum Gas, and Suppliers of Blended Fuels

These entities are subject to Cap and Trade compliance obligations which must cover all fuels (except jet fuels) identified in section 95811 (c) through (f) of the Cap-and-Trade regulation delivered to end users in California, less the fuel delivered to covered entities (group 1 above).

This facility is subject to the Cap-and-Trade regulation. Therefore, as discussed above, consistent with District Policies APR 2005 and APR 2025, the District concludes that the GHG emissions increases associated with this project would have a less than significant individual and cumulative impact on global climate change.

District CEQA Findings

The District is the Lead Agency for this project because there is no other agency with broader statutory authority over this project. The District performed an Engineering Evaluation (this document) for the proposed project and determined that for each emissions unit affected by the project the potential project emission increase is equal to or less than 2 lbs per day per pollutant. Therefore, the potential project emission increase is considerably below all annual criteria emissions CEQA significant thresholds. The activity will occur at an existing facility and involves negligible expansion of the existing or former use. Furthermore, the District determined that the activity will not have a significant effect on the environment. Therefore, the District finds that the activity is categorically exempt from the provisions of CEQA pursuant to CEQA Guideline § 15301 (Existing Facilities), and finds that the project is exempt per the common sense exemption that CEQA applies only to projects which have the potential for causing a significant effect on the environment (CEQA Guidelines §15061(b)(3)).

Indemnification Agreement/Letter of Credit Determination

According to District Policy APR 2010 (CEQA Implementation Policy), when the District is the Lead or Responsible Agency for CEQA purposes, an indemnification agreement and/or a letter of credit may be required. The decision to require an indemnity agreement and/or a letter of credit is based on a case-by-case analysis of a particular project’s potential for litigation risk, which in turn may be based on a project’s potential to generate public concern, its potential for significant impacts, and the project proponent’s ability to pay for the costs of litigation without a letter of credit, among other factors.

The criteria pollutant emissions and toxic air contaminant emissions associated with the proposed project are not significant, and there is minimal potential for public concern for this particular type of facility/operation. Therefore, an Indemnification Agreement and/or a Letter of Credit will not be required for this project in the absence of expressed public concern.

IX. Recommendation

Compliance with all applicable rules and regulations is expected. Pending a successful EPA Noticing period, issue ATCs S-511-1-23, '-2-24, '-3-23, and '-4-25, subject to the permit conditions on the attached draft ATCs in Appendix B.

X. Billing Information

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
S-511-1-21	3020-08A-G	75 MW cogeneration unit	\$12,254
S-511-2-22	3020-08A-G	75 MW cogeneration unit	\$12,254
S-511-3-22	3020-08A-G	75 MW cogeneration unit	\$12,254
S-511-4-21	3020-08A-G	75 MW cogeneration unit	\$12,254

Appendices:

- A: Source Test Results Summary
- B: Certificate of Conformity
- C: Current PTOs
- D: Draft ATCs

Appendix A: Source Test Results Summary

Facility ID: S-511

Facility Name: Sycamore Cogeneration

PTO: S-511-1

Source Test Date	PM10 Emissions Rate Limit (lb/hr)	PM10 Results (lb/hr)	Deviation from limit (%)
4/24/2008	5	1.97	-61
5/31/2013		2.27	-55
6/18/2018		3.96	-21

PTO: S-511-2

Source Test Date	PM10 Emissions Rate Limit (lb/hr)	PM10 Results (lb/hr)	Deviation from limit (%)
4/24/2008	5	1.87	-63
5/30/2013		1.65	-67
6/27/2018		3.87	-23

PTO: S-511-3

Source Test Date	PM10 Emissions Rate Limit (lb/hr)	PM10 Results (lb/hr)	Deviation from limit (%)
5/20/2008	5	3.54	-29
5/29/2013		2.36	-53
6/12/2018		4.13	-17

PTO: S-511-4

Source Test Date	PM10 Emissions Rate Limit (lb/hr)	PM10 Results (lb/hr)	Deviation from limit (%)
6/11/2008	5	3.06	-39
5/28/2013		2.46	-51
6/20/2018		3.07	-39

Appendix B:
Certificate of Conformity



San Joaquin Valley Air Pollution Control District



TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

ADMINISTRATIVE AMENDMENT MINOR MODIFICATION SIGNIFICANT MODIFICATION

COMPANY NAME: Sycamore Cogeneration Facility	FACILITY ID: S-511
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name:	
3. Agent to the Owner: Jay Blackmon	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial **applicable** circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true, accurate, and complete.
- For minor modifications, this application meets the criteria for use of minor permit modification procedures pursuant to District Rule 2520.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

Jay Blackmon

Signature of Responsible Official

6/9/2022

Date

Jay Blackmon

Name of Responsible Official (please print)

Asset Manager

Title of Responsible Official (please print)

Appendix C: Current PTOs

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-1-20

EXPIRATION DATE: 11/30/2026

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration. [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
51. Each CGT shall have a fuel consumption monitor/recorder. [District Rule 2201 and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
52. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

53. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
54. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
55. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
56. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
59. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
60. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit
63. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
64. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

66. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
67. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
68. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
70. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deem compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-2-21

EXPIRATION DATE: 11/30/2026

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration. [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NO_x, CO and O₂ or CO₂ concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
51. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
52. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
53. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

54. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
55. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
56. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
57. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit
64. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
65. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
66. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

67. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
68. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
71. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deem compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-3-21

EXPIRATION DATE: 11/30/2026

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
9. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
19. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NOx, CO and O2 or CO2 concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
21. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
22. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
23. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
26. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
27. Source testing to determine NO_x and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
29. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
30. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
31. The operator shall perform source testing for PM₁₀ concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
32. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
36. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
37. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

38. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
39. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
40. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
41. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration. [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
44. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
45. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
46. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
47. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
48. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
49. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
50. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
51. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
52. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

53. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit
54. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
55. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
56. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
57. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit
64. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
65. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

66. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
68. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
71. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-4-20

EXPIRATION DATE: 11/30/2026

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NO_x and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM₁₀ concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
51. Each CGT shall have a fuel consumption monitor/recorder. [District Rule 2201 and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
52. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

53. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
54. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
55. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
56. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
59. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
60. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit
63. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
64. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

66. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
67. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
68. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
70. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deem compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Appendix D: Draft ATCs

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-511-1-21

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION FACILITY

MAILING ADDRESS: PO BOX 81438
BAKERSFIELD, CA 93380-1438

LOCATION: HEAVY OIL CENTRAL
1546 CHINA GRADE LOOP
BAKERSFIELD, CA 93308

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1): REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The combustion turbine generator (CTG) combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

Brian Clements, Director of Permit Services

S-511-1-21 : Feb 7 2023 3:00PM -- PROCOPIS : Joint Inspection NOT Required

6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 5.0 lb/hr, SO_x (as SO₂) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 120.0 lb/day, SO_x (as SO₂) - 21.6 lb/day, NO_x (as NO₂) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
9. Emission rates from CTG, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NO_x (as NO₂) - 3 ppmvd @ 15% O₂, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O₂, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. NO₂ and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
11. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NO_x on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Annual NO_x emissions (as NO₂) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NO_x / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CTG is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NO_x performance test nor shall NO_x emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CTG shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
19. CTG may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CTG's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

22. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
23. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
24. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
25. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
27. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703] Federally Enforceable Through Title V Permit
30. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
31. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703] Federally Enforceable Through Title V Permit
32. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CTG flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
37. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
38. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
39. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
40. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080] Federally Enforceable Through Title V Permit
41. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration. [40 CFR 60.334(b),(c) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
43. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520 and 4703] Federally Enforceable Through Title V Permit
44. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
45. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
46. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520 and 4703; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
47. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
48. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
49. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

50. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
51. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
52. Each CTG shall have a fuel consumption monitor/recorder. [District Rule 2201 and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
53. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit
54. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CTG fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
55. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
56. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
57. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080 and 1100; and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. CTG shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703] Federally Enforceable Through Title V Permit
65. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520] Federally Enforceable Through Title V Permit
66. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
68. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
71. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deem compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
74. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-511-2-22

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION FACILITY

MAILING ADDRESS: PO BOX 81438
BAKERSFIELD, CA 93380-1438

LOCATION: HEAVY OIL CENTRAL
1546 CHINA GRADE LOOP
BAKERSFIELD, CA 93308

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2): REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CTG combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services

S-511-2-22 : Feb 7 2023 3:00PM -- PROCOPIS : Joint Inspection NOT Required

6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 5.0 lb/hr, SO_x (as SO₂) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 120.0 lb/day, SO_x (as SO₂) - 21.6 lb/day, NO_x (as NO₂) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
9. Emission rates from CTG, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NO_x (as NO₂) - 3 ppmvd @ 15% O₂, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O₂, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. NO₂ and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
11. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NO_x on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Annual NO_x emissions (as NO₂) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NO_x / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CTG is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NO_x performance test nor shall NO_x emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CTG shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
19. CTG may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CTG's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
23. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
24. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
25. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
27. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703] Federally Enforceable Through Title V Permit
30. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
31. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703] Federally Enforceable Through Title V Permit
32. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CTG flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
37. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
38. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
39. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
40. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080] Federally Enforceable Through Title V Permit
41. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration. [40 CFR 60.334(b),(c), and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
43. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520 and 4703] Federally Enforceable Through Title V Permit
44. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
45. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
46. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520 and 4703; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
47. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703] Federally Enforceable Through Title V Permit
48. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
49. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

50. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
51. When CTG exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NO_x, CO and O₂ or CO₂ concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
52. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
53. Each CTG shall have a fuel consumption monitor/recorder. [District Rule 2201 and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
54. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit
55. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CTG fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
56. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
57. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
58. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080; and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
60. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080] Federally Enforceable Through Title V Permit
61. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080 and 1100; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
62. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. CTG shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit
65. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703] Federally Enforceable Through Title V Permit
66. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
68. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
69. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
72. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
75. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-511-3-22

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION FACILITY

MAILING ADDRESS: PO BOX 81438
BAKERSFIELD, CA 93380-1438

LOCATION: HEAVY OIL CENTRAL
1546 CHINA GRADE LOOP
BAKERSFIELD, CA 93308

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3): REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CTG combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services

S-511-3-22 : Feb 7 2023 3:00PM -- PROCOPIS : Joint Inspection NOT Required

6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 5.0 lb/hr, SO_x (as SO₂) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 120.0 lb/day, SO_x (as SO₂) - 21.6 lb/day, NO_x (as NO₂) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Emission rates from CTG, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NO_x (as NO₂) - 3 ppmvd @ 15% O₂, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O₂, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NO_x on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
11. NO₂ and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
12. Annual NO_x emissions (as NO₂) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NO_x / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CTG is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NO_x performance test nor shall NO_x emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CTG shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
19. CTG may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CTG's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
21. When CTG exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NO_x, CO and O₂ or CO₂ concentration. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
23. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
24. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
25. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
28. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. Source testing to determine NO_x and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
31. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
32. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
33. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
35. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

36. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CTG flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
37. {2250} The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
38. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
39. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
40. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
41. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
42. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
43. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
45. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
46. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
47. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
48. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
49. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

50. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
51. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
52. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
53. Each CTG shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
54. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit
55. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CTG fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
56. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
57. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
58. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
60. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
61. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
62. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. CTG shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit
65. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
66. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
68. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
69. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
72. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
75. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-511-4-21

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION FACILITY
MAILING ADDRESS: PO BOX 81438
BAKERSFIELD, CA 93380-1438

LOCATION: HEAVY OIL CENTRAL
1546 CHINA GRADE LOOP
BAKERSFIELD, CA 93308

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4): REMOVE CONDITION REQUIRING SOURCE TESTING FOR PM10

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CTG combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

DRAFT

Brian Clements, Director of Permit Services

S-511-4-21 : Feb 7 2023 3:00PM -- PROCOPIS : Joint Inspection NOT Required

6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 5.0 lb/hr, SO_x (as SO₂) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CTG shall not exceed any of the following: PM₁₀ - 120.0 lb/day, SO_x (as SO₂) - 21.6 lb/day, NO_x (as NO₂) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
9. Emission rates from CTG, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NO_x (as NO₂) - 3 ppmvd @ 15% O₂, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O₂, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. NO₂ and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
11. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NO_x on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Annual NO_x emissions (as NO₂) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NO_x / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CTG is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NO_x performance test nor shall NO_x emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CTG shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District Rule 2201] Federally Enforceable Through Title V Permit
19. CTG may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CTG's through HRSG's to the atmosphere shall be gas-tight. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
23. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
24. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
25. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
27. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
30. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
31. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
32. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CTG flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
37. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
38. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
39. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
40. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
41. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
44. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
45. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
46. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
47. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
48. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
49. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

50. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
51. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
52. Each CTG shall have a fuel consumption monitor/recorder. [District Rule 2201 and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
53. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District Rule 2201] Federally Enforceable Through Title V Permit
54. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CTG fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
55. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
56. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
57. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. CTG shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District Rule 2201; Kern County Rule 407] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
65. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
66. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
68. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
71. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deem compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT