

**NOTICE OF FINAL ACTION  
FOR THE ISSUANCE OF  
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permit to Children's Hospital of California for a 762 horsepower Tier 2 diesel engine with selective catalytic reduction, a diesel particulate filter, and an oxidation catalyst for tier 4F compliant emissions to provide emergency power in the event of an electrical outage, at 40979 Goodwin Way, Madera.

No comments were received following the District's preliminary decision on this project.

The application review for Project # C-1223500 is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm), the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.