## San Joaquin Valley Unified Air Pollution Control District

## **Best Performance Standard (BPS) x.x.xx**

Date: May 10, 2010

Class	Gasoline Dispensing Facilities (GDFs)
Category	GDFs with Underground Storage Tanks (USTs) and Phase II EVR Vapor Recovery System
Best Performance Standard	ARB-certified non-combustion based Phase II vapor recovery systems
Percentage Reduction in GHG Emissions Relative to Baseline Emissions	74.3%

District Project Number	C-1100389
Evaluating Engineer	Sajjad Ahmad
Lead Engineer	Jim Swaney, P.E.
Initial Public Notice Date	April 8, 2010
Final Public Notice Date	April 30, 2010
Determination Effective Date	May 12, 2010