

# Calibration Sheet For Pressure Measuring Device

Date: \_\_\_\_\_

Equipment:  Mechanical  Digital

Serial Number: \_\_\_\_\_

20% of scale \_\_\_\_\_ (incline) \_\_\_\_\_ (actual)

50% of scale \_\_\_\_\_ (incline) \_\_\_\_\_ (actual)

80% of scale \_\_\_\_\_ (incline) \_\_\_\_\_ (actual)

Calibration check can be done using a 2" incline manometer. For pressure measuring devices great than 2", use a 2" scale. Pressure measuring devices below 2" shall be based on the scale of the pressure-measuring device.

Company Name: \_\_\_\_\_

Person conducting calibration: \_\_\_\_\_

Signature: \_\_\_\_\_