San Joaquin Valley Air Pollution Control District Supplemental Application Form

Emergency/Low-Use IC Engines for Non-Agricultural Operations

Please complete one form for each engine.

This form must be accompanied by a completed Application for Authority to Construct and Permit to Operate form

PERMIT TO BE ISSUED TO:

LOCATION WHERE THE EQUIPMENT WILL BE OPERATED:								
EQUIPMENT DESCRIPTION								
Engine Details	Engine Manufacturer:		Number of Cylinders:					
	Engine Model:		Engine Year of Manufacture:					
	Engine Serial Number:		Engine Tier Rating:					
	Engine Certification Family Number:							
	Engine's Type of Combustion: Rich-Burn Lean-Burn 4-Stroke 2-Stroke							
	Engine Manufacturer's Maximum Rated Power Output (per the data plate): bhp							
	Engine's Rated Power Output for the Process the Engine Serves: bhp							
Process Data	Process the Engine Serves:							
	Electrical Power	Generator Manufacturer:	Model:					
	Generation Only	Power Output: kW						
	Will this equipment be used in an electric utility rate reduction program? Yes No							
	Fuel Type: Diesel Natural Gas LPG/Propane Gasoline Other:							
Fuel Data	For "Other" fuels only: Higher Heating Value: Btu/scf, or Btu/gal,							
	For "Other" fuels only: An Ultimate Fuel Analysis or the combustion F-Factordscf/MMBtu							
	Sulfur Content: gr/100 scf (gaseous fuel) or % by weight (liquid fuel)							
	Fuel Consumption at Maximum Rated Output: gal/hr, or scf/hr							
Rule 4702 Type of Use	 Emergency Standby - Limited exclusively to power primary mechanical or an electrical generator during periods of unscheduled power outages beyond the control of the operator, and limited from 20 to 100 hrs/yr (depending on the engine's PM₁0 emission factor) for maintenance and testing purposes only. This engine is specifically used to power a pump for a municipal water supply. I request the higher opacity limit of 40% with the corresponding operational limits of 30 minutes per week and 2 hours per month for maintenance and testing. (CH&SC 41701.6) I request the lower opacity limit of 20%. This engine is specifically used to provide power at a health care facility. (CH&SC 1250) This engine is subject to Office of Statewide Health Planning and Development (OSHPD) requirements. Special Case Emergency - Limited exclusively to preserve or protect property, human life, or public health during a disaster or a state emergency (e.g. fire or flood) and limited to 20 to 100 hrs/yr (depending on the engine's PM₁0 emission factor) for maintenance and testing purposes only. This engine is specifically used to power a direct-drive firewater pump. This firewater pump engine is subject to National Fire Protection Association (NFPA) requirements. Low Use - Limited to ≤ 200 hrs/yr of operation for ALL purposes combined, including maintenance and testing. 							
Hour Meter	Note: All engines are required to have either a nonresettable elapsed time meter or an alternate device, method, or technique, approved by the APCO, for determining elapsed operating time. Equipped with a Nonresettable Elapsed Operating Time Meter Alternate Method (please provide details):							

EMISSIONS CONTROL

	Positive Crankcase Ventilation System 90% Efficient crankcase emission control device								
	☐ Turbocharger ☐ Intercooler/Aftercooler								
Emissions	Automatic Air/Fuel Ratio or O ₂ Controller - Manufacturer:								
Control	Non-Selective Catalytic Reduction: Manufacturer: Model:								
Equipment	Control Efficiencies: NO _X %, SO _X %, PM ₁₀ %, CO%, VOC%								
(Check all that apply)	Control Efficiencies: NO _X %, SO _X %, PM ₁₀ %, CO%, VOC% Particulate Filter - Manufacturer: Model: Control Efficiency:%								
	Control Efficiency: %								
	Other (please								
EMISSIONS DATA									
Note: See District BACT and District Rule 4702 requirements for applicability to proposed engine at http://www.valleyair.org/busind/pto/bact/chapter3.pdf and http://www.valleyair.org/busind/pto/bact/chapter3.pdf and http://www.valleyair.org/busind/pto/bact/chapter3.pdf and http://www.valleyair.org/rules/currntrules/r4702.pdf .									
imp.//www.vaneyan.org	/busind/pto/bacvenapter3.pdi and http://w			/w.vaneyair.org/rules/currntrules/r4/02.pdf.					
Emissions Data	Pollutant		(g/bhp-h	ır)	(g/kW-hr)	(ppmvd)			
	Nitrogen Oxides (NO _x)								
	Volatile Organic Compounds (VOC)								
	$NO_x + NMHC$								
	Particulate Matter (PM ₁₀)								
	Carbon Monoxide								
	% O ₂ , dry basis, if corrected to other than 15%: %								
Source of Data	 ☐ Manufacturer's Specifications ☐ Other ☐ Manufacturer's Specification ☐ CARB/EPA Certification Note: please provide copies of all sources of emissions data. 								
		HEALTH RI	SK ASSESSI	MENT I	DATA				
Operating Hours	Maximum Operating Schedule: hours per day, and hours per year								
	Distance to nearest Residence			Distance is measured from the proposed stack location to the nearest					
Receptor Data	Direction to		-	boundary of the nearest apartment, house, dormitory, etc.					
	nearest Residence			Direction from the stack to the receptor, i.e. Northeast or South.					
	Distance to nearest Business	feet		Distance is measured from the proposed stack location to the nearest boundary of the nearest office building, factory, store, etc.					
	Direction to			Direction from the stack to the receptor, i.e. North or Southwest.					
	nearest Business		1 ,						
Stack Parameters	Release Height		ve grade						
	Stack Diameter	inches at point of release							
	Rain Cap								
Exhaust Data	Direction of Flow	Vertically Upward Horizontal Other: of from vert. or of from horiz.							
Exhaust Data Transportable	Flowrate: acfm								
•	_								
Facility Location	Urban (area of dense population) Rural (area of sparse population)								