



# San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

DEC 24 2014



HEALTHY AIR LIVING™

Mr. Daniel Mudge  
Freeport McMoran Oil & Gas  
1200 Discovery Drive, Suite 100  
Bakersfield, CA 93309

**Re: Proposed ATC / Certificate of Conformity (Significant Mod)-Revised  
District Facility # S-1372  
Project # 1143358**

Dear Mr. Mudge:


Enclosed for your review is the District's analysis of an application for Authority to Construct for the facility identified above. You requested that a Certificate of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. Our analysis includes your revised proposal for offsetting emissions increases for the installation of two steam generators using different banked emissions reduction credits. This is the only revision to the project which was approved with preliminary decision published on November 11, 2014 and sent to CARB and US EPA Region IX on November 4, 2014.

After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authority to Construct with a Certificate of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authority to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,

  
Arnaud Marjollet  
Director of Permit Services

AM:RE/st

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email  
cc: Gerardo C. Rios, EPA (w/enclosure) via email

**Seyed Sadredin**

Executive Director/Air Pollution Control Officer

---

**Northern Region**

4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**

1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**

34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

**San Joaquin Valley Air Pollution Control District**  
**Authority to Construct Application Review**  
Two New 85 MMBtu/hr Steam Generators

**REVISED PRELIMINARY DECISION DOCUMENT**

Facility Name: Freeport McMoran Oil & Gas

Date: December 17, 2014

Mailing Address: 1200 Discovery Drive, Suite 100  
Bakersfield, CA 93309

Engineer: Richard Edgehill  
Lead Engineer: Richard Karrs

Contact Person: Daniel Mudge

Telephone: (661) 395-5458

Application #(s): S-1372-417-0 and '418-0

Project #: 1143358

Deemed Complete: May 10, 2014

---

**I. PROPOSAL:**

**Note: FMM has amended their original offset proposal to include the use of different banked emissions reductions credits (ERC). No other changes were proposed or approved. This amended document includes the District's review the revised offset package and is being re-noticed as required.**

Freeport McMoran Oil & Gas (FMM) is requesting Authorities to Construct (ATCs) for two new 85 MMBtu/hr natural gas fired steam generators, one at the Dome lease and the other at the Hopkins lease

The project is a Federal Major Modification requiring BACT, offsets, and public notice.

FMM facility S-1372 has a Title V permit. The project is a Federal Major Modification; therefore, it is classified as a Title V Significant Modification pursuant to Rule 2520, Section 3.20, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. FMM must apply to administratively amend their Title V Operating Permit to include the requirements of the ATC(s) issued with this project

**II. APPLICABLE RULES:**

Rule 2201 New and Modified Stationary Source Review Rule (4/21/11)  
Rule 2410 Prevention of Significant Deterioration (6/16/11)  
Rule 2520 Federally Mandated Operating Permits (June 6, 2001)  
Rule 4001 New Source Performance Standards Subpart Dc (April 14, 1999)  
Rule 4101 Visible Emissions (February 17, 2005)

Rule 4102 Nuisance (December 17, 1992)  
Rule 4201 Particulate Matter Concentration (December 17, 1992)  
Rule 4301 Fuel Burning Equipment (December 17, 1992)  
Rule 4305 Boilers, Steam Generators, and Process Heaters - Phase 2 (August 21, 2003)  
Rule 4306 Boilers, Steam Generators, and Process Heaters - Phase 3 (October 16, 2008)  
Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters - Phase 3 (October 16, 2008)  
Rule 4351 Boilers, Steam Generators, and Process Heaters - Phase 1 (August 21, 2003)  
Rule 4801 Sulfur Compounds (December 17, 1992)  
CH&SC 41700 Health Risk Assessment  
CH&SC 42301.6 School Notice  
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)  
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines

### III. PROJECT LOCATION:

The steam generator in this project is permitted to operate in the FMM's heavy oil western stationary source (HOWSS).

Proposed locations of the steam generator are listed in the table below.

Unit	Proposed Locations
S-1372-417-0	Dome Lease, Midway Sunset Field NW Section 23, T31S, R22E
S-1372-418-0	Hopkins Lease, South Belridge Field NW Section 10, T29S R21E

The proposed locations are not within a 1,000 feet of any K-12 school.

Location maps are included in **Attachment I**.

### IV. PROCESS DESCRIPTION:

FMM operates permitted equipment utilized for the production of crude oil and natural gas. In thermally enhanced oil recovery (TEOR) operations, natural gas is combusted in steam generators to produce steam for injection into heavy crude oil bearing strata via injection wells to reduce the viscosity of the crude oil, thereby facilitating thermally enhanced oil production.

In this project FMM is proposing to install two 85 MMBtu/hr steam generators.

**V. EQUIPMENT LISTING:**

S-1372-417-0: 85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#71), WITH NORTH AMERICAN GLE ULTRA LOW NOX BURNER (OR EQUIVALENT) AND A FLUE GAS RECIRCULATION SYSTEM (DOME)

S-1372-418-0: 85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR, WITH NORTH AMERICAN GLE ULTRA LOW NOX BURNER (OR EQUIVALENT) AND A FLUE GAS RECIRCULATION SYSTEM (HOPKINS)

As per District policy APR 1035 Flexibility in Equipment Descriptions in ATCs, some flexibility in the final specifications of the equipment is requested and will be allowed as stated in the following ATC conditions:

*The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201]*

*The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2010]*

*Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201]*

*No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201]*

**VI. EMISSION CONTROL TECHNOLOGY EVALUATION:**

Emissions from gas-fired steam generators include NO<sub>x</sub>, CO, VOC, PM<sub>10</sub>, and SO<sub>x</sub>.

Low-NO<sub>x</sub> burners reduce NO<sub>x</sub> formation by producing lower flame temperatures (and longer flames) than conventional burners. Conventional burners thoroughly mix all the fuel and air in a single stage just prior to combustion, whereas low-NO<sub>x</sub> burners delay the mixing of fuel and air by introducing the fuel (or sometimes the air) in multiple stages. Generally, in the first combustion stage, the air-fuel mixture is fuel rich. In a fuel rich environment, all the oxygen will be consumed in reactions with the fuel, leaving no excess oxygen available to react with nitrogen to produce thermal NO<sub>x</sub>. In the secondary and tertiary stages, the combustion zone is maintained in a fuel-lean environment. The excess air in these stages helps to reduce the flame temperature so that the reaction between the excess oxygen with nitrogen is minimized.

The use of flue gas re-circulation (FGR) can reduce nitrogen oxides (NO<sub>x</sub>) emissions by 60 - 70%. In an FGR system, a portion of the flue gas is re-circulated back to the inlet air. As flue gas is composed mainly of nitrogen and the products of combustion, it is much lower in oxygen than the inlet air and contains virtually no combustible hydrocarbons to burn. Thus, flue gas is practically inert. The addition of an inert mass of gas to the combustion reaction serves to absorb heat without producing heat, thereby lowering the flame temperature. Since thermal NO<sub>x</sub> is formed by high flame temperatures, the lower flame temperatures produced by FGR serve to reduce thermal NO<sub>x</sub>.

## VII. General Calculations

### A. Assumptions

- The maximum operating schedule is 24 hours per day (per applicant)
- EPA F-factor for natural gas is 8,578 dscf/MMBtu (40 CFR 60, Appendix B)
- Natural/Field Gas Heating Value: 1,000 Btu/scf (District Practice)
- Maximum daily emissions are based on one startup and one shutdown (each) per day. Annual emissions are based on steady state emissions for 8760 hr/yr.
- 

### B. Emission Factors

Pollutant	Post-Project Emission Factors (EF2)			Source
NO <sub>x</sub>	6.2 lb-NO <sub>x</sub> /MMscf	0.0062 lb-NO <sub>x</sub> /MMBtu	5 ppmvd NO <sub>x</sub> (@ 3%O <sub>2</sub> )	proposed
SO <sub>x</sub>	2.85 lb-SO <sub>x</sub> /MMscf	0.00285 lb SO <sub>2</sub> /MMBtu		District standard for natural gas
PM10	0.003 lb-PM10/MMscf	0.003 lb-PM10/MMBtu		FYI-328
CO	18.5 lb-CO/MMscf	0.0185 lb-CO/MMBtu	25 ppmv CO @3% O <sub>2</sub>	BACT
VOC	3.0 lb-VOC/MMscf	0.003 lb-VOC/MMBtu	7 ppmv VOC @3% O <sub>2</sub>	proposed

Startup and shutdown (applicant email 8-8-14)

NO<sub>x</sub>: 15 ppmv @ 3% O<sub>2</sub>, 0.018 lb/MMBtu

CO: 100 ppmv @ 3% O<sub>2</sub>, 0.074 lb/MMBtu

## C. Calculations

### 1. Pre-Project Potential to Emit (PE1)

S-1372-417-0 and '-418-0

Since these are new emissions units, PE1 = 0 for all pollutants.

### 2. Post Project Potential to Emit (PE2)

ATC S-1372-417 and '-418 (each)

Pollutant	Daily PE2			
	EF2 (lb/MMBtu)	Heat Input (MMBtu/hr)	Operating Schedule (hr/day)	Daily PE2 (lb/day)
NO <sub>x</sub>	0.0062	85	24	see below
SO <sub>x</sub>	0.00285	85	24	5.8
PM <sub>10</sub>	0.0030	85	24	6.1
CO	0.019	85	24	see below
VOC	0.0030	85	24	6.1

Pollutant	Annual PE2			
	EF2 (lb/MMBtu)	Heat Input (MMBtu/hr)	Operating Schedule (hr/year)	Annual PE2 (lb/year)
NO <sub>x</sub>	0.006	85	8,760	4,617
SO <sub>x</sub>	0.00285	85	8,760	2,122
PM <sub>10</sub>	0.0030	85	8,760	2,234
CO	0.019	85	8,760	13,775
VOC	0.0030	85	8,760	2,234

#### Daily Startup and Shutdown

NO<sub>x</sub>:  $(0.018 \text{ lb/MMBtu} \times 4 \text{ hr/day} + 0.0062 \text{ lb/MMBtu} \times 20 \text{ hr/day}) \times 85 \text{ MMBtu/hr}$   
= 16.7 lb/day

CO:  $(0.074 \text{ lb/MMBtu} \times 4 \text{ hr/day} + 0.0185 \text{ lb/MMBtu} \times 20 \text{ hr/day}) \times 85 \text{ MMBtu/hr}$   
= 56.6 lb/day



### Total Annual Emissions for Project

Pollutant	Total Annual Post-Project Potential to Emit (PE2)		
	Emissions per Steam Generator	No of Steam Generators	Total Emissions (lb/year)
NO <sub>x</sub>	4,617	2	9,234
SO <sub>x</sub>	2,122	2	4,244
PM <sub>10</sub>	2,234	2	4,468
CO	13,775	2	27,550
VOC	2,234	2	4,468

Emissions Profiles Included in **Attachment II**.

### 3. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

SSPE1 (lb/year)					
Permit Unit	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC
SSPE1*	422,007	2,545,464	370,808	2,768,044	424,926

\*SSPE calculator 8-16-14

### 4. Post Project Stationary Source Potential to Emit (SSPE2)

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site.

SSPE2 (lb/year)					
Permit Unit	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC
SSPE1*	422,007	2,545,464	370,808	2,768,044	424,926
ATC S-1372-417 and '-418	9,234	4,244	4,468	27,550	4,468
SSPE2	431,241	2,549,708	375,276	2,795,594	429,394

### 5. Major Source Determination

#### Rule 2201 Major Source Determination:

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For

the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source
- Emissions from non-road IC engines (i.e. IC engines at a particular site at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Rule 2201 Major Source Determination (lb/year)					
	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC
Facility emissions pre-project	422,007	2,545,464	370,808	2,768,044	424,926
Facility emissions – post project	431,241	2,549,708	375,276	2,795,594	429,394
Major Source Threshold	20,000	140,000	140,000	200,000	20,000
Major Source?	Yes	Yes	Yes	Yes	Yes

As seen in the table above, the facility is an existing Major Source for all criterion air contaminants.

**Rule 2410 Major Source Determination:**

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). Therefore the PSD Major Source threshold is 250 tpy for any regulated NSR pollutant and 100,000 tpy for CO<sub>2</sub>e.

PSD Major Source Determination (tons/year)						
	NO <sub>2</sub>	VOC	SO <sub>2</sub>	CO	PM	PM <sub>10</sub>
Estimated Facility PE before Project Increase	211	212	1272	1384	185	185
PSD Major Source Thresholds	250	250	250	250	250	250
PSD Major Source ? (Y/N)	N	N	Y	Y	N	N

As shown above, the facility is an existing major source for PSD for at least one pollutant. Therefore the facility is an existing major source for PSD.



## 6. Baseline Emissions (BE)

The BE calculation (in lbs/year) is performed pollutant-by-pollutant for each unit within the project to calculate the QNEC, and if applicable, to determine the amount of offsets required.

Pursuant to District Rule 2201, BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, located at a Major Source.

otherwise,

BE = Historic Actual Emissions (HAE), calculated pursuant to District Rule 2201.

Since the steam generators are new emissions units, BE = PE1 = 0 for all pollutants.

## 7. SB 288 Major Modification

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is a major source for VOCs, the project's PE2 is compared to the SB 288 Major Modification Thresholds in the following table in order to determine if the SB 288 Major Modification calculation is required.

SB 288 Major Modification Thresholds			
Pollutant	Project PE2 (lb/year)*	Threshold (lb/year)	SB 288 Major Modification Calculation Required?
NO <sub>x</sub>	9,234	50,000	No
SO <sub>x</sub>	4,244	80,000	No
PM <sub>10</sub>	4,468	30,000	No
VOC	4,468	50,000	No

Since none of the SB 288 Major Modification Thresholds are surpassed with this project, this project does not constitute an SB 288 Major Modification.

## 8. Federal Major Modification

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

The determination of Federal Major Modification is based on a two-step test. For the first step, only the emission *increases* are counted. Emission decreases may not cancel out the increases for this determination.

For new emissions units, the increase in emissions is equal to the PE2 for each new unit included in this project.

The project's combined total emission increases are compared to the Federal Major Modification Thresholds in the following table.

Federal Major Modification Thresholds for Emission Increases			
Pollutant	Total Emissions Increases (lb/yr)	Thresholds (lb/yr)	Federal Major Modification?
NO <sub>x</sub> *	9,234	0	Yes
VOC*	4,468	0	Yes
PM <sub>10</sub>	4,468	30,000	No
PM <sub>2.5</sub>	4,468	20,000	No
SO <sub>x</sub>	4,244	80,000	No

\*If there is any emission increases in NO<sub>x</sub> or VOC, this project is a Federal Major Modification and no further analysis is required.

\*If there is any emission increases in NO<sub>x</sub> or VOC, this project is a Federal Major Modification and no further analysis is required.

Since there is an increase in NO<sub>x</sub> and VOC emissions, this project constitutes a Federal Major Modification.

## 9. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination

Rule 2410 applies to any pollutant regulated under the Clean Air Act, except those for which the District has been classified nonattainment. The pollutants which must be addressed in the PSD applicability determination for sources located in the SJV and which are emitted in this project are: (See 52.21 (b) (23) definition of significant)

- NO<sub>2</sub> (as a primary pollutant)
- SO<sub>2</sub> (as a primary pollutant)
- CO
- PM
- PM<sub>10</sub>

**I. Project Location Relative to Class 1 Area**

As demonstrated in the "PSD Major Source Determination" Section above, the facility was determined to be a existing PSD Major Source. Because the project is not located within 10 km (6.2 miles) of a Class 1 area – modeling of the emission increase is not required to determine if the project is subject to the requirements of Rule 2410.

**II. Project Emission Increase – Significance Determination**

**a. Evaluation of Calculated Post-project Potential to Emit for New or Modified Emissions Units vs PSD Significant Emission Increase Thresholds**

As a screening tool, the post-project potential to emit from all new and modified units is compared to the PSD significant emission increase thresholds, and if the total potentials to emit from all new and modified units are below the applicable thresholds, no further PSD analysis is needed.

PSD Significant Emission Increase Determination: Potential to Emit (tons/year)					
	NO2	SO2	CO	PM	PM10
Total PE from New and Modified Units*	4.6	2.1	13.8	2.2	2.2
PSD Significant Emission Increase Thresholds	40	40	100	25	15
PSD Significant Emission Increase?	N	N	N	N	N

\*includes 1140710, ATC S-1372-414-0 emissions

As demonstrated above, because the post-project total potentials to emit from all new and modified emission units are below the PSD significant emission increase thresholds, this project is not subject to the requirements of Rule 2410 and no further discussion is required.

**10. Quarterly Net Emissions Change (QNEC)**

The Quarterly Net Emissions Change is used to complete the emission profile screen for the District's PAS database. The QNEC for each pollutant is shown in the table(s) below and reported in the PAS database emissions profile.

The QNEC shall be calculated as follows:

$QNEC = (PE2 - BE)/4$ , where:

QNEC = Quarterly Net Emissions Change for each emissions unit, lb/qtr.  
PE2 = Post Project Potential to Emit for each emissions unit, lb/yr.  
BE = Baseline Emissions (per Rule 2201) for each emissions unit, lb/yr.

QNEC (lb/qtr) — S-1372-417 and -418 (each)					
Pollutant	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC
PE2 (lb/yr)	4,617	2,122	2,234	13,775	2,234
BE (lb/yr)	0	0	0	0	0
QNEC	1,154	531	559	3,444	559

## VIII. Compliance

### Rule 2201 New and Modified Stationary Source Review Rule

#### A. Best Available Control Technology (BACT)

##### 1. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis. Unless specifically exempted by Rule 2201, BACT shall be required for the following actions\*:

- Any new emissions unit with a potential to emit exceeding two pounds per day,
- The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- Modifications to an existing emissions unit with a valid Permit to Operate resulting in an AIPE exceeding two pounds per day, and/or
- Any new or modified emissions unit, in a stationary source project, which results in an SB 288 Major Modification or a Federal Major Modification, as defined by the rule.

\*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

##### a. New emissions units – PE > 2 lb/day

As seen in Section VII.C.2 of this evaluation, the project authorizes 2 x 85 MMBtu/hr new steam generators with a PE greater than 2 lb/day for NO<sub>x</sub>, SO<sub>x</sub>, PM<sub>10</sub>, CO, and VOC. BACT is triggered for NO<sub>x</sub>, SO<sub>x</sub>, PM<sub>10</sub>, CO, and VOC.

**b. Relocation of emissions units – PE > 2 lb/day**

As discussed in Section I above, there are no emissions units being relocated from one stationary source to another; therefore BACT is not triggered.

**c. Modification of emissions units – AIPE > 2 lb/day**

As discussed in Section I above, there are no modified emissions units associated with this project. Therefore BACT is not triggered.

**d. SB 288/Federal Major Modification**

As discussed in Section VII.C.7 above, this project does constitute a Federal Major Modification for NO<sub>x</sub> and VOC emissions. Therefore BACT is triggered for NO<sub>x</sub> and VOC for all emissions units in the project for which there is an emission increase.

**2. BACT Guideline**

BACT Guideline 1.2.1 [Steam Generator ( $\geq$  5 MMBtu/hr, Oilfield) updated 3/24/14 is included in **Attachment III**.

**3. Top-Down BACT Analysis**

Per Permit Services Policies and Procedures for BACT, a Top-Down BACT analysis shall be performed as a part of the application review for each application subject to the BACT requirements pursuant to the District's NSR Rule.

Pursuant to the attached Top-Down BACT Analysis (see **Attachment IV**), BACT has been satisfied with the following:

NO<sub>x</sub>: 5 ppmvd @ 3% O<sub>2</sub>  
SO<sub>x</sub>, PM<sub>10</sub>: Natural gas, with a sulfur content not exceeding 1 gr of sulfur compounds (as S) per 100 scf.  
CO: 25 ppmvd @ 3% O<sub>2</sub>  
VOC: Gaseous fuel

**B. Offsets**

**1. Offset Applicability**

Offset requirements shall be triggered on a pollutant by pollutant basis and shall be required if the SSPE2 equals to or exceeds the offset threshold levels in Table 4-1 of Rule 2201.



The SSPE2 is compared to the offset thresholds in the following table.

Offset Determination (lb/year)					
	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC
SSPE2	431,241	2,549,708	375,276	2,795,594	429,394
Offset Thresholds	20,000	54,750	29,200	200,000	20,000
Offsets calculations required?	Yes	Yes	Yes	Yes	Yes

## 2. Quantity of Offsets Required

As seen above, the SSPE2 is greater than the offset thresholds for NO<sub>x</sub>, SO<sub>x</sub>, PM<sub>10</sub>, CO, and VOCs. Therefore offset calculations will be required for this project.

The quantity of offsets in pounds per year is calculated as follows for sources with an SSPE1 greater than the offset threshold levels before implementing the project being evaluated.

Offsets Required (lb/year) =  $(\Sigma[PE2 - BE] + ICCE) \times DOR$ , for all new or modified emissions units in the project,

Where,

PE2 = Post Project Potential to Emit, (lb/year)

BE = Baseline Emissions, (lb/year)

ICCE = Increase in Cargo Carrier Emissions, (lb/year)

DOR = Distance Offset Ratio, determined pursuant to Section 4.8

BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, Located at a Major Source.

otherwise,

BE = HAE

The facility is proposing to install two new emissions units; therefore BE = 0. Also, there are two emissions units associated with this project and there are no increases in cargo carrier emissions; therefore offsets can be determined as follows:

NO<sub>x</sub> (both units)

$$\text{Offsets Required (lb/year)} = ([\text{PE2} - \text{BE}] + \text{ICCE}) \times \text{DOR}$$

$$\begin{aligned}\text{PE2 (NO}_x\text{)} &= 9,234 \text{ lb/year} \\ \text{BE (NO}_x\text{)} &= 0 \text{ lb/year} \\ \text{ICCE} &= 0 \text{ lb/year}\end{aligned}$$

The project is a Federal Major Modification and therefore the correct offset ratio for NO<sub>x</sub> and VOCs is 1.5:1.

$$\begin{aligned}\text{Offsets Required (lb/year)} &= ([9,234 - 0] + 0) \times 1.5 \\ &= 9,234 \times 1.5 \\ &= 13,851 \text{ lb NO}_x\text{/year}\end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned}\text{Quarterly offsets required (lb/qtr)} &= (13,851 \text{ lb NO}_x\text{/year}) \div (4 \text{ quarters/year}) \\ &= 3,462.75 \text{ lb/qtr}\end{aligned}$$

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

<b>Redistribution of Required Quarterly Offsets</b> (where X is the annual amount of offsets, and $X \div 4 = Y$ )				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Calculating the appropriate quarterly emissions to be offset is as follows:

<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>	<u>Total</u>
3,462	3,463	3,463	3,463	13,851

The applicant has stated that the facility plans to use ERC certificate S-4368-2 and S-4193-2. The above certificate has available quarterly NO<sub>x</sub> credits as follows:

	<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>
ERC #S-4368-2	3,462	3,463	3,463	3,462
	<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>
ERC #S-4193-2	4,630	4,630	4,633	4,633

As seen above, the facility has sufficient credits to fully offset the quarterly NO<sub>x</sub> emissions increases associated with this project and the required quarterly amounts have been reserved for the project.

**Proposed Rule 2201 (offset) Conditions (with redistribution between permit units):**

'-417

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender NO<sub>x</sub> emission reduction credits for the following quantity of emissions: 1st quarter – 1,731 lb, 2nd quarter – 1,731 lb, 3rd quarter – 1,731 lb, and fourth quarter – 1,731 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]

'-418

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender NO<sub>x</sub> emission reduction credits for the following quantity of emissions: 1st quarter – 1,731 lb, 2nd quarter – 1,732 lb, 3rd quarter – 1,732 lb, and fourth quarter – 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]

**PM<sub>10</sub>**

PE2 (PM<sub>10</sub>) = 4,468 lb/year  
BE (PM<sub>10</sub>) = 0 lb/year  
ICCE = 0 lb/year

The site of reductions occurred at another stationary source greater than 15 miles from the proposed steam generators and therefore the correct offset ratio 1.5:1.

The amount of PM<sub>10</sub> ERCs that need to be withdrawn is:

Offsets Required (lb/year) = ([4,468 – 0] + 0) x 1.5  
= 4,468 x 1.5

$$= 6,702 \text{ lb PM}_{10}/\text{year}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (6,702 \text{ lb PM}_{10}/\text{year}) \div (4 \text{ quarters/year}) \\ &= 1,675.5 \text{ lb/qtr} \end{aligned}$$

With redistribution as described in the NO<sub>x</sub> offsets calculation section above, the calculated appropriate quarterly emissions to be offset is as follows:

<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>
1675	1675	1676	1676

These emissions will be offset using SO<sub>x</sub> ERCs (C-1304-5) as described below. PM<sub>10</sub> may be offset using SO<sub>x</sub> at an interpollutant offset ratio of 1.0 tons SO<sub>x</sub>/ton PM<sub>10</sub> (District Draft Policy APR 14XX).

#### SO<sub>x</sub>

$$\begin{aligned} \text{PE2 (SO}_x\text{)} &= 4,244 \text{ lb/year} \\ \text{BE (SO}_x\text{)} &= 0 \text{ lb/year} \\ \text{ICCE} &= 0 \text{ lb/year} \end{aligned}$$

The site of reductions occurred at another stationary source greater than 15 miles from the proposed steam generators and therefore the correct offset ratio 1.5:1.

Assuming an offset ratio of 1.5:1, the amount of SO<sub>x</sub> ERCs that need to be withdrawn is:

$$\begin{aligned} \text{Offsets Required (lb/year)} &= ([4,244 - 0] + 0) \times 1.5 \\ &= 4,244 \times 1.5 \\ &= 6,366 \text{ lb SO}_x/\text{year} \end{aligned}$$

With redistribution as described in the NO<sub>x</sub> section above, the calculated appropriate quarterly emissions to be offset is as follows:

<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>
1591	1591	1592	1592

The applicant has stated that the facility plans to use ERC certificate C-1304-5 (offspring of C-1262-5 listed in application) for both PM<sub>10</sub> and SO<sub>x</sub> (8/18/14 email) which have been reserved for the quantities in the table below.

Certificate	Q1	Q2	Q3	Q4	Total
C-1304-5	1675 (PM10) + 1591 (SOx) = 3,266	1675 (PM10) + 1591 (SOx) = 3,266	1676 (PM10) + 1592 (SOx) = 3,268	1676 (PM10) + 1592 (SOx) = 3,268	13,068

The above certificate has available quarterly SO<sub>x</sub> credits as follows:

	<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>
ERC #C-1304-5	5,661	5,603	5,405	7,631

As seen above, the facility has sufficient credits to fully offset the quarterly SO<sub>x</sub> and PM10 emissions increases associated with this project.

**Proposed Rule 2201 (offset) Conditions (with redistribution between permit units):**

**-417**

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender SO<sub>x</sub> emission reduction credits for the following quantity of combined SO<sub>x</sub> and PM10 emissions: 1st quarter – 1,633 lb, 2nd quarter – 1,633 lb, 3rd quarter – 1,634 lb, and fourth quarter – 1,634 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]

**-418**

- { GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender SO<sub>x</sub> emission reduction credits for the following quantity of combined SO<sub>x</sub> and PM10 emissions: 1st quarter – 1,633 lb, 2nd quarter – 1,633 lb, 3rd quarter – 1,634 lb, and fourth quarter – 1,634 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]

**VOCs**

PE2 (VOCs) = 4,468 lb/year  
BE (VOCs) = 0 lb/year  
ICCE = 0 lb/year

The amount of VOCs ERCs that need to be withdrawn is:

Offsets Required (lb/year) =  $[(4,468 - 0) + 0] \times 1.5$   
=  $4,468 \times 1.5$   
= 6,702 lb VOCs/year



Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned}\text{Quarterly offsets required (lb/qtr)} &= (6,702 \text{ lb NO}_x/\text{year}) \div (4 \text{ quarters/year}) \\ &= 1,675.5 \text{ lb/qtr}\end{aligned}$$

With redistribution as described in the NO<sub>x</sub> offsets calculation section above, the calculated appropriate quarterly emissions to be offset is as follows:

<u>1<sup>st</sup> Quarter</u>	<u>2<sup>nd</sup> Quarter</u>	<u>3<sup>rd</sup> Quarter</u>	<u>4<sup>th</sup> Quarter</u>	<u>Total Annual</u>
1,675	1,675	1,676	1,676	6,702

The applicant has stated that the facility plans to use ERC certificate listed in the following table which have been reserved for the quantities above.

Certificate	Q1	Q2	Q3	Q4
S-4384-1	4,593	4,668	4,759	4,768

As seen above, the facility has sufficient credits to fully offset the quarterly VOC emissions increases associated with this project.

**Proposed Rule 2201 (offset) Conditions (with redistribution between permit units):**

**'-417**

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter – 837 lb, 2nd quarter – 837 lb, 3rd quarter – 838 lb, and fourth quarter – 838 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]

**'-418**

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter – 838 lb, 2nd quarter – 838 lb, 3rd quarter – 838 lb, and fourth quarter – 838 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]

The following condition appears on both ATCs S-1372-417-0 and '-418-0

- ERC Certificate Numbers S-4384-1, S-4368-2, S-4193-2, and S-1304-5 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct.

*Emissions reduction credits for SO<sub>x</sub> may be used for PM<sub>10</sub> at a 1:1 offset ratio.  
[District Rule 2201] Y*

## CO

CO: 13,775 lb/yr

Notwithstanding the above, Section 4.6.1 of Rule 2201 states that emissions offsets are not required for increases in carbon monoxide in attainment areas provided the applicant demonstrates to the satisfaction of the APCO that the Ambient Air Quality Standards are not violated in the areas to be affected, and such emissions will be consistent with Reasonable Further Progress, and will not cause or contribute to a violation of Ambient Air Quality Standards. The District performed an Ambient Air Quality Analysis and determined that this project will not result in or contribute to a violation of an Ambient Air Quality Standard for CO (see **Attachment V**). Therefore, CO offsets are not required for this project.

## **C. Public Notification**

### **1. Applicability**

Public noticing is required for:

- a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications,
- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- c. Any project which results in the offset thresholds being surpassed, and/or
- d. Any project with an SSIPE of greater than 20,000 lb/year for any pollutant.
- e. Any project which results in a Title V significant permit modification

#### **a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications**

New Major Sources are new facilities, which are also Major Sources. Since this is not a new facility, public noticing is not required for this project for New Major Source purposes.

As demonstrated in VII.C.7, this project is an SB 288 or Federal Major Modification. Therefore, public noticing for SB 288 or Federal Major Modification purposes is required.

#### **b. PE > 100 lb/day**

Applications which include a new emissions unit with a PE greater than 100 pounds during any one day for any pollutant will trigger public noticing requirements. As seen in Section VII.C.2 above, this project does not include a new emissions unit which has daily emissions greater than 100 lb/day for

any pollutant, therefore public noticing for PE > 100 lb/day purposes is not required.

**c. Offset Threshold**

The SSPE1 and SSPE2 are compared to the offset thresholds in the following table.

Offset Thresholds				
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	Offset Threshold	Public Notice Required?
NO <sub>x</sub>	>20,000	>20,000	20,000 lb/year	No
SO <sub>x</sub>	>54,750	>54,750	54,750 lb/year	No
PM <sub>10</sub>	>29,200	>29,200	29,200 lb/year	No
CO	>200,000	>200,000	200,000 lb/year	No
VOC	>20,000	>20,000	20,000 lb/year	No

As detailed above, there were no thresholds surpassed with this project; therefore public noticing is not required for offset purposes.

**d. SSIPE > 20,000 lb/year**

Public notification is required for any permitting action that results in a SSIPE of more than 20,000 lb/year of any affected pollutant. According to District policy, the SSIPE = SSPE2 – SSPE1. The SSIPE is compared to the SSIPE Public Notice thresholds in the following table.

SSIPE Public Notice Thresholds					
Pollutant	SSPE2 (lb/year)	SSPE1 (lb/year)	SSIPE (lb/year)	SSIPE Public Notice Threshold	Public Notice Required?
NO <sub>x</sub>	>20,000	>20,000	9,282	20,000 lb/year	No
SO <sub>x</sub>	>54,750	>54,750	4,244	20,000 lb/year	No
PM <sub>10</sub>	>29,200	>29,200	4,468	20,000 lb/year	No
CO	>200,000	>200,000	27,550	20,000 lb/year	Yes
VOC	>20,000	>20,000	4,468	20,000 lb/year	No

As demonstrated above, the SSIPE was greater than 20,000 lb/year for CO; therefore public noticing for SSIPE purposes is required.

**e. Title V Significant Permit Modification**

As shown in the Discussion of Rule 2520 below, this project constitutes a Title V significant modification. Therefore, public noticing for Title V significant modifications is required for this project.

## **2. Public Notice Action**

As discussed above, public noticing is required for this project for SB288/Federal Major Modification and SSIPE > 20,000 lb/yr purposes. Therefore, public notice documents will be submitted to the California Air Resources Board (CARB) and a public notice will be published in a local newspaper of general circulation prior to the issuance of the ATC for this equipment.

### **D. Daily Emission Limits (DELs)**

DELs and other enforceable conditions are required by Rule 2201 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. The DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

#### **Proposed Rule 2201 (DEL) Conditions:**

The sulfur content of any fuel, or fuels combined, shall not exceed 1 grains of total sulfur (as H<sub>2</sub>S) per 100 dscf of fuel gas. [District Rules 2201 and 4320] Y

Except during startup and shutdown, emissions shall not exceed any of the following limits: 5 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub> or 0.0062 lb-NO<sub>x</sub>/MMBtu, 0.00285 lb-SO<sub>x</sub>/MMBtu, 0.003 lb-PM<sub>10</sub>/MMBtu, 25 ppmvd CO @ 3% O<sub>2</sub> or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Y

Emissions shall not exceed 13.2 lb/day NO<sub>x</sub> nor 4641 lb/yr NO<sub>x</sub>, 5.8 lb/day SO<sub>x</sub> nor 2122 lb/yr SO<sub>x</sub>, 6.1 lb/day PM<sub>10</sub> nor 2234 lb/yr PM<sub>10</sub>, 37.8 lb/day CO nor 13,775 lb/yr CO, and 6.1 lb/day VOCs nor 2234 lb/yr VOCs. [District Rule 2201] Y

Duration of startup and shutdown (combined) shall not exceed 0.5 hr day nor 24 hr/yr. [District Rule 2201] Y

Emissions rates during startup and shutdown shall not exceed 0.018 lb/MMBtu NO<sub>x</sub> and 0.074 lb/MMBtu CO [District Rule 2201] Y

### **E. Compliance Assurance**

#### **1. Source Testing**

##### **VOC**

Startup source testing will be required.

##### **NO<sub>x</sub> and CO**

This units are subject to District Rule 4305, *Boilers, Steam Generators and Process Heaters, Phase 2*, District Rule 4306, *Boilers, Steam Generators and Process Heaters, Phase 3*, and District Rule 4320 *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*. Source testing requirements, in accordance with District Rules 4305, 4306, and 4320 will be discussed in Section VIII, District Rules 4305, 4306, and 4320 of this evaluation.

## 1. Monitoring

### Sulfur Monitoring for Rule 4320 Compliance

The following conditions will be included on the ATCs for the steam generators:

*When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested monthly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 6 consecutive months for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, monthly testing shall resume. [District Rules 1070, 2201, 2520, and 4320] Y*

### NOx and CO

As required by *District Rule 4305, Boilers, Steam Generators and Process Heaters, Phase 2*, *District Rule 4306, Boilers, Steam Generators and Process Heaters, Phase 3*, and *District Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*, this unit is subject to monitoring requirements. Monitoring requirements, in accordance with District Rules 4305, 4306, and 4320 will be discussed in Section VIII, District Rules 4305, 4306, and 4320 of this evaluation.

## 2. Recordkeeping

As required by *District Rule 4305, Boilers, Steam Generators and Process Heaters, Phase 2*, *District Rule 4306, Boilers, Steam Generators and Process Heaters, Phase 3*, and *District Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*, this unit is subject to recordkeeping requirements. Recordkeeping requirements, in accordance with District Rules 4305, 4306, and 4320 will be discussed in Section VIII, *District Rules 4305, 4306, and 4320* of this evaluation.

The following permit condition will be listed on permit as follows:

*{2983} All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Y*

## 4. Reporting



No reporting is required to demonstrate compliance with Rule 2201.

#### **F. Ambient Air Quality Analysis (AAQA)**

An AAQA shall be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse a violation of an air quality standard. The District's Technical Services Division conducted the required analysis. Refer to **Appendix X** of this document for the AAQA summary sheet.

The proposed location is in an attainment area for NO<sub>x</sub>, CO, and SO<sub>x</sub>. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO<sub>x</sub>, CO, or SO<sub>x</sub>.

The proposed location is in a non-attainment area for the state's PM<sub>10</sub> as well as federal and state PM<sub>2.5</sub> thresholds. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for PM<sub>10</sub> and PM<sub>2.5</sub>.

#### **G. Compliance Certification**

Section 4.15.2 of this Rule requires the owner of a new Major Source or a source undergoing a Title I Modification to demonstrate to the satisfaction of the District that all other Major Sources owned by such person and operating in California are in compliance or are on a schedule for compliance with all applicable emission limitations and standards. As discussed in Section VIII above, this facility is a new major source and this project does constitute a Title I modification, therefore this requirement is applicable. Corporation XYZ's compliance certification is included in **Attachment VI**.

#### **H. Alternate Siting Analysis**

The current project occurs at an existing facility. The applicant proposes to install 2 85 MMBtu/hr natural gas fired steam generators.

Since the project will authorize installation of steam generators to be used at the same location, the existing site will result in the least possible impact from the project. Alternative sites would involve the relocation and/or construction of various support structures on a much greater scale, and would therefore result in a much greater impact.

#### **Rule 2410 Prevention of Significant Deterioration**

As shown in Section VII. C. 9. above, this project does not result in a new PSD major source or PSD major modification. No further discussion is required.

### **District Rule 2520 Federally Mandated Operating Permits**

FMM has a Title V permit. This facility is subject to this Rule, and has received their Title V Operating Permit. The proposed modification is a Minor Modification to the Title V Permit.

In accordance with Rule 2520, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
  - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
  - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

As discussed above, the facility has applied for a Certificate of Conformity (COC). Therefore, the facility must apply to modify their Title V permit with an administrative amendment, prior to operating with the proposed modifications. Continued compliance with this rule is expected. The facility may construct/operate under the ATC upon submittal of the Title V administrative amendment application.

The Title V Compliance Certification Form is included in **Attachment VI**.

### **Rule 4001 New Source Performance Standards**

40 CFR Part 60, Subpart Dc applies to Small Industrial-Commercial-Industrial Steam Generators between 10 MMBtu/hr and 100 MMBtu/hr (post-6/9/89 construction, modification or, reconstruction).

The subject steam generator has a rating of 85 MMBtu/hr and is fired on natural/TEOR gas. Subpart Dc has no standards for gas-fired steam generators. Therefore the subject steam generator is not an affected facility and subpart Dc does not apply.

#### **Rule 4101 Visible Emissions**

Per Section 5.0, no person shall discharge into the atmosphere emissions of any air contaminant aggregating more than 3 minutes in any hour which is as dark as or darker than Ringelmann 1 (or 20% opacity). A condition will be placed on the ATC to ensure compliance with the opacity limit.

Therefore, compliance with the requirements of this rule is expected.

#### **Rule 4102 Nuisance**

Section 4.0 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

#### **California Health & Safety Code 41700 – Health Risk Analysis**

District Policy APR 1905 – Risk Management Policy for Permitting New and Modified Sources specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

An HRA is not required for a project with a total facility prioritization score of less than one. According to the Technical Services Memo for this project (**Attachment V**), the total facility prioritization score including this project was greater than one. Therefore, an HRA was required to determine the short-term acute and long-term chronic exposure from this project.

The cancer risk for this project is shown below:

<b>HRA Summary</b>		
<b>Unit</b>	<b>Cancer Risk</b>	<b>T-BACT Required</b>
<b>S-1372-417 and -418</b>	<b>0.4 per million</b>	<b>No</b>

To ensure that human health risks will not exceed District allowable levels; the following permit condition must be included:

#### **Units 417 and -418**

*{1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction.  
[District Rule 4102] N*

## **Rule 4201 Particulate Matter Concentration**

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot.

F-Factor for NG: 8,578 dscf/MMBtu at 60 °F

PM<sub>10</sub> Emission Factor: 0.005 lb-PM<sub>10</sub>/MMBtu

Percentage of PM as PM<sub>10</sub> in Exhaust: 100%

Exhaust Oxygen (O<sub>2</sub>) Concentration: 3%

$$\text{Excess Air Correction to F Factor} = \frac{20.9}{(20.9 - 3)} = 1.17$$

$$GL = \left( \frac{0.003 \text{ lb-PM}}{\text{MMBtu}} \times \frac{7,000 \text{ grain}}{\text{lb-PM}} \right) / \left( \frac{8,578 \text{ ft}^3}{\text{MMBtu}} \times 1.17 \right)$$

$$GL = 0.002 \text{ grain/dscf} < 0.1 \text{ grain/dscf}$$

Therefore, compliance with the requirements of this rule is expected.

## **Rule 4301 Fuel Burning Equipment**

Rule 4301 limits air contaminant emissions from fuel burning equipment as defined in the rule. Section 3.1 defines fuel burning equipment as “any furnace, boiler, apparatus, stack, and all appurtenances thereto, used in the process of burning fuel for the primary purpose of producing heat or power by indirect heat transfer”.

Section 5.0 gives the requirements of the rule.

A person shall not discharge into the atmosphere combustion contaminants exceeding in concentration at the point of discharge, 0.1 grain per cubic foot of gas calculated to 12% of carbon dioxide at dry standard conditions.

A person shall not build, erect, install or expand any non-mobile fuel burning equipment unit unless the discharge into the atmosphere of contaminants will not and does not exceed any one or more of the following rates:

- 200 pound per hour of sulfur compounds, calculated as sulfur dioxide (SO<sub>2</sub>)
- 140 pounds per hour of nitrogen oxides, calculated as nitrogen dioxide (NO<sub>2</sub>)
- Ten pounds per hour of combustion contaminants as defined in Rule 1020 and derived from the fuel.

District Rule 4301 Limits			
Unit	NO <sub>2</sub>	Total PM	SO <sub>2</sub>
S-1372-417, -418 (lb/hr)	$0.0062 \times 85 = 0.53$	$0.003 \times 85 = 0.26$	$0.00285 \times 85 = 0.24$
Rule Limit (lb/hr)	140	10	200

The particulate emissions from the steam generators will not exceed 0.1 gr/dscf at 12% CO<sub>2</sub> or 10 lb/hr. Further, the emissions of SO<sub>x</sub> and NO<sub>x</sub> will not exceed 200 lb/hr or 140 lb/hr, respectively.

Therefore, compliance with the requirements of this rule is expected.

#### **District Rule 4305 Boilers, Steam Generators and Process Heaters – Phase 2**

The units have a maximum heat input of 85 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4305, the unit is subject to District Rule 4305, *Boilers, Steam Generators and Process Heaters – Phase 2*.

In addition, the unit is also subject to District Rule 4306, *Boilers, Steam Generators and Process Heaters – Phase 3*.

Since emissions limits of District Rule 4320 and all other requirements are equivalent or more stringent than District Rule 4305 requirements, compliance with District Rule 4320 requirements will satisfy requirements of District Rule 4305.

#### **District Rule 4306 Boilers, Steam Generators and Process Heaters – Phase 3**

The units have a maximum heat input of 85 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4306, the unit is subject to District Rule 4306, *Boilers, Steam Generators and Process Heaters – Phase 3*.

Since emissions limits of District Rule 4320 and all other requirements are equivalent or more stringent than District Rule 4306 requirements, compliance with District Rule 4320 requirements will satisfy requirements of District Rule 4306.

#### **Rule 4320 – Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr**



This rule limits NO<sub>x</sub>, CO, SO<sub>2</sub> and PM<sub>10</sub> emissions from boilers, steam generators and process heaters rated greater than 5 MMBtu/hr. This rule also provides a compliance option of payment of fees in proportion to the actual amount of NO<sub>x</sub> emitted over the previous year.

The units in this project are all rated at greater than 5 MMBtu/hr heat input and are subject to this rule.

### **Section 5.1 NO<sub>x</sub> Emission Limits**

Section 5.1 states that an operator of a unit(s) subject to this rule shall comply with all applicable requirements of the rule and one of the following, on a unit-by-unit basis:

- 5.1.1 Operate the unit to comply with the emission limits specified in Sections 5.2 and 5.4; or
- 5.1.2 Pay an annual emissions fee to the District as specified in Section 5.3 and comply with the control requirements specified in Section 5.4; or
- 5.1.3 Comply with the applicable Low-use Unit requirements of Section 5.5.

The unit will comply with the NO<sub>x</sub> and CO emissions limits specified in Section 5.2 of the rule.

The proposed NO<sub>x</sub> and CO limits are 5 and 25 ppmv @ 3% O<sub>2</sub>, respectively.

Therefore, compliance with the emissions limits of Section 5.2 of District Rule 4320 is expected.

A permit condition listing the emissions limits will be listed on permit as shown in the DEL section above.

### **Section 5.4 Particulate Matter Control Requirements**

Section 5.4.1 states that to limit particulate matter emissions, an operator shall comply with one of the options listed in the rule.

Section 5.4.1.1 provides option for the operator to comply with the rule by firing the unit exclusively on PUC-quality gas, commercial propane, butane, or liquefied petroleum gas, or a combination of such gases;

Section 5.4.1.2 provides option for the operator to comply with the rule by limiting the fuel sulfur content to no more than five (5) grains of total sulfur per hundred (100) standard cubic feet.

Section 5.4.1.3 provides option for the operator to comply with the rule by installing and properly operating an emissions control system that reduces SO<sub>2</sub> emissions by at least 95% by weight; or limit exhaust SO<sub>2</sub> to less than or equal to 9 ppmv corrected to 3 % O<sub>2</sub>.

The steam generators will be fired on natural gas containing no more than 1 gr S/100 scf. Therefore, compliance with this section of the rule is expected.

## **Section 5.5 Low Use**

The subject steam generators are not low use units and therefore the requirements of Section 5.5 do not apply.

## **Section 5.6, Startup and Shutdown Provisions**

Applicable emissions limits are not required during startup and shutdown provided the duration of each start-up or each shutdown shall not exceed two hours, the emission control system shall be in operation and emissions shall be minimized insofar as technologically feasible during start-up or shutdown or operator has submitted an application for a Permit to Operate condition to allow more than two hours for each start-up or each shutdown provided the operator meets all of the conditions specified in Sections 5.6.3.1 through 5.6.3.3. Applicant has proposed to limit startup and shutdown to 15 minutes per day for each event.

No special start-up and shut-down emissions have been proposed.

## **Section 5.7 Monitoring Provisions**

Section 5.7.1 requires that permit units subject to District Rule 4320, Section 5.2 shall either install or maintain an operational APCO approved Continuous Emission Monitoring System (CEMS) for NO<sub>x</sub>, CO and O<sub>2</sub>, or implement an APCO-approved alternate monitoring.

FMM has proposed to implement Alternate Monitoring Scheme A (pursuant to District Policy SSP-1105), which requires periodic monitoring of NO<sub>x</sub>, CO, and O<sub>2</sub> concentrations at least once a month using a portable analyzer. The following conditions will be placed in the permits to ensure compliance with the requirements of this alternate monitoring plan:

*{2395} The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Y*

*If either the NO<sub>x</sub> or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour*

*of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4102, 4305, 4306 and 4320] Y*

*All NO<sub>x</sub>, CO, and O<sub>2</sub> emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NO<sub>x</sub>, CO, and O<sub>2</sub> analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4102, 4305, 4306 and 4320] Y*

*The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent by volume and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Y*

Section 5.7.6.1 requires that operators complying with Sections 5.4.1.1 or 5.4.1.2 shall provide an annual fuel analysis to the District unless a more frequent sampling and reporting period is included in the Permit To Operate. Sulfur analysis shall be performed in accordance with the test methods in Section 6.2. The following conditions will be placed in the ATCs for compliance with this rule requirement:

*If the unit is fired on noncertified gaseous fuel and compliance with SO<sub>x</sub> emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084, D 4468, D 6667 or grab sample analysis by GC-FPD/TCD or double GC performed in the laboratory. [District Rule 1070, 2201, 2520, and 4320] Y*

*When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested monthly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 6 consecutive months for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, monthly testing shall resume. [District Rules 1070, 2201, 2520, and 4320] Y*

*If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 1070, 2201, 2520, and 4320] Y*

## **Section 5.8 Compliance Determination**

Section 5.8.1 requires that the operator of any unit have the option of complying with either the applicable heat input (lb/MMBtu), emission limits or the concentration (ppmv) emission limits specified in Section 5.2. The emission limits selected to demonstrate compliance shall be specified in the source test proposal pursuant to Rule 1081 (Source Sampling). Therefore, the following condition will be retained or listed on the permits as follows:

*{2976} The source plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Y*

Section 5.8.2 requires that all emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. Therefore, the following permit condition will be listed on the permits as follows:

*{2972} All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Y*

Section 5.8.4 requires that for emissions monitoring pursuant to Sections 5.7.1 and 6.3.1 using a portable NO<sub>x</sub> analyzer as part of an APCO approved Alternate Emissions Monitoring System, emission readings shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15-consecutive-minute period. Therefore, the following previously listed permit condition will be on the permits as follows:

*{2937} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions*

*specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Y*

Section 5.8.5 requires that for emissions source testing performed pursuant to Section 6.3.1 for the purpose of determining compliance with an applicable standard or numerical limitation of this rule, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. Therefore, the following permit condition will be listed on the permit as follows:

*{2980} For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Y*

## **Section 6.1 Recordkeeping**

Section 6.1 requires that the records required by Sections 6.1.1 through 6.1.5 shall be maintained for five calendar years and shall be made available to the APCO and EPA upon request. Failure to maintain records or information contained in the records that demonstrate noncompliance with the applicable requirements of this rule shall constitute a violation of this rule. Therefore, the following permit condition will be listed on the permit as follows:

*All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Y*

## **Section 6.2, Test Methods**

Section 6.2 identifies test methods to be used when determining compliance with the rule. The following conditions will be listed on the permits:

*{109} Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Y*

*The following test methods shall be used: NOX (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O2) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities – EPA Method 2; Stack gas moisture content – EPA Method 4; SOx – EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H2S content – EPA Method*

11 or 15; and fuel hhv (MMBtu) –ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 4305, 4306 and 4320] Y

### **Section 6.3, Compliance Testing**

Section 6.3.1 requires that each unit subject to the requirements in Section 5.2 shall be source tested at least once every 12 months, except if two consecutive annual source tests demonstrate compliance, source testing may be performed every 36 months. If such a source test demonstrates non-compliance, source testing shall revert to every 12 months. The following conditions will be included in the permits:

*Source testing to measure NOx, CO, and VOC emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] N*

*Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Y*

*{110} The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Y*

Sections 6.3.2.1 through 6.3.2.7 address the requirements of group testing which is not proposed in this project. Therefore these sections are not applicable.

### **Conclusion**

Conditions will be incorporated into the permit in order to ensure compliance with each section of this rule, see attached draft permits. Therefore, compliance with District Rule 4320 requirements is expected.

### **Rule 4801 Sulfur Compounds**

A person shall not discharge into the atmosphere sulfur compounds, which would exist as a liquid or gas at standard conditions, exceeding in concentration at the point of discharge: 0.2 % by volume calculated as SO<sub>2</sub>, on a dry basis averaged over 15 consecutive minutes. The unit will combust gas containing no more than 1 gr S/100 scf and therefore compliance is expected.

**California Health & Safety Code 42301.6 (School Notice)**

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

### California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

The proposed steam generator will combust fuel (natural gas) which results in GHG emissions that are mitigated under ARB's Cap and Trade regulation. Consistent with CCR §15064(h)(3), the District finds that compliance with ARB's Cap and Trade regulation would avoid or substantially lessen the impact of project-specific GHG emissions on global climate change. The District therefore concludes that projects occurring at facilities which combust fuel subject to ARB's Cap and Trade regulation would have a less than significant individual and cumulative impact on global climate change. The District finds that the activity is categorically exempt from the provisions of CEQA pursuant to CEQA Guideline § 15301 (Existing Facilities), and finds that the project is exempt per the general rule that CEQA applies only to projects which have the potential for causing a significant effect on the environment (CEQA Guidelines §15061(b)(3)).

### IX. Recommendation

Compliance with all applicable rules and regulations is expected. Pending a successful Public Notice period, issue ATCs S-1372-417 and -418 subject to the permit conditions on the attached draft ATCs in **Attachment XII**.

### X. Billing Information

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee

S-1372-417, '-418	3020-02-H	85 MMBtu/hr	\$1030.00
-------------------	-----------	-------------	-----------

**Attachments**

- I. Project Location Map
- II. Emissions Profiles
- III. BACT Guideline
- IV: BACT Analysis
- V: HRA and AAQA Modeling
- VI: Statewide Compliance Statement and Title V Compliance Certification Form
- XII: Draft ATCs



# ATTACHMENT I

## Project Location Map



Missouri Triangle

7th Standard Rd

HOPKINS GENERATOR 72

33

Lost Hills Rd

West Gate Hwy

© 2014 Google

Google earth

## ATTACHMENT II Emissions Profiles

# Application Emissions

Permit #: S-1372-417-0	Last Updated
Facility: FREEPORT-MC MORAN OIL & GAS	10/14/2014 EDGEHILR

Equipment Pre-Baselined: NO

	<u>NOX</u>	<u>SOX</u>	<u>PM10</u>	<u>CO</u>	<u>VOC</u>
Potential to Emit (lb/Yr):	4617.0	2122.0	2234.0	13775.0	2234.0
Daily Emis. Limit (lb/Day)	16.7	5.8	6.1	56.6	6.1
Quarterly Net Emissions Change (lb/Qtr)					
Q1:	1154.0	530.0	558.0	3443.0	558.0
Q2:	1154.0	530.0	558.0	3444.0	558.0
Q3:	1154.0	531.0	559.0	3444.0	559.0
Q4:	1155.0	531.0	559.0	3444.0	559.0
Check if offsets are triggered but exemption applies	N	N	N	Y	N
Offset Ratio	1.5	1.5	1.5		1.5
Quarterly Offset Amounts (lb/Qtr)					
Q1:	1732.0	796.0	838.0		838.0
Q2:	1732.0	796.0	838.0		838.0
Q3:	1732.0	796.0	838.0		838.0
Q4:	1732.0	796.0	838.0		838.0

Permit #: S-1372-418-0	Last Updated
Facility: FREEPORT-MC MORAN OIL & GAS	10/14/2014 EDGEHILR

Equipment Pre-Baselined: NO

	<u>NOX</u>	<u>SOX</u>	<u>PM10</u>	<u>CO</u>	<u>VOC</u>
Potential to Emit (lb/Yr):	4617.0	2122.0	2234.0	13775.0	2234.0
Daily Emis. Limit (lb/Day)	16.7	5.8	6.1	56.6	6.1
Quarterly Net Emissions Change (lb/Qtr)					
Q1:	1154.0	530.0	558.0	3443.0	558.0
Q2:	1154.0	530.0	558.0	3444.0	558.0
Q3:	1155.0	531.0	559.0	3444.0	559.0
Q4:	1155.0	531.0	559.0	3444.0	559.0
Check if offsets are triggered but exemption applies	N	N	N	Y	N
Offset Ratio	1.5	1.5	1.5		1.5
Quarterly Offset Amounts (lb/Qtr)					
Q1:	1732.0	796.0	838.0		838.0
Q2:	1732.0	796.0	838.0		838.0
Q3:	1732.0	796.0	838.0		838.0
Q4:	1732.0	796.0	838.0		838.0

## ATTACHMENT III BACT Guideline

San Joaquin Valley  
Unified Air Pollution Control District

**Best Available Control Technology (BACT) Guideline 1.2.1\***

Last Update 3/24/2014

**Oilfield Steam Generator (> or =20 MMBtu/hr)**

Pollutant	Achieved in Practice or contained in the SIP	Technologically Feasible	Alternate Basic Equipment
VOC	Gaseous fuel		
SOx	Fired on PUC quality natural gas, commercial propane, and/or commercial LPG; or gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO <sub>2</sub> scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO <sub>2</sub> @ 3% O <sub>2</sub>		
PM10	Fired on PUC quality natural gas, commercial propane, and/or commercial LPG; or gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO <sub>2</sub> scrubber and either achieve 95% by weight control of sulfur compounds or achieving an emission rate of 9 ppmvd SO <sub>2</sub> @ 3% O <sub>2</sub>		
NOx	<ul style="list-style-type: none"> <li>•Units rated 85 MMBtu/hr and fired solely on PUC quality natural gas: 6 ppmvd @ 3% O<sub>2</sub>; or</li> <li>•Units firing on ≥50% PUC quality natural gas; commercial propane; and/or LPG: 7 ppmvd @ 3% O<sub>2</sub>, except units rated 85 MMBtu/hr and fired solely on PUC quality natural gas; or</li> <li>•Units firing on &lt;50% PUC quality natural gas; commercial propane; and/or LPG: 9 ppmvd @ 3% O<sub>2</sub></li> </ul>	5 ppmvd @ 3% O <sub>2</sub>	
CO	25 ppmvd @ 3% O <sub>2</sub>		



## ATTACHMENT IV BACT Analysis

### Top Down BACT Analysis for the Steam Generator

Oxides of nitrogen ( $\text{NO}_x$ ) are generated from the high temperature combustion of the natural gas fuel. A majority of the  $\text{NO}_x$  emissions are formed from the high temperature reaction of nitrogen and oxygen in the inlet air. The rest of the  $\text{NO}_x$  emissions are formed from the reaction of fuel-bound nitrogen with oxygen in the inlet air.

#### 1. BACT Analysis for $\text{NO}_x$ Emissions:

##### a. Step 1 - Identify all control technologies

The SJVUAPCD BACT Clearinghouse Guideline 1.2.1, updated 3/24/14, identifies for achieved in practice BACT for  $\text{NO}_x$  emissions from oil field steam generators  $\geq 5$  MMBtu/hr as follows (non-applicable Achieved-in-Practice requirements are in strikeout text):

##### Achieved-in-Practice

• Units rated 85 MMBtu/hr and fired solely on PUC-quality natural gas: 6 ppmvd @ 3%  $\text{O}_2$

~~• Units firing on  $\geq 50\%$  PUC quality natural gas; commercial propane; and/or LPG: 7 ppmvd @ 3%  $\text{O}_2$ , except units rated 85 MMBtu/hr and fired solely on PUC quality natural gas — unit is 85 MMBtu/hr~~

~~• Units firing on  $< 50\%$  PUC quality natural gas; commercial propane; and/or LPG: 9 ppmvd @ 3%  $\text{O}_2$  — unit is fired on PUC-quality natural gas~~

##### Technologically Feasible

5 ppmvd @ 3%  $\text{O}_2$  — units rated 85 MMBtu/hr and fired solely on PUC-quality natural gas

##### b. Step 2 - Eliminate technologically infeasible options

There are no technologically infeasible options to eliminate from step 1.

##### c. Step 3 - Rank remaining options by control effectiveness

- 1) 6 ppmvd @ 3%  $\text{O}_2$  — Achieved-in-Practice
- 2) 5 ppmvd @ 3%  $\text{O}_2$  — Technologically Feasible

**d. Step 4 - Cost Effectiveness Analysis**

A cost effective analysis is required for technologically feasible control options that are not proposed. The applicant is proposing a NO<sub>x</sub> limit of 5 ppmvd @ 3% O<sub>2</sub>, the highest rank technology; therefore, a cost effective analysis is not required.

**e. Step 5 - Select BACT**

Applicant has proposed 5 ppmv NO<sub>x</sub> @ 3% O<sub>2</sub>. BACT is satisfied.

**2. BACT Analysis for SO<sub>x</sub> Emissions:**

Oxides of sulfur (SO<sub>x</sub>) emissions occur from the combustion of the sulfur, which is present in the fuel.

**a. Step 1 - Identify all control technologies**

The SJVUAPCD BACT Clearinghouse Guideline 1.2.1, updated 3/24/14, identifies for achieved in practice BACT for SO<sub>x</sub> emissions from oil field steam generators ≥5 MMBtu/hr as follows:

Achieved-in-Practice

or  
Fired on PUC quality natural gas, commercial propane, and/or commercial LPG;  
gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO<sub>2</sub> scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO<sub>2</sub> @ 3% O<sub>2</sub>

**b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

**c. Step 3 - Rank remaining options by control effectiveness**

or  
Fired on PUC quality natural gas, commercial propane, and/or commercial LPG;  
gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO<sub>2</sub> scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO<sub>2</sub> @ 3% O<sub>2</sub>

**d. Step 4 - Cost Effectiveness Analysis**

The only control technology in the ranking list from Step 3 has been achieved in practice. Therefore, per the District's BACT Policy (dated 11/9/99) Section IX.D.2, the cost effectiveness analysis is not required.

**e. Step 5 - Select BACT**

BACT for SO<sub>x</sub> emissions from this oil field steam generator is natural gas fuel with a sulfur content ≤1 gr-S/100 scf. BACT is satisfied.

**3. BACT Analysis for PM<sub>10</sub> Emissions:**

Particulate matter (PM<sub>10</sub>) emissions result from the incomplete combustion of various elements in the fuel.

**a. Step 1 - Identify all control technologies**

The SJVUAPCD BACT Clearinghouse Guideline 1.2.1, updated 3/24/14, identifies for achieved in practice BACT for CO<sub>10</sub> emissions from oil field steam generators ≥5 MMBtu/hr as follows:

Achieved-in-Practice

or  
Fired on PUC quality natural gas, commercial propane, and/or commercial LPG;  
gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO<sub>2</sub> scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO<sub>2</sub> @ 3% O<sub>2</sub>

**b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

**c. Step 3 - Rank remaining options by control effectiveness**

or  
Fired on PUC quality natural gas, commercial propane, and/or commercial LPG;  
gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO<sub>2</sub> scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO<sub>2</sub> @ 3% O<sub>2</sub>

**d. Step 4 - Cost Effectiveness Analysis**

The only control technology in the ranking list from Step 3 has been achieved in practice. Therefore, per the District's BACT Policy (dated 11/9/99) Section IX.D.2, the cost effectiveness analysis is not required.

**e. Step 5 - Select BACT**

BACT for PM<sub>10</sub> emissions from this oil field steam generator is natural gas fuel with a sulfur content  $\leq 1$  gr-S/100 scf. BACT is satisfied.

**4. BACT Analysis for CO Emissions:**

Carbon monoxide (CO) emissions are generated from the incomplete combustion of air and fuel.

**a. Step 1 - Identify all control technologies**

The SJVUAPCD BACT Clearinghouse Guideline 1.2.1, updated 3/24/14, identifies for achieved in practice BACT for CO emissions from oil field steam generators  $\geq 5$  MMBtu/hr as follows:

- 1) 25 ppmvd @ 3% O<sub>2</sub>

No technologically feasible alternatives or control alternatives identified as alternate basic equipment for this class and category of source are listed.

**b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

**c. Step 3 - Rank remaining options by control effectiveness**

- 1) 25 ppmvd @ 3% O<sub>2</sub>

**d. Step 4 - Cost Effectiveness Analysis**

The only control technology in the ranking list from Step 3 has been achieved in practice. Therefore, per the District's BACT Policy (dated 11/9/99) Section IX.D.2, the cost effectiveness analysis is not required.

**e. Step 5 - Select BACT**

BACT for CO emissions from this oil field steam generator is a CO limit of 25 ppmvd @ 3% O<sub>2</sub>. The applicant has proposed to install an oil field steam generator with a CO limit of 25 ppmvd @ 3% O<sub>2</sub>; therefore BACT for CO emissions is satisfied.

## **5. BACT Analysis for VOC Emissions:**

Volatile organic compounds (VOC) emissions are generated from the incomplete combustion of the fuel.

### **a. Step 1 - Identify all control technologies**

The SJVUAPCD BACT Clearinghouse guideline 1.2.1, 1<sup>st</sup> quarter 2005, identifies for achieved in practice BACT for VOC emissions from oil field steam generators  $\geq 5$  MMBtu/hr as follows:

- 1) Gaseous fuel

No technologically feasible alternatives or control alternatives identified as alternate basic equipment for this class and category of source are listed.

### **b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

### **c. Step 3 - Rank remaining options by control effectiveness**

- 1) Gaseous fuel

### **d. Step 4 - Cost effectiveness analysis**

The only control technology in the ranking list from Step 3 has been achieved in practice. Therefore, per the District's BACT Policy (dated 11/9/99) Section IX.D.2, the cost effectiveness analysis is not required.

### **e. Step 5 - Select BACT**

BACT for VOC emissions from this oil field steam generator is gaseous fuel. The applicant has proposed to install an oil field steam generator fired on gaseous fuel; therefore BACT for PM<sub>10</sub> emissions is satisfied.

## ATTACHMENT V HRA and AAQA Modeling

## San Joaquin Valley Air Pollution Control District Risk Management Review

To: Richard Edgehill, AQE – Permit Services  
From: Trevor Joy, Air Quality Specialist  
Date: August 21, 2014  
Facility Name: Freeport McMoran  
Location: Dome and Hopkins Leases, HOWSS  
Application #(s): S-1372-417-0 and 418-0  
Project #: 1143358

---

### A. RMR SUMMARY

Categories	Units 417 and 418 NG Steam Generators	Project Totals	Facility Totals
Prioritization Score	0.0	0.0	>1
Acute Hazard Index	0.00	0.00	0.11
Chronic Hazard Index	0.00	0.00	0.05
Maximum Individual Cancer Risk ( $10^{-6}$ )	0.4	0.4	2.4
T-BACT Required?	No		
Special Permit Conditions?	Yes		

### Proposed Permit Conditions

To ensure that human health risks will not exceed District allowable levels; the following permit conditions must be included for:

#### Units # 417, and 418

{1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] N

### B. RMR REPORT

#### I. Project Description

Technical Services received a revised request on August 13, 2014 to perform an Ambient Air Quality Analysis and a Risk Management Review for the proposed installation of two 85 MMBtu/hr Natural Gas Steam Generators.

## II. Analysis

Technical Services performed a prioritization using the District's HEARTs database. Emissions were calculated using "NG 10-100 MMBTU/Hr External Combustion" emission factors. In accordance with the District's *Risk Management Policy for Permitting New and Modified Sources* (APR 1905, March 2, 2001), risks from the proposed unit's toxic emissions were prioritized using the procedure in the 1990 CAPCOA Facility Prioritization Guidelines and incorporated in the District's HEARTs database. The prioritization score for the facility was greater than 1.0 (see RMR Summary Table). Therefore, a refined analysis was required and performed. AERMOD was used, with the parameters outlined below and concatenated meteorological data for Missouri Triangle 2004 to 2008 to determine the maximum dispersion factor at the nearest residential and business receptors. These dispersion factors were input into the HARP model to calculate the chronic and acute hazard indices and the carcinogenic risk for the project. Also, AERMOD was used for the AAQA analysis, with the parameters outlined below to determine the maximum dispersion factors.

The following parameters were used for the review:

Analysis Parameter Units 417-0 and 418-0 (each)			
Closest Receptor - Business (m)	1076	Closest Receptor - Resident (m)	3004
NG Usage (MMBtu/hr)	85	NG Usage (MMBtu/yr)	744,600
Effective Release Height (m)	6.096	Gas Exit Temperature (K)	383
Stack Inside Diameter (m)	1.07	Gas Exit Velocity (m/s)	13.7

Technical Services also performed modeling for criteria pollutants CO, NO<sub>x</sub>, SO<sub>x</sub> and PM<sub>10</sub>; as well as a RMR. The emission rates used for criteria pollutant modeling were

Parameter	NO <sub>x</sub>	Sox	CO	PM10	PM2.5
Lbs/hr	1.53	0.2	6.3	0.3	0.3
Lbs/yr	4,617	2,122	16,530	2,234	2,234

The results from the Criteria Pollutant Modeling are as follows:

### Criteria Pollutant Modeling Results\*

Values are in µg/m<sup>3</sup>

Steam Generator	1 Hour	3 Hours	8 Hours	24 Hours	Annual
CO	Pass	X	Pass	X	X
NO <sub>x</sub>	Pass <sup>1</sup>	X	X	X	Pass
SO <sub>x</sub>	Pass <sup>2</sup>	Pass	X	Pass	Pass
PM <sub>10</sub>	X	X	X	Pass <sup>3</sup>	Pass <sup>3</sup>
PM2.5	X	X	X	Pass <sup>3</sup>	Pass <sup>3</sup>

\*Results were taken from the attached PSD spreadsheet.

<sup>1</sup>The project was compared to the 1-hour NO<sub>2</sub> National Ambient Air Quality Standard that became effective on April 12, 2010 using the District's approved procedures. The criteria pollutant 1-hour value passed using TIER I NO<sub>2</sub> NAAQS modeling

<sup>2</sup>The project was compared to the 1-hour SO<sub>2</sub> National Ambient Air Quality Standard that became effective on August 23, 2010 using the District's approved procedures.

<sup>3</sup>The maximum predicted concentration for emissions of these criteria pollutants from the proposed unit are below EPA's level of significance as found in 40 CFR Part 51.165 (b)(2).



### **III. Conclusion**

The prioritization score is less than 1.0. In accordance with the District's Risk Management Policy, the project is approved without Toxic Best Available Control Technology (T-BACT).

To ensure that human health risks will not exceed District allowable levels; the permit conditions listed on page 1 of this report must be included for this proposed unit.

The emissions from the proposed equipment will not cause or contribute significantly to a violation of the State and National AAQS.

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

#### **Attachments:**

- A. RMR request from the project engineer
- B. Prioritization score with toxic emissions summary
- C. HEARTS – Facility Summary
- D. AAQA spreadsheet

**ATTACHMENT VI**  
**Statewide Compliance Statement and Title V Compliance**  
**Certification Form**



**FREEPORT-McMoRAN  
OIL & GAS**

Freeport-McMoRan Oil & Gas  
1200 Discovery Dr., Suite 500  
Bakersfield, CA 93309

Telephone: 881-322-7600

August 6, 2011

San Joaquin Valley  
Pollution Control District  
34946 Flyover Court  
Bakersfield, CA. 93308  
Attention: Mr. Richard Edgehill

**RULE 2201 COMPLIANCE STATEMENT  
ATC S-1372 FEDERAL MAJOR MODIFICATION  
Project # 1143358**

Mr. Edgehill:

In accordance with Rule 2201, Section 4.15 "Additional Requirements for new Major Sources and Federal Major Modifications", FM O&G is providing this compliance statement regarding its proposed ATC for Steam Generators at Dome #71 and Hopkins #72.

All major stationary sources in California owned and operated by FM O&G, or by any entity controlling, controlled by, or under common control with FM O&G, and which are subject to emission limitations are in compliance or on a schedule for compliance with all applicable emission limitations and standards. These sources include one or more of the following oil and gas production facilities:

1. Arroyo Grande Field
2. Inglewood Field
3. Lompoc Point Pedernales Title V Stationary Source
4. Gaviota Oil Heating Facility, Point Arguello Title V Stationary Source

Based on information and belief formed after reasonable inquiry, the statements and information in this letter are true, accurate, and complete. Should you have any questions concerning this matter, please contact Daniel Mudge at (661) 395-5206.

Sincerely,

Steve Rusch  
Vice President of EHS and Government Affairs



San Joaquin Valley  
Unified Air Pollution Control District

RECEIVED  
AUG - 5 2014  
SJVAPCD  
Southern Region



**TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM**

**I. TYPE OF PERMIT ACTION (Check appropriate box)**

- ☐ SIGNIFICANT PERMIT MODIFICATION ☒ ADMINISTRATIVE  
☐ MINOR PERMIT MODIFICATION ☐ AMENDMENT

COMPANY NAME: Freeport-McMoRan Oil & Gas LLC	FACILITY ID: S - 1372
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: Freeport-McMoRan Oil & Gas	
3. Agent to the Owner: Kenneth R. Bork	

**II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):**

- ☒ Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- ☒ Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- ☒ Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- ☒ Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

Kenneth R. Bork

Signature of Responsible Official

8/5/2014

Date

Kenneth R. Bork

\_\_\_\_\_  
Name of Responsible Official (please print)

\_\_\_\_\_  
Senior Environmental Advisor

\_\_\_\_\_  
Title of Responsible Official (please print)

ATTACHMENT VII  
Draft ATCs

San Joaquin Valley  
Air Pollution Control District

## AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT

PERMIT NO: S-1372-417-0

LEGAL OWNER OR OPERATOR: FREEPORT-MC MORAN OIL & GAS

MAILING ADDRESS: 1200 DISCOVERY DR - STE 500  
BAKERSFIELD, CA 93309

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE  
CA

SECTION: NW23 TOWNSHIP: 31S RANGE: 22E

### EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#71), WITH NORTH AMERICAN GLE ULTRA LOW NOX BURNER (OR EQUIVALENT) AND A FLUE GAS RECIRCULATION SYSTEM (DOME)

## CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 1,731 lb, 2nd quarter - 1,731 lb, 3rd quarter - 1,731 lb, and fourth quarter - 1,731 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOx emission reduction credits for the following quantity of combined SOx and PM10 emissions: 1st quarter - 1,633 lb, 2nd quarter - 1,633 lb, 3rd quarter - 1,634 lb, and fourth quarter - 1,634 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Sayed Sadredin, Executive Director, APCO

Arnaud Marjollet, Director of Permit Services

S-1372-417-0 : Dec 16 2014 4:10PM - EDGEHUR : Joint Inspection NOT Required

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308 • (661) 392-5500 • Fax (661) 392-5585

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 837 lb, 2nd quarter - 837 lb, 3rd quarter - 838 lb, and fourth quarter - 838 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. ERC Certificate Numbers S-4384-1, S-4368-2, S-4193-2, and S-1304-5 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. Emissions reduction credits for SOx may be used for PM10 at a 1:1 offset ratio. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
10. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
11. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. Steam generator shall be equipped with operational fuel gas volumetric flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. The sulfur content of any fuel, or fuels combined, shall not exceed 1 grains of total sulfur (as H2S) per 100 dscf of fuel gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
16. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084, D 4468, D 6667 or grab sample analysis by GC-FPD/TCD or double GC performed in the laboratory. [District Rule 1070, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit
17. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested monthly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 6 consecutive months for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, monthly testing shall resume. [District Rules 1070, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit
18. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 1070, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

19. Except during startup and shutdown, emissions shall not exceed any of the following limits: 5 ppmvd NOx @ 3% O2 or 0.0062 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.003 lb-PM10/MMBtu, 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. Duration of start-up and shutdown shall not exceed 2 hours each per occurrence. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Emissions rates shall not exceed 16.7 lb-NOx/day NOx nor 4,617 lb-NOx/yr and 56.6 lb-CO/day nor 13,775 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4320] Federally Enforceable Through Title V Permit
23. Flue gas recirculation system shall be operated whenever steam generator is operated. [District Rule 2201] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. Source testing to measure NOx, CO, and VOC emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320]

DRAFT  
CONDITIONS CONTINUE ON NEXT PAGE



31. Source testing to measure natural gas-combustion NO<sub>x</sub> and CO emissions from this unit shall be conducted once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. When the unit changes fuel source, the unit shall undergo source testing to measure NO<sub>x</sub> and CO emissions within 60 days of the change unless the unit has already undergone source testing in the last twelve (12) months or thirty-six (36) months after demonstrating compliance on the previous two (2) source tests when fired on that fuel source. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
34. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
35. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
36. NO<sub>x</sub> emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
37. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
38. Stack gas oxygen (O<sub>2</sub>) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
39. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
40. Records of sulfur content (gr S/100 scf) of combusted gas shall be maintained. [District Rules 1070, 2201, and 4320] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley  
Air Pollution Control District

## AUTHORITY TO CONSTRUCT

PERMIT NO: S-1372-418-0

ISSUANCE DATE: DRAFT

LEGAL OWNER OR OPERATOR: FREEPORT-MC MORAN OIL & GAS

MAILING ADDRESS: 1200 DISCOVERY DR - STE 500  
BAKERSFIELD, CA 93309

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE  
CA

SECTION: NW10 TOWNSHIP: 29S RANGE: 21E

### EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR, WITH NORTH AMERICAN GLE ULTRA LOW NOX BURNER (OR EQUIVALENT) AND A FLUE GAS RECIRCULATION SYSTEM (HOPKINS)

## CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 1,731 lb, 2nd quarter - 1,732 lb, 3rd quarter - 1,732 lb, and fourth quarter - 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOx emission reduction credits for the following quantity of combined PM10 and SOx emissions: 1st quarter - 1,633 lb, 2nd quarter - 1,633 lb, 3rd quarter - 1,634 lb, and fourth quarter - 1,634 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST** NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-6500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

Arnaud Marjollet, Director of Permit Services

S-1372-418-0 : Dec 16 2014 4:10PM - EDGEHILL : Joint Inspection NOT Required

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308 • (661) 392-5500 • Fax (661) 392-5585

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 837 lb, 2nd quarter - 837 lb, 3rd quarter - 838 lb, and fourth quarter - 838 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. ERC Certificate Numbers S-4384-1, S-4368-2, S-4193-2, and S-1304-5 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. Emissions reduction credits for SOx may be used for PM10 at a 1:1 offset ratio. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
10. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
11. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. Steam generator shall be equipped with operational fuel gas volumetric flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. The sulfur content of any fuel, or fuels combined, shall not exceed 1 grains of total sulfur (as H<sub>2</sub>S) per 100 dscf of fuel gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
16. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084, D 4468, D 6667 or grab sample analysis by GC-FPD/TCD or double GC performed in the laboratory. [District Rule 1070, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit
17. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested monthly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 6 consecutive months for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, monthly testing shall resume. [District Rules 1070, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit
18. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 1070, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

**DRAFT**  
CONDITIONS CONTINUE ON NEXT PAGE

19. Except during startup and shutdown, emissions shall not exceed any of the following limits: 5 ppmvd NOx @ 3% O2 or 0.0062 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.003 lb-PM10/MMBtu, 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. Duration of start-up and shutdown shall not exceed 2 hours each per occurrence. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Emissions rates shall not exceed 16.7 lb-NOx/day NOx nor 4,617 lb-NOx/yr and 56.6 lb-CO/day nor 13,775 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4320] Federally Enforceable Through Title V Permit
23. Flue gas recirculation system shall be operated whenever steam generator is operated. [District Rule 2201] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. Source testing to measure NOx, CO, and VOC emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

31. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. When the unit changes fuel source, the unit shall undergo source testing to measure NOx and CO emissions within 60 days of the change unless the unit has already undergone source testing in the last twelve (12) months or thirty-six (36) months after demonstrating compliance on the previous two (2) source tests when fired on that fuel source. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
34. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
35. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
36. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
37. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
38. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
39. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
40. Records of sulfur content (gr S/100 scf) of combusted gas shall be maintained. [District Rules 1070, 2201, and 4320] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT