



JAN 24 2019

Mr. Spencer Hammond
E&B Natural Resources
3000 James Road
Bakersfield, CA 93308

Re: Proposed ATC / Certificate of Conformity (Significant Mod)
Facility Number: S-1624
Project Number: S-1184033

Dear Mr. Hammond:


Enclosed for your review is the District's analysis of an application for Authorities to Construct for the facility identified above. You requested that Certificates of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. The permits are for five steam generators.

After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authorities to Construct with Certificates of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authorities to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District
Authority to Construct Application Review
New Steam Generators

Facility Name: E&B Natural Resources	Date: 1/9/19
Mailing Address: 3000 James Road Bakersfield, CA 93308	Engineer: David Torii Lead Engineer: Rich Karrs
Contact Person: Spencer Hammond	
Telephone: 310-944-1685	
Application #(s): S-1624-338-0, '339-0, '340-0, '341-0 and '342-0	
Project #: 1184033	
Deemed Complete: 11/16/18	

I. Proposal

E&B Natural Resources (EBNR) has requested an Authority to Construct (ATC) permits for the installation of five 85 MMBtu/hr steam generators. Additionally, tank permits S-1624-38 and '39 will be canceled to mitigate the steam generators' VOC emission increase.

EBNR has received their Title V Permit. This modification can be classified as a Title V significant modification pursuant to Rule 2520, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. EBNR must apply to administratively amend their Title V permit.

II. Applicable Rules

Rule 2201	New and Modified Stationary Source Review Rule (2/18/16)
Rule 2410	Prevention of Significant Deterioration (6/16/11)
Rule 2520	Federally Mandated Operating Permits (6/21/01)
Rule 4001	New Source Performance Standards (4/14/99)
Rule 4101	Visible Emissions (2/17/05)
Rule 4102	Nuisance (12/17/92)
Rule 4201	Particulate Matter Concentration (12/17/92)
Rule 4301	Fuel Burning Equipment (12/17/92)
Rule 4305	Boilers, Steam Generators, and Process Heaters – Phase 2 (8/21/03)
Rule 4306	Boilers, Steam Generators, and Process Heaters – Phase 3 (10/16/08)
Rule 4320	Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr (10/16/08)
Rule 4801	Sulfur Compounds (12/17/92)
CH&SC 41700	Health Risk Assessment
CH&SC 42301.6	School Notice
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)	
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines	

III. Project Location

The equipment will be located in the Wilcox lease within the SW/4 of Section 4, Township 28S, Range 27E in EBNR's Heavy Oil Central stationary source. The equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. Process Description

In TEOR operations, steam generators are used to produce steam which is injected into the production zone to reduce the viscosity of the crude oil and pressurize the oil-bearing strata, thereby facilitating oil flow to producing wells. Produced fluids are then piped to surface facilities for processing and temporary storage.

Production from wells initially enters a gas/liquid separator. Liquid from the gas liquid separator enters wash tanks for separation into oil, gas and water. Separated oil is stored in stock tanks prior to custody transfer.

V. Equipment Listing

Pre-Project Equipment Description (see PTOs in Appendix B):

S-1624-38-3: 1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK, MABRY #8

S-1624-39-3: 1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK, MABRY #9

Proposed ATCs:

S-1624-338-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB-32 - WILCOX)

S-1624-339-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB-33 - WILCOX)

S-1624-340-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB-34 - WILCOX)

S-1624-341-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB-35 - WILCOX)

S-1624-342-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB-36 - WILCOX)

VI. Emission Control Technology Evaluation

Emissions from natural gas-fired steam generators include NO_x, CO, VOC, PM₁₀, and SO_x.

NO_x is the major pollutant of concern when burning natural gas. NO_x formation is either due to thermal fixation of atmospheric nitrogen in the combustion air (thermal NO_x) or due to conversion of chemically bound nitrogen in the fuel (fuel NO_x). Due to the low fuel nitrogen content of natural gas, nearly all NO_x emissions are thermal NO_x. Formation of thermal NO_x is affected by four furnace zone factors: (1) nitrogen concentration, (2) oxygen concentration, (3) peak temperature, and (4) time of exposure at peak temperature.

Low-NO_x burners reduce NO_x formation by producing lower flame temperatures (and longer flames) than conventional burners. Low-NO_x burners delay the mixing of fuel and air by introducing the fuel (or sometimes air) in multiple stages. In the first stage, the air-fuel mixture is fuel-rich in which the oxygen is consumed in reactions with the fuel, thereby limiting excess oxygen available to react with nitrogen to produce thermal NO_x.

The combustion zones in the secondary and tertiary stages are maintained in a fuel-lean environment. The excess air in these stages helps to reduce the flame temperature, which in turn minimizes the reaction between excess oxygen and nitrogen. The North American burner incorporates patented internal mixing elements that pre-mix the fuel and air prior to combustion in the reaction zone. By completing a majority of the combustion in the burner reaction chamber, the low emissions of the burner are protected from process influences.

Flue gas recirculation (FGR) reduces NO_x emissions by recirculating a percentage of the exhaust gas back into the windbox. This reduces the oxygen concentration in the air-fuel mixture and regulates the combustion process, lowering the combustion temperature. The lowered availability of oxygen in conjunction with lowered combustion temperature reduces the formation of NO_x.

Tanks S-1624-38 and '39 are each equipped with a pressure-vacuum (PV) relief vent valve set to within 10% of the maximum allowable working pressure of the tanks. PV-valves reduces VOC wind induced emissions from the tank vent.

VII. General Calculations

A. Assumptions

Steam Generators:

- Maximum heat input rating = 85 MMBtu/hr (each steam generator)
- F-Factor for Natural Gas @ 60°F: 8,578 dscf/MMBtu
- Gas Molar Vol 60 oF = $10.7316 \text{ psia ft}^3/\text{lbmol R} \times 519.67 \text{ R}/(14.696 \text{ psia/atm})$
= 378.61 ft³/lbmol
- Natural Gas Heating Value = 1,000 Btu/scf

Tank S-1624-38 and '39:

- Throughput = one turnover/day (District practice for tanks without a throughput limit)
- Pre-project TVP limit = 0.5 psia (PTO)

- Volume = 1,000 bbls (PTO)
- Not constant level

B. Emission Factors

Pollutant	Steam Generators Emission Factors (EF)		Source
NO _x	0.0062 lb-NO _x /MMBtu	5 ppmvd NO _x (@ 3%O ₂)	Proposed and BACT
SO _x	0.00285 lb SO ₂ /MMBtu	1.0 gr S/100 scf	Proposed and APR 1720
PM ₁₀	*0.0035 lb-PM ₁₀ /MMBtu		Proposed
CO	0.0185 lb-CO/MMBtu	25 ppmv CO @3% O ₂	BACT
VOC	0.0055 lb-VOC/MMBtu	13 ppmv VOC @3% O ₂	Proposed & AP-42 (07/98) Table 1.4-2

*The District has determined that steam generators fired solely on PUC-quality natural gas have PM₁₀ emissions no greater than 0.003 lb-PM₁₀/ MMBtu. The applicant has conservatively proposed a limit of 0.0035 lb-PM₁₀/ MMBtu.

The PE for tanks S-1624-38 and '39 are based on the results from the District's Microsoft Excel spreadsheets for Tank Emissions - Fixed Roof Crude Oil less than 26° API.

C. Calculations

1. Pre-Project Potential to Emit (PE1)

Since the steam generators are new emissions units, PE1 = 0 for all pollutants.

PE1*		
Tanks	Daily Emissions (lb/day)	Annual Emissions (lb/year)
S-1624-38	52.2	19,051
S-1624-39	52.2	19,051
Total:		38,102

*See emission calculations in Appendix C

2. Post Project Potential to Emit (PE2)

The potential to emit for each steam generator is summarized in the tables below:

Pollutant	Daily PE2			
	EF2 (lb/M MBtu)	Heat Input (M MBtu/hr)	Operating Schedule (hr/day)	Daily PE2 (lb/day)
NO _x	0.0062	85	24	12.6
SO _x	0.0029	85	24	5.8
PM ₁₀	0.0035	85	24	7.1
CO	0.0185	85	24	37.7
VOC	0.0055	85	24	11.2

Pollutant	Annual PE2			
	EF2 (lb/M MBtu)	Heat Input (M MBtu/hr)	Operating Schedule (hr/year)	Annual PE2 (lb/year)
NO _x	0.0062	85	8,760	4,617
SO _x	0.0029	85	8,760	2,122
PM ₁₀	0.0035	85	8,760	2,606
CO	0.0185	85	8,760	13,775
VOC	0.0055	85	8,760	4,095

Total PE2					
	NO _x	SO _x	PM ₁₀	CO	VOC
S-1624-338-0	4,617	2,122	2,606	13,775	4,095
S-1624-339-0	4,617	2,122	2,606	13,775	4,095
S-1624-340-0	4,617	2,122	2,606	13,775	4,095
S-1624-341-0	4,617	2,122	2,606	13,775	4,095
S-1624-342-0	4,617	2,122	2,606	13,775	4,095
Total:	23,085	10,610	13,030	68,875	20,475

3. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

SSPE1 (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE1*	161,406	65,642	77,098	650,012	>> 20,000

*from latest project S1183307

4. Post Project Stationary Source Potential to Emit (SSPE2)

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site.

SSPE2 (lb/year)					
Permit Unit	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE1	161,406	65,642	77,098	650,012	>> 20,000
S-1624-38-3	0	0	0	0	-19,051
S-1624-39-3	0	0	0	0	-19,051
S-1624-338-0	4,617	2,122	2,606	13,775	4,095
S-1624-339-0	4,617	2,122	2,606	13,775	4,095
S-1624-340-0	4,617	2,122	2,606	13,775	4,095
S-1624-341-0	4,617	2,122	2,606	13,775	4,095
S-1624-342-0	4,617	2,122	2,606	13,775	4,095
SSPE2	184,491	76,252	90,128	718,887	>>20,000
SSIPE	23,085	10,610	13,030	68,875	-17,627

5. Major Source Determination

Rule 2201 Major Source Determination:

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source
- Emissions from non-road IC engines (i.e. IC engines at a particular site at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Rule 2201 Major Source Determination (lb/year)						
	NO _x	SO _x	PM ₁₀	PM _{2.5}	CO	VOC
SSPE1	161,406	65,642	77,098	77,098	650,012	>>20,000
SSPE2	184,491	76,252	90,128	90,128	718,887	>>20,000
Major Source Threshold	20,000	140,000	140,000	140,000	200,000	20,000
Major Source?	y	n	n	n	y	y

Note: PM2.5 assumed to be equal to PM10

This source is an existing Major Source for NO_x, CO and VOC emissions and will remain so. No change in other pollutants are proposed or expected as a result of this project.

Rule 2410 Major Source Determination:

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). Therefore the PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination (tons/year)						
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀
Estimated Facility PE before Project Increase				>250		
PSD Major Source Thresholds	250	250	250	250	250	250
PSD Major Source?				y		

As shown above, the facility is an existing PSD major source for at least one pollutant.

6. Baseline Emissions (BE)

The BE calculation (in lb/year) is performed pollutant-by-pollutant for each unit within the project to calculate to determine the amount of offsets required.

Pursuant to District Rule 2201, BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, located at a Major Source.

otherwise,

BE = Historic Actual Emissions (HAE), calculated pursuant to District Rule 2201.

Since steam generators are new emissions units, BE = PE1 = 0 for all pollutants.

7. SB 288 Major Modification

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is a major source for NO_x and VOC the project's PE2 is compared to the SB 288 Major Modification Thresholds in the following table in order to determine if the SB 288 Major Modification calculation is required.

SB 288 Major Modification Thresholds			
Pollutant	Project PE2 (lb/year)	Threshold (lb/year)	SB 288 Major Modification Calculation Required?
NO _x	23,085	50,000	N
SO _x	NA	80,000	
PM ₁₀	NA	30,000	
VOC	20,475	50,000	N

Since none of the SB 288 Major Modification Thresholds are surpassed with this project, this project does not constitute an SB 288 Major Modification.

8. Federal Major Modification

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

The determination of Federal Major Modification is based on a two-step test. For the first step, only the emission *increases* are counted. Emission decreases may not cancel out the increases for this determination.

Step 1

For new emissions units, the increase in emissions is equal to the PE2 for each new unit included in this project.

The project's combined total emission increases are compared to the Federal Major Modification Thresholds in the following table.

Federal Major Modification Thresholds for Emission Increases			
Pollutant	Total Emissions Increases (lb/yr)	Thresholds (lb/yr)	Federal Major Modification?
NO _x	23,085	0	Y
VOC	20,475	0	Y
PM ₁₀	NA	30,000	
PM _{2.5}	NA	20,000	
SO _x	NA	80,000	

Since there is an increase in NO_x and VOC emissions, this project constitutes a Federal Major Modification. Federal Offset quantities are calculated below.

Federal Offset Quantities:

The Federal offset quantity is only calculated only for the pollutants for which the project is a Federal Major Modification. The Federal offset quantity is the sum of the annual emission changes for all new and modified emission units in a project calculated as the potential to emit after the modification (PE2) minus the actual emissions (AE) during the

baseline period for each emission unit multiplied by the applicable federal offset ratio. There are no special calculations performed for units covered by an SLC.

NOx		Federal Offset Ratio		1.5
Permit No.	Actual Emissions (lb/year)	Potential Emissions (lb/year)	Emissions Change (lb/yr)	
S-1624-338-0	NA	4,617	4,617	
S-1624-339-0	NA	4,617	4,617	
S-1624-340-0	NA	4,617	4,617	
S-1624-341-0	NA	4,617	4,617	
S-1624-342-0	NA	4,617	4,617	
Net Emission Change (lb/year):			23,085	
Federal Offset Quantity: (NEC * 1.5)			34,628	

VOC		Federal Offset Ratio		1.5
Permit No.	Actual Emissions (lb/year)	Potential Emissions (lb/year)	Emissions Change (lb/yr)	
S-1624-338-0	NA	4,095	4,095	
S-1624-339-0	NA	4,095	4,095	
S-1624-340-0	NA	4,095	4,095	
S-1624-341-0	NA	4,095	4,095	
S-1624-342-0	NA	4,095	4,095	
Net Emission Change (lb/year):			20,475	
Federal Offset Quantity: (NEC * 1.5)			30,713	

9. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination

Rule 2410 applies to any pollutant regulated under the Clean Air Act, except those for which the District has been classified nonattainment. The pollutants which must be addressed in the PSD applicability determination for sources located in the SJV and which are emitted in this project are: (See 52.21 (b) (23) definition of significant)

I. Project Location Relative to Class 1 Area

As demonstrated in the “PSD Major Source Determination” Section above, the facility was determined to be an existing PSD Major Source. Because the project is not located within 10 km (6.2 miles) of a Class 1 area – modeling of the emission increase is not required to determine if the project is subject to the requirements of Rule 2410.

II. Project Emission Increase – Significance Determination

a. Evaluation of Calculated Post-project Potential to Emit for New or Modified Emissions Units vs PSD Significant Emission Increase Thresholds

As a screening tool, the post-project potential to emit from all new and modified units is compared to the PSD significant emission increase thresholds, and if the total potentials to emit from all new and modified units are below the applicable thresholds, no further PSD analysis is needed.

PSD Significant Emission Increase Determination: Potential to Emit (tons/year)					
	NO₂	SO₂	CO	PM	PM₁₀
Total PE from New and Modified Units	12	5	34	7	7
PSD Significant Emission Increase Thresholds	40	40	100	25	15
PSD Significant Emission Increase?	n	n	n	n	n

As demonstrated above, because the post-project total potentials to emit from all new and modified emission units are below the PSD significant emission increase thresholds, this project is not subject to the requirements of Rule 2410 and no further discussion is required.

10. Quarterly Net Emissions Change (QNEC)

The QNEC is calculated solely to establish emissions that are used to complete the District's PAS emissions profile screen. Detailed QNEC calculations are included in Appendix A.

VIII. Compliance Determination

Rule 2201 New and Modified Stationary Source Review Rule

A. Best Available Control Technology (BACT)

1. BACT Applicability

Pursuant to District Rule 2201, Section 4.1, BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis. Unless specifically exempted by Rule 2201, BACT shall be required for the following actions*:

- a. Any new emissions unit with a potential to emit exceeding two pounds per day,
- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an Adjusted Increase in Permitted Emissions (AIPE) exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in an SB 288 Major Modification or a Federal Major Modification, as defined by the rule.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

a. New emissions units – PE > 2 lb/day

As seen in Section VII.C.2 above, the applicant is proposing to install new steam generators each with a PE greater than 2 lb/day for NO_x, SO_x, PM₁₀, CO, and VOC. Therefore BACT for new units with PE > 2 lb/day purposes is triggered for NO_x, SO_x, PM₁₀, CO, and VOC.

b. Relocation of emissions units – PE > 2 lb/day

As discussed in Section I above, there are no emissions units being relocated from one stationary source to another; therefore BACT is not triggered.

c. Modification of emissions units – AIPE > 2 lb/day

As discussed in Section I above, there are no modified emissions units associated with this project. Therefore BACT is not triggered.

d. SB 288/Federal Major Modification

As discussed in Sections VII.C.7 and VII.C.8 above, this project does constitute a Federal Major Modification for NO_x and VOC emissions. Therefore BACT is triggered for NO_x and VOC for all emissions units in the project for which there is an emission increase.

2. BACT Guideline

BACT Guideline 1.2.1, applies to the oilfield steam generators greater \geq 20 MMBtu/hr. [Oilfield Steam Generator ($>$ or $=$ 20 MMBtu/hr)] (See **Appendix D**)

3. Top-Down BACT Analysis

Per Permit Services Policies and Procedures for BACT, a Top-Down BACT analysis shall be performed as a part of the application review for each application subject to the BACT requirements pursuant to the District's NSR Rule.

Pursuant to the attached Top-Down BACT Analysis (see **Appendix D**), BACT has been satisfied with the following:

NO _x :	5 ppmvd @ 3% O ₂
SO _x and PM ₁₀ :	gaseous fuel treated such that the sulfur content does not exceed 1 gr of sulfur compounds (as S) per 100 dscf
CO:	25 ppmvd or less @ 3% O ₂
VOC:	Gaseous fuel

B. Offsets**1. Offset Applicability**

Pursuant to District Rule 2201, Section 4.5, offset requirements shall be triggered on a pollutant by pollutant basis and shall be required if the SSPE2 equals or exceeds the offset threshold levels in Table 4-1 of Rule 2201.

The SSPE2 is compared to the offset thresholds in the following table.

Offset Determination (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE2	184,491	76,252	90,128	718,887	>>20,000
Offset Thresholds	20,000	54,750	29,200	200,000	20,000
Offsets triggered?	y	y	y	y	y

2. Quantity of Offsets Required

The quantity of offsets in pounds per year for NO_x is calculated as follows for sources with an SSPE1 greater than the offset threshold levels before implementing the project being evaluated.

Offsets Required (lb/year) = $(\Sigma[PE2 - BE] + ICCE) \times DOR$, for all new or modified emissions units in the project,

Where,

PE2 = Post Project Potential to Emit, (lb/year)

BE = Baseline Emissions, (lb/year)

ICCE = Increase in Cargo Carrier Emissions, (lb/year)

DOR = Distance Offset Ratio, determined pursuant to Section 4.8

BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, Located at a Major Source.

otherwise,

BE = HAE

The facility is proposing to install new steam generators; therefore their BEs = 0. Also, there are no increases in cargo carrier emissions; therefore offsets can be determined as follows:

Offsets Required (lb/year) = $(PE2 - BE) \times DOR$

NO_x:

PE2 (NO_x) = 4617 lb/year

BE (NO_x) = 0 lb/year

The project is a Federal Major Modification for NO_x. therefore the correct offset ratio for NO_x is 1.5:1.

$$\begin{aligned}\text{Offsets Required (lb/year)} &= (4617 - 0) \times 1.5 \\ &= 6926 \text{ lb NO}_x/\text{year}\end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned}\text{Quarterly offsets required (lb/qtr)} &= (6926 \text{ lb NO}_x/\text{year}) \div (4 \text{ quarters/year}) \\ &= 1731.5 \text{ lb/qtr}\end{aligned}$$

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets				
(where X is the annual amount of offsets, and $X \div 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore the appropriate quarterly emissions to be offset are as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-1624-338-0	1731	1731	1732	1732
S-1624-339-0	1731	1731	1732	1732
S-1624-340-0	1731	1731	1732	1732
S-1624-341-0	1731	1731	1732	1732
S-1624-342-0	1731	1731	1732	1732
Total	8655	8655	8660	8660

The applicant has stated that the facility plans to use ERC certificate S-5016-2 to offset the increases in NO_x emissions associated with this project. The above certificate has available quarterly NO_x credits as follows:

	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
ERC #S-5016-2	8900	8900	8900	8900

As seen above, the facility has sufficient credits to fully offset the quarterly NO_x emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender NO_x emission reduction credits for the following quantity of emissions: 1st quarter – 1,731 lb, 2nd quarter - 1,731 lb, 3rd quarter - 1,732 lb, and 4th quarter - 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- ERC Certificate Number S-5016-2 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

SO_x:

PE2 (SO_x) = 2122 lb/year

BE (SO_x) = 0 lb/year

The approved distance offset ratio is 1:1.2 because the emission reduction originated less than 15 miles for the proposed unit.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= (2122 - 0) \times 1.2 \\ &= 2546 \text{ lb SO}_x/\text{year} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (2546 \text{ lb SO}_x/\text{year}) \div (4 \text{ quarters/year}) \\ &= 636.5 \text{ lb/qtr} \end{aligned}$$

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets (where X is the annual amount of offsets, and $X \div 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore the appropriate quarterly emissions to be offset are as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-1624-338-0	636	636	637	637
S-1624-339-0	636	636	637	637
S-1624-340-0	636	636	637	637
S-1624-341-0	636	636	637	637
S-1624-342-0	636	636	637	637
Total	3180	3180	3185	3185

The applicant has stated that the facility plans to use ERC certificates S-5018-5 and S-5020-5 to offset the increases in SO_x emissions associated with this project. The above certificates has available quarterly NO_x credits as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
ERC # S-5018-5	12,194	8,550	8,550	10,195
ERC # S-5020-5	4,906	8,550	8,550	6,905
Total:	17,100	17,100	17,100	17,100

As seen above, the facility has sufficient credits to fully offset the quarterly SO_x emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender SO_x emission reduction credits for the following quantity of emissions: 1st quarter – 636 lb, 2nd quarter – 636 lb, 3rd quarter – 637 lb, and 4th quarter – 637 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- ERC Certificate Numbers S-5018-5 and S-5020-5 (or a certificate(s) split from these certificate(s)) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

PM10:

PE2 (PM10) = 2606 lb/year
 BE (PM10) = 0 lb/year

Interpollutant offset ratios for trades between SO_x and PM₁₀ are allowed pursuant to Rule 2201, Section 4.13.3.1.2. Pursuant to draft District policy APR 1430, SO_x ERCs may be used to offset PM10 at an interpollutant ratio of 1.0 : 1.0. An interpollutant ratio of 1.0 : 1.0 for SO_x to PM₁₀ will be applied.

The approved distance offset ratio is 1:1.2 because the emission reduction originated less than 15 miles for the proposed unit.

Offsets Required (lb/year) = (2606 – 0) x 1.2
 = 3127lb PM10/year

Calculating the appropriate quarterly emissions to be offset is as follows:

Quarterly offsets required (lb/qtr) = (3127 lb PM10/year) ÷ (4 quarters/year)
 = 781.75 lb/qtr

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets (where X is the annual amount of offsets, and $X \div 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore the appropriate quarterly emissions to be offset are as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-1624-338-0	781	782	782	782
S-1624-339-0	781	782	782	782
S-1624-340-0	781	782	782	782
S-1624-341-0	781	782	782	782
S-1624-342-0	781	782	782	782
Total	3905	3910	3910	3910

The applicant has stated that the facility plans to use ERC certificates S-5018-5 and S-5020-5 to offset the increases in PM10 emissions associated with this project. The above certificates has available quarterly NO_x credits as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
ERC # S-5018-5	12,194	8,550	8,550	10,195
ERC # S-5020-5	4,906	8,550	8,550	6,905
Total:	17,100	17,100	17,100	17,100

As seen above, the facility has sufficient credits to fully offset the quarterly SO_x emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender SO_x (for PM10) emission reduction credits for the following quantity of emissions: 1st quarter – 781 lb, 2nd quarter – 782 lb, 3rd quarter – 782 lb, and 4th quarter – 782 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- ERC Certificate Numbers S-5018-5 and S-5020-5 (or a certificate(s) split from these certificate(s)) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

CO:

Pursuant to section 4.6.1 of Rule 2201, increases in CO in attainment areas are exempt from offsetting if the applicant demonstrates to the satisfaction of the APCO, that the Ambient Air Quality Standards are not violated in the areas to be affected and such emissions will be consistent with Reasonable Further Progress and will not cause or contribute to a violation of Ambient Air Quality Standards. As shown below in section VII.F, Ambient Air Quality Standards are not violated; therefore, offsets are not required for CO.

VOC:

PE1 (five SGs) = 0

PE2 (five SGs) = 20,475 lb/year

BE (both tanks) = 38,102 lb/year

PE2 (both tanks) = 0

The project is a Federal Major Modification for VOC and therefore the correct offset ratio for VOC is 1.5:1.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= (20,475 - 38,102) \times 1.5 \\ &= 0 \text{ lb VOC/year} \end{aligned}$$

As demonstrated in the calculation above, the amount of VOC offsets is zero. Therefore, VOC offsets will not be required for this project.

3. ERC Withdrawal Calculations

The applicant must identify the ERC Certificate(s) to be used to offset the increase of emissions for the project. As indicated in previous section, the applicant is proposing to use the identified ERC certificates to mitigate the increases of NO_x, SO_x and PM₁₀ emissions associated with this project. See **Appendix E** for detailed ERC Withdrawal Calculations.

C. Public Notification**1. Applicability**

Pursuant to District Rule 2201, Section 5.4, public noticing is required for:

- a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications,
- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- c. Any project which results in the offset thresholds being surpassed,
- d. Any project with an SSIPE of greater than 20,000 lb/year for any pollutant, and/or
- e. Any project which results in a Title V significant permit modification

a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications

New Major Sources are new facilities, which are also Major Sources. Since this is not a new facility, public noticing is not required for this project for New Major Source purposes.

As demonstrated in Sections VII.C.7 and VII.C.8, this project is a Federal Major Modification. Therefore, public noticing for Federal Major Modification purposes is required.

b. PE > 100 lb/day

Applications which include a new emissions unit with a PE greater than 100 pounds during any one day for any pollutant will trigger public noticing requirements. As seen in Section VII.C.2 above, this project does not include a new emissions unit which has daily emissions greater than 100 lb/day for any pollutant, therefore public noticing for PE > 100 lb/day purposes is not required.

c. Offset Threshold

Pursuant to District Rule 2201, Section 4.5.3, offset requirements shall be triggered on a pollutant-by-pollutant basis, unless exempted pursuant to Section 4.6, offsets shall be required if the post-project Stationary Source Potential to Emit (SSPE2) equals or exceeds specific threshold levels.

The SSPE1 and SSPE2 are compared to the offset thresholds in the following table.

Offset Thresholds				
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	Offset Threshold	Public Notice Required?
NO _x	161,406	184,491	20,000 lb/year	No
SO _x	65,642	76,252	54,750 lb/year	No
PM ₁₀	77,098	90,128	29,200 lb/year	No
CO	650,012	718,887	200,000 lb/year	No
VOC	>> 20,000	>>20,000	20,000 lb/year	No

As detailed above, there were no thresholds surpassed with this project; therefore public noticing is not required for offset purposes.

d. SSIPE > 20,000 lb/year

Public notification is required for any permitting action that results in a SSIPE of more than 20,000 lb/year of any affected pollutant. According to District policy, the SSIPE = SSPE2 – SSPE1. The SSIPE is compared to the SSIPE Public Notice thresholds in the following table.

SSIPE Public Notice Thresholds					
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	SSIPE (lb/year)	SSIPE Public Notice Threshold	Public Notice Required?
NO _x	161,406	184,491	23,085	20,000 lb/year	Y
SO _x	65,642	76,252	10,610	20,000 lb/year	N
PM ₁₀	77,098	90,128	13,030	20,000 lb/year	N
CO	650,012	718,887	68,875	20,000 lb/year	Y
VOC			-17,627	20,000 lb/year	N

As demonstrated above, the SSIPEs for NO_x and CO were greater than 20,000 lb/year; therefore public noticing for SSIPE purposes is required.

e. Title V Significant Permit Modification

As shown in the Discussion of Rule 2520 below, this project constitutes a Title V significant modification. Therefore, public noticing for Title V significant modifications is required for this project.

2. Public Notice Action

As discussed above, public noticing is required for this project for NO_x and VOC emissions triggering a Federal Major Modification and the IPE of NO_x and CO greater than 20,000 lb/year. Therefore, public notice documents will be submitted to the California Air Resources Board (CARB) and a public notice will be published in a local newspaper of general circulation prior to the issuance of the ATC for this equipment.

D. Daily Emission Limits (DELs)

DELs and other enforceable conditions are required by Rule 2201 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. The DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

Proposed Rule 2201 (DEL) Conditions:

The unit shall only be fired on natural gas/waste gas with a maximum sulfur content of 1.0 gr S/100 scf. [District Rules 2201 and 4320]

Emission rates shall not exceed any of the following: NO_x (as NO_x): 5 ppmvd @ 3% O₂ or 0.0062 lb/MMBtu; SO_x: 0.00285 lb/MMBtu; PM₁₀: 0.0035 lb/MMBtu; CO: 25 ppmvd @ 3% O₂ or 0.0185 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rules 2201 and 4320]

E. Compliance Assurance

1. Source Testing

This unit is subject to District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*. Source testing requirements, in accordance with District Rule 4320, will be discussed in Section VIII, *District Rule 4320*, of this evaluation.

1. Monitoring

As required by District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*, this unit is subject to monitoring requirements. Monitoring requirements, in accordance with District Rule 4320, will be discussed in Section VIII, *District Rule 4320*, of this evaluation.

2. Recordkeeping

As required by District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*, this unit is subject to recordkeeping requirements. Recordkeeping requirements, in accordance with District Rule 4320, will be discussed in Section VIII, *District Rule 4320*, of this evaluation.

The following permit condition will be listed on permits as follows:

Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)]

All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)]

4. Reporting

No reporting is required to demonstrate compliance with Rule 2201.

F. Ambient Air Quality Analysis (AAQA)

An AAQA shall be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse a violation of an air quality standard. The District's Technical Services Division conducted the required analysis. Refer to Appendix F of this document for the AAQA summary sheet.

The proposed location is in an attainment area for NO_x, CO, and SO_x. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO_x, CO, or SO_x.

The proposed location is in a non-attainment area for the state's PM₁₀ as well as federal and state PM_{2.5} thresholds. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for PM₁₀ and PM_{2.5}.

G. Compliance Certification

Section 4.15.2 of this Rule requires the owner of a new Major Source or a source undergoing a Federal Major Modification to demonstrate to the satisfaction of the District that all other Major Sources owned by such person and operating in California are in compliance or are on a schedule for compliance with all applicable emission limitations and standards. As discussed in Section VIII above, this facility is a new major source and this project does constitute a Federal Major Modification, therefore this requirement is applicable. E&B's compliance certification is included in Appendix F.

H. Alternate Siting Analysis

The current project occurs at an existing facility. The applicant proposes to install steam generators.

Since the project will provide steam to be used at the same location, the existing site will result in the least possible impact from the project. Alternative sites would involve the relocation and/or construction of various support structures on a much greater scale, and would therefore result in a much greater impact.

Rule 2410 Prevention of Significant Deterioration

As shown in Section VII.C.9 above, this project does not result in a new PSD major source or PSD major modification. No further discussion is required.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule, and has received their Title V Operating Permit. A significant permit modification is defined as a "permit amendment that does not qualify as a minor permit modification or administrative amendment."

Minor permit modifications are not Title I modifications as defined in this rule. This project triggers a Federal Major Modification, as a result, the proposed project constitutes a Significant Modification to the Title V Permit. E&Bs Title V Compliance Certification form is included in Appendix G.

Rule 4001 New Source Performance Standards (NSPS)

40 CFR Part 60 Subpart Dc Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60. 40 CFR Part 60, Subpart Dc applies to Small Industrial-Commercial-Institutional Steam Generators between 10 MMBtu/hr and 100 MMBtu/hr (post-6/9/89 construction, modification or, reconstruction). Subpart Dc has standards for SO_x and PM₁₀. The 85 MMBtu/hr steam generators are subject to Subpart Dc requirements.

60.42c – Standards for Sulfur Dioxide

Since coal is not combusted by the steam generators in this project, the requirements of this section are not applicable.

60.43c – Standards for Particulate Matter

The steam generators do not fired on coal, combust mixtures of coal with other fuels, combust wood, combust mixtures of wood with other fuels, or oil; therefore, it will not be subject to the requirements of this section.

60.44c – Compliance and Performance Tests Methods and Procedures for Sulfur Dioxide.

Since the steam generators in this project are not subject to the sulfur dioxide requirements of this subpart, no testing to show compliance is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.