



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT



APR 15 2019

Mr. Brooks Waddle
Cal Peak Power - Panoche, LLC
9405 Arrowpoint Blvd
Charlotte, NC 28273

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: C-3811
Project Number: C-1173181

Dear Mr. Waddle:

The District has issued the Final Renewed Title V Permit for Cal Peak Power - Panoche, LLC (see enclosure). The preliminary decision for this project was made on February 7, 2019. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Brian Clerico, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Facility # C-3811
CAL PEAK POWER - PANOCHE, LLC
ATTN: BROOKS WADDLE
9405 ARROWPOINT BLVD
CHARLOTTE, NC 28273

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

| | |
|--------------|----------------|
| Modesto: | (209) 557-6446 |
| Fresno: | (559) 230-5888 |
| Bakersfield: | (661) 392-5665 |

*Failure to comply with the permit unit requirements may result in enforcement action.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Permit to Operate

FACILITY: C-3811

EXPIRATION DATE: 05/31/2023

LEGAL OWNER OR OPERATOR:

CAL PEAK POWER - PANOCHÉ, LLC

MAILING ADDRESS:

ATTN: BROOKS WADDLE
9405 ARROWPOINT BLVD
CHARLOTTE, NC 28273

FACILITY LOCATION:

43699 WEST PANOCHÉ RD
FIREBAUGH, CA 93622-9720

FACILITY DESCRIPTION:

POWER GENERATION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: C-3811-0-3

EXPIRATION DATE: 05/31/2023

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CAL PEAK POWER - PANOCHE, LLC
Location: 43699 WEST PANOCHE RD, FIREBAUGH, CA 93622-9720
C-3811-0-3 - Mar 28 2019 11:56AM - SANDOVAV

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit.
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Fresno County Rule 110. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
42. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
43. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
44. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
45. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
46. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72 and 40 CFR 75] Federally Enforceable Through Title V Permit
47. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
48. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

49. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
50. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit
57. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
58. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit
59. On April 30, 2004, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin May 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3811-1-9

EXPIRATION DATE: 05/31/2023

EQUIPMENT DESCRIPTION:

24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #1 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-2)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Selective catalytic reduction (SCR) system and oxidation catalyst shall serve the common exhaust duct from C-3811-1 and C-3811-2. Common exhaust ducting shall be equipped with a fresh air inlet and blower to be used to lower the exhaust temperature prior to inlet of the SCR system catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be equipped with a continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rules 2201 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. The owner or operator shall certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NO_x, CO and O₂ concentrations. [40 CFR 60.334(c), District Rules 1080 and 4703, and 40 CFR 64] Federally Enforceable Through Title V Permit
7. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and 40 CFR 60.334(c), and District Rule 1080] Federally Enforceable Through Title V Permit
8. The NO_x, CO and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specification 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and 40 CFR 60.334(c), District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
11. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and provisions to sample stack gases at ground level with a portable NOx, CO, and O2 analyzer. [District Rule 1081] Federally Enforceable Through Title V Permit
12. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and Fresno County Rule 406] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
14. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
15. Number of startups and shutdowns shall not exceed 365 in one calendar year. [District Rules 2201] Federally Enforceable Through Title V Permit
16. Each startup or shutdown shall not exceed 30 minutes. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
17. Combined emission rates from units C-3811-1 and C-3811-2 during startup or shutdown shall not exceed : 8.28 lb NOx/hr, 1.42 lb SOx/hr, 3.42 lb PM10/hr, 35.46 lb CO/hr, and 1.28 lb VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Except during startup and shutdown, emission rates from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed any of the following limits: PM10 - 3.24 lb/hr, SOx (as SO2) - 1.42 lb/hr, NOx (as NO2) - 3.4 ppmvd @ 15% O2 and 6.16 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O2 and 1.28 lb/hr, CO - 30 ppmvd @ 15% O2 and 33.2 lb/hr, or ammonia - 10 ppmvd @ 15% O2. All emission limits are three hour rolling averages. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
19. Except during startup and shutdown, emission rates from gas turbine engine C-3811-1 shall not exceed any of the following limits: PM10 - 1.62 lb/hr, SOx (as SO2) - 0.71 lb/hr, NOx (as NO2) - 3.4 ppmvd @ 15% O2 and 3.08 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O2 and 0.64 lb/hr, CO - 30 ppmvd @ 15% O2 and 16.6 lb/hr, or ammonia - 10 ppmvd @ 15% O2. All emission limits are three hour rolling averages. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
20. The NOx emission from gas turbine engine at all times during operating hours shall not exceed 112 ppmvd NOx @ 15% O2 over a 4-hour rolling average, including start-up and shutdown periods. The 4-hour rolling average is the arithmetic average of the average NOx concentration measured by the CEMS for a given hour (corrected to 15 percent O2) and the three unit operating hour average NOx concentrations immediately preceding that unit operating hour. [40 CFR 60.332(a)(1) and 60.334(j)(1)(iii)(A)] Federally Enforceable Through Title V Permit
21. An hour of excess emissions shall be defined as any operating hour in which 4-hour rolling average NOx concentration exceeds applicable emissions limit in §60.332(a)(1), and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOx, CO or O2. [40 CFR 64 and 40 CFR 60.334(j)(1)(iii)] Federally Enforceable Through Title V Permit
22. Daily emissions from gas turbine engine C-3811-1 shall not exceed any of the following emission limits, regardless of type of operation: 74.0 lb NOx/day, 17.0 lb SOx/day, 38.9 lb PM10/day, 385.2 lb CO/day, and 15.4 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Combined emission from units C-3811-1 and C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 148.0 lb NO_x/day, 34.0 lb SO_x/day, 77.8 lb PM₁₀/day, 770.0 lb CO/day, and 30.8 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
24. NO_x emissions from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed 20,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Compliance with the ammonia emission limits shall be demonstrated utilizing one of the following procedures: 1) Calculate ammonia slip utilizing the following equation: ammonia slip ppmvd @ 15% O₂ = $\left[\frac{a - (b \times c / 1,000,000)}{1,000,000/b} \right] \times \left[\frac{(20.9 - 15.0)}{(20.9 - e)} \right] \times d$, where a = ammonia injection rate (lb/hr) / (17 lb/lb mol), b = dry exhaust flow rate (lb/hr) / (29 lb/lb mol), c = change in measured NO_x concentration across the catalyst, d = correction factor, and e = stack O₂ concentration (%vd). The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip; 2.) Utilize another District-approved calculation method using measured surrogate parameters to determine the daily ammonia emissions in ppmvd @ 15% O₂. If this option is chosen, the permittee shall submit a detailed calculation protocol for District approval at least 60 days prior to commencement of operation; 3.) Alternatively, the permittee may utilize a continuous in-stack ammonia monitor to verify compliance with the ammonia emissions limit. If this option is chosen, the permittee shall submit a monitoring plan for District approval at least 60 days prior to commencement of operation. [District Rule 4102]
26. Compliance testing to demonstrate compliance with the PM₁₀, NO_x (as NO₂), VOC, CO, and ammonia emission limits, and fuel gas sulfur content shall be conducted at least once every twelve months. Compliance testing may be demonstrated when both C-3811-1 and C-3811-2 are operating. NO_x emission concentration at the SCR inlet shall be determined for 50%, 75%, 90%, and 100% loads during annual compliance testing by measuring NO_x emissions at each load for a minimum of 5 minutes or until NO_x concentration has stabilized. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
27. Compliance demonstration (source testing) shall be District witnessed, or authorized and samples shall be collected by a California Air Resources Board certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The following test methods shall be used PM₁₀: EPA method 5 (front half and back half), NO_x: EPA Method 7E or 20, CO: EPA method 10 or 10B, O₂: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.8(a), 40 CFR 60.335(a) & (c), District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
29. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
30. In lieu of the cylinder gas audit requirements of Appendix F to Part 60, quarterly audits of continuous emission monitors shall be conducted per the procedures and frequencies specified in Appendix B to Part 75, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified 48-hours prior to conducting the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rules 1080 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

31. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit
32. The owner or operator shall submit reports of NOx excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c) on a semi annual basis. Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction, for any 4-consecutive rolling average that exceeds the NOx limit under 40 CFR 60.332(a)(1). For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined in 40 CFR 60.334(j). All reports required under 40 CFR 60.7(c) shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.334(j); 40 CFR 60.334 (j)(5); District Rule 4703] Federally Enforceable Through Title V Permit
33. If the total duration of NOx excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CEMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form in §60.7(d) shall be submitted and the excess emission report described in §60.7(c) need not be submitted unless requested by the EPA or the Air District. [40 CFR. 60.334(j), 40 CFR 60.7(c) and (d)] Federally Enforceable Through Title V Permit
34. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b), District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
35. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, calculated ammonia slip, and calculated NOx mass emission rates (lb/hr and lb/twelve month rolling period). [40 CFR 60.334(c), District Rules 2201, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
36. The permittee shall maintain a daily stationary gas turbine system operating log that includes the actual local startup and stop time, length and reason for reduced load periods, total hours of operation and the type and quantity of fuel used. [District Rule 4703] Federally Enforceable Through Title V Permit
37. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
38. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit
39. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a), Fresno County Rules 406, and District Rule 4801] Federally Enforceable Through Title V Permit
40. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
41. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b) and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

42. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703] Federally Enforceable Through Title V Permit
43. All records shall be maintained, retained on-site for a minimum of five years and shall be made available for District inspection upon request. [District Rule 4703] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3811-2-9

EXPIRATION DATE: 05/31/2023

EQUIPMENT DESCRIPTION:

24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #2 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-1)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Selective catalytic reduction (SCR) system and oxidation catalyst shall serve the common exhaust duct from C-3811-1 and C-3811-2. Common exhaust ducting shall be equipped with a fresh air inlet and blower to be used to lower the exhaust temperature prior to inlet of the SCR system catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be equipped with a continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rules 2201 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. The owner or operator shall certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NO_x, CO and O₂ concentrations. [40 CFR 60.334(c), District Rules 1080 and 4703, and 40 CFR 64] Federally Enforceable Through Title V Permit
7. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and 40 CFR 60.334(c), and District Rule 1080] Federally Enforceable Through Title V Permit
8. The NO_x, CO and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specification 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and 40 CFR 60.334(c), District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
11. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and provisions to sample stack gases at ground level with a portable NO_x, CO, and O₂ analyzer. [District Rule 1081] Federally Enforceable Through Title V Permit
12. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and Fresno County Rule 406] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
14. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
15. Number of startups and shutdowns shall not exceed 365 in one calendar year. [District Rules 2201] Federally Enforceable Through Title V Permit
16. Each startup or shutdown shall not exceed 30 minutes. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
17. Combined emission rates from units C-3811-1 and C-3811-2 during startup or shutdown shall not exceed : 8.28 lb NO_x/hr, 1.42 lb SO_x/hr, 3.42 lb PM₁₀/hr, 35.46 lb CO/hr, and 1.28 lb VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Except during startup and shutdown, emission rates from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed any of the following limits: PM₁₀ - 3.24 lb/hr, SO_x (as SO₂) - 1.42 lb/hr, NO_x (as NO₂) - 3.4 ppmvd @ 15% O₂ and 6.16 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O₂ and 1.28 lb/hr, CO - 30 ppmvd @ 15% O₂ and 33.2 lb/hr, or ammonia - 10 ppmvd @ 15% O₂. All emission limits are three hour rolling averages. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
19. Except during startup and shutdown, emission rates from gas turbine engine C-3811-2 shall not exceed any of the following limits: PM₁₀ - 1.62 lb/hr, SO_x (as SO₂) - 0.71 lb/hr, NO_x (as NO₂) - 3.4 ppmvd @ 15% O₂ and 3.08 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O₂ and 0.64 lb/hr, CO - 30 ppmvd @ 15% O₂ and 16.6 lb/hr, or ammonia - 10 ppmvd @ 15% O₂. All emission limits are three hour rolling averages. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
20. The NO_x emission from gas turbine engine at all times during operating hours shall not exceed 112 ppmvd NO_x @ 15% O₂ over a 4-hour rolling average, including start-up and shutdown periods. The 4-hour rolling average is the arithmetic average of the average NO_x concentration measured by the CEMS for a given hour (corrected to 15 percent O₂) and the three unit operating hour average NO_x concentrations immediately preceding that unit operating hour. [40 CFR 60.332(a)(1) and 60.334(j)(1)(iii)(A)] Federally Enforceable Through Title V Permit
21. An hour of excess emissions shall be defined as any operating hour in which 4-hour rolling average NO_x concentration exceeds applicable emissions limit in §60.332(a)(1), and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO_x, CO or O₂. [40 CFR 64 and 40 CFR 60.334(j)(1)(iii)] Federally Enforceable Through Title V Permit
22. Daily emissions from gas turbine engine C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 74.0 lb NO_x/day, 17.0 lb SO_x/day, 38.9 lb PM₁₀/day, 385.2 lb CO/day, and 15.4 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Combined emission from units C-3811-1 and C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 148.0 lb NO_x/day, 34.0 lb SO_x/day, 77.8 lb PM₁₀/day, 770.0 lb CO/day, and 30.8 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
24. NO_x emissions from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed 20,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Compliance with the ammonia emission limits shall be demonstrated utilizing one of the following procedures: 1) Calculate ammonia slip utilizing the following equation: ammonia slip ppmvd @ 15% O₂ = $\left[\left\{ a - \left(b \times c / 1,000,000 \right) \right\} \times \left(1,000,000 / b \right) \right] \times \left[(20.9 - 15.0) / (20.9 - e) \right] \times d$, where a = ammonia injection rate (lb/hr) / (17 lb/lb mol), b = dry exhaust flow rate (lb/hr) / (29 lb/lb mol), c = change in measured NO_x concentration across the catalyst, d = correction factor, and e = stack O₂ concentration (%vd). The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip; 2.) Utilize another District-approved calculation method using measured surrogate parameters to determine the daily ammonia emissions in ppmvd @ 15% O₂. If this option is chosen, the permittee shall submit a detailed calculation protocol for District approval at least 60 days prior to commencement of operation; 3.) Alternatively, the permittee may utilize a continuous in-stack ammonia monitor to verify compliance with the ammonia emissions limit. If this option is chosen, the permittee shall submit a monitoring plan for District approval at least 60 days prior to commencement of operation. [District Rule 4102]
26. Compliance testing to demonstrate compliance with the PM₁₀, NO_x (as NO₂), VOC, CO, and ammonia emission limits, and fuel gas sulfur content shall be conducted at least once every twelve months. Compliance testing may be demonstrated when both C-3811-1 and C-3811-2 are operating. NO_x emission concentration at the SCR inlet shall be determined for 50%, 75%, 90%, and 100% loads during annual compliance testing by measuring NO_x emissions at each load for a minimum of 5 minutes or until NO_x concentration has stabilized. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
27. Compliance demonstration (source testing) shall be District witnessed, or authorized and samples shall be collected by a California Air Resources Board certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The following test methods shall be used PM₁₀: EPA method 5 (front half and back half), NO_x: EPA Method 7E or 20, CO: EPA method 10 or 10B, O₂: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.8(a), 40 CFR 60.335(a) & (c), District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
29. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
30. In lieu of the cylinder gas audit requirements of Appendix F to Part 60, quarterly audits of continuous emission monitors shall be conducted per the procedures and frequencies specified in Appendix B to Part 75, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified 48-hours prior to conducting the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rules 1080 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

31. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit
32. The owner or operator shall submit reports of NOx excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c) on a semi annual basis. Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction, for any 4-consecutive rolling average that exceeds the NOx limit under 40 CFR 60.332(a)(1). For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined in 40 CFR 60.334(j). All reports required under 40 CFR 60.7(c) shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.334(j); 40 CFR 60.334 (j)(5); District Rule 4703] Federally Enforceable Through Title V Permit
33. If the total duration of NOx excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CEMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form in §60.7(d) shall be submitted and the excess emission report described in §60.7(c) need not be submitted unless requested by the EPA or the Air District. [40 CFR. 60.334(j), 40 CFR 60.7(c) and (d)] Federally Enforceable Through Title V Permit
34. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b), District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
35. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, calculated ammonia slip, and calculated NOx mass emission rates (lb/hr and lb/twelve month rolling period). [40 CFR 60.334(c), District Rules 2201, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
36. The permittee shall maintain a daily stationary gas turbine system operating log that includes the actual local startup and stop time, length and reason for reduced load periods, total hours of operation and the type and quantity of fuel used. [District Rule 4703] Federally Enforceable Through Title V Permit
37. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
38. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit
39. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a), Fresno County Rules 406, and District Rule 4801] Federally Enforceable Through Title V Permit
40. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
41. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b) and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.