

**AVISO DE UNA DECISIÓN PRELIMINAR
PARA LA EMISIÓN DE UNA AUTORIDAD PARA CONSTRUIR Y
LA PROPUESTA MODIFICACIÓN SIGNIFICATIVA DE UN PERMISO
MANDATORIO FEDERAL PARA OPERAR**

POR EL PRESENTE SE NOTIFICA que el Distrito Unificado para el Control de la Contaminación del Aire del Valle de San Joaquín está solicitando comentarios públicos en la propuesta modificación significativa de Fresno-Clovis Regional Wastewater Reclamation Facility en 5607 W Jensen Ave, Fresno, California. La modificación consiste de la instalación de una motor de combustión interna de diésel de 247 caballos de fuerza que es certificado Nivel 3 para apoderar un generador eléctrico durante apagones eléctricos

El análisis de los fundamentos jurídicos y fácticos de esta acción propuesta, Número del Proyecto # C-1193231, está disponible para la inspección del público en http://www.valleyair.org/notices/public_notices_idx.htm y en cualquiera de las oficinas del Distrito. El aumento de emisiones asociadas con este proyecto son de: 71 libras de NOx por año, 0 libras de SOx por año, 3 libras de PM10 por año, 3 libras de PM2.5 por año, 20 libras de CO por año y 4 libras de VOC por año. Esta será la única oportunidad para que el público haga comentarios en las condiciones especificadas de esta modificación. Si se solicita, el Distrito llevará a cabo una audiencia pública acerca de la emisión de esta modificación. Para más información en Español, por favor comuníquese con el Distrito al (559) 230-6000. Comentarios por escrito acerca de este proyecto deben ser sometidos o con matasellos antes del 9 de Marzo del 2020 a publicnotices@valleyair.org o a **ARNAUD MARJOLLET, DIRECTOR DEL DEPARTAMENTO DE PERMISOS, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**NOTICE OF PRELIMINARY DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
THE PROPOSED SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed significant modification of Fresno-Clovis Regional Wastewater Reclamation Facility at 5607 W Jensen Ave, Fresno, California. The modification consists of the installation of a 247 horsepower Tier 3 certified diesel engine to provide emergency power in the event of an electrical outage.

The District's analysis of the legal and factual basis for this proposed action, project # C-1193231, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and at any District office. The emission increases associated with this project are: 71 lb-NOx/year, 0 lb-SOx/year, 3 lb-PM10/year, 3 lb-PM2.5/year, 20 lb-CO/year and 4 lb-VOC/year. This will be the public's only opportunity to comment on the specific conditions of the modification. If requested, the District will hold a public hearing regarding issuance of this modification. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be sent or postmarked by March 9, 2020 to publicnotices@valleyair.org or **ARNAUD MARJOLLET, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**