

September 15, 2020

Ms. Kristine Boyer
Chalk Cliff Limited
34759 Lencioni Ave
Bakersfield, CA 93308

Re: Notice of Preliminary Decision – Title V Permit Renewal
Facility Number: S-723
Project Number: S-1183838

Dear Ms. Boyer:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Chalk Cliff Limited at 29041 Highway 33 in Maricopa, California.

The notice of preliminary decision for this project has been posted on the District's website (www.valleyair.org). After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via EPS

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT**

**Title V Permit Renewal Evaluation
Chalk Cliff Limited
S-723**

TABLE OF CONTENTS

I. PROPOSAL.....	2
II. FACILITY LOCATION	2
III. EQUIPMENT LISTING	2
IV. GENERAL PERMIT TEMPLATE USAGE	3
V. SCOPE OF EPA AND PUBLIC REVIEW	3
VI. FEDERALLY ENFORCEABLE REQUIREMENTS	3
VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE.....	6
VIII. PERMIT REQUIREMENTS	6
IX. PERMIT SHIELD	9
X. PERMIT CONDITIONS	9
XI. ATTACHMENTS.....	9
A. RENEWED TITLE V OPERATING PERMIT	
B. PREVIOUS TITLE V OPERATING PERMIT	
C. DETAILED FACILITY LIST	

TITLE V PERMIT RENEWAL EVALUATION

Cogeneration

Engineer: Robert Rinaldi
Date:

Facility Number: S-723
Facility Name: Chalk Cliff Limited
Mailing Address: 34759 Lencioni Ave
Bakersfield, CA 93308

Contact Name: Kristine Boyer
Phone: (661) 387-7828

Responsible Official: Mr. Ed Capehart
Title: Plant Manager

Project # : 1183838
Deemed Complete: 5/20/19

I. PROPOSAL

Chalk Cliff Limited was issued a Title V permit on December 31, 2002. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the last renewed Title V permit on 8/31/2015. This review will span from 8/31/2015 to the present.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

Chalk Cliff Limited is located at 29041 Highway 33 in Maricopa, CA.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant does not propose to use any model general permit templates.

V. SCOPE OF EPA AND PUBLIC REVIEW

The applicant is not requesting any model general permit templates. Therefore, all federally enforceable conditions in this current Title V permit will be subject to EPA and public review.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated during this current renewal review interval (8/31/2015 to present)

- District Rule 2201, New and Modified Stationary Source Review Rule (amended May 21, 2011 ⇒ amended August 15, 2019)
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001 ⇒ amended August 15, 2019)
- 40 CFR Part 63 Subpart YYYY—National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (amended March 5, 2004 ⇒ March 9, 2020)
- 40 CFR Part 68, Chemical Accident Prevention Provisions (amended April 9, 2004 ⇒ 12/19/2019)
- 40 CFR Part 82, Subpart B, Stratospheric Ozone (amended April 25, 2015 ⇒ amended August 23, 2019)

B. Rules Removed during this current renewal review interval (8/31/15 to present)

- None.

C. Rules Added during this current renewal review interval (8/31/15 to present)

- None.

D. Rules Not Updated during this current renewal review interval (8/31/15 to present)

- District Rule 1070, Inspections (amended December 17,1992)
- District Rule 1080, Stack Monitoring (amended December 17,1992)
- District Rule 1081, Source Sampling (amended December 16,1993)
- District Rule 1100, Equipment Breakdown (amended December 17,1992)
- District Rule 1160, Emission Statements (adopted November 18, 1992)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2020, Exemptions (amended December 18, 2014)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2040, Applications (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 2410, Prevention of Significant Deterioration (became effective on November 26, 2012)
- District Rule 4101, Visible Emissions (amended February 17, 2005)
- District Rule 4102, Nuisance (amended December 17, 1992)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4202, Particulate Matter - Emission Rate (amended December 17, 1992)

- District Rule 4301, Fuel Burning Equipment (amended December 17, 1992)
- District Rule 4601, Architectural Coatings (amended December 17, 2009)
- District Rule 4701, Internal Combustion Engines – Phase I (amended August 21, 2003)
- District Rule 4702, Internal Combustion Engines – Phase 2 (amended November 14, 2013)
- District Rule 4703, Stationary Gas Turbines (amended September 20, 2007)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- District Rule 8011 - General Requirements (amended August 19, 2004)
- District Rule 8021 - Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities (amended August 19, 2004)
- District Rule 8031 - Bulk Materials (amended August 19, 2004)
- District Rule 8041 - Carryout and Trackout (amended August 19, 2004)
- District Rule 8051 - Open Areas (amended August 19, 2004)
- District Rule 8061 - Paved and Unpaved Roads (amended August 19, 2004)
- District Rule 8071 - Unpaved Vehicle/Equipment Traffic Area (amended September 16, 2004)
- 40 CFR Part 60, Subpart GG, New Source Performance Standards: Standard of Performance for Stationary Gas Turbines (amended August 29, 2012)
- 40 CFR Part 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines (amended August 29, 2012)
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos (amended July 20, 2004)
- 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (amended August 15, 2014)

- 40 CFR Part 64, Compliance Assurance Monitoring (CAM) (amended October 22, 1997)
- 40 CFR Part 82, Subpart F, Stratospheric Ozone (amended April 25, 2015)

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

A. Rules Added

There are no new rules that are not federally enforceable being added at this time.

B. Rules Not Updated

- District Rule 4102, Nuisance (as amended December 17, 1992)

For this facility, condition #42 of the facility wide requirements S-723-0-4 is based on District Rule 4102 listed above and is not Federally Enforceable through Title V.

- Title 17, California Code of Regulations, Section 92000 through 92540

No changes were made to these rules since the renewed Title V permit was issued, therefore, they will not be discussed any further.

VIII. FEDERALLY ENFORCABLE PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the of the last renewed Title V permit which was on 8/31/2015.

A. District Rule 2201 - New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.
- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

B. District Rule 2520 – Federally Mandated Operating Permits

Greenhouse Gas Requirements

There are no federally applicable Greenhouse Gas (GHG) requirements for this source. It should be noted that the Mandatory Greenhouse Gas Reporting rule (40CFR Part 98) is not included in the definition of an applicable requirement within Title V (per 40CFR 71.2). Therefore, there will be no further discussion of GHG in this evaluation.

C. 40 CFR Part 63 Subpart YYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines

This subpart establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emissions from stationary combustion turbines located at major sources of HAP emissions, and requirements to demonstrate initial and continuous compliance with the emission and operating limitations. The facility is not a major or area source of HAP emissions and is not subject to this subpart.

D. 40 CFR Part 68, Chemical Accident Prevention Provisions

For the stationary sources that could be subject to the risk management plan requirements, or the owner or operator wants flexibility to preclude a permit reopening if the source becomes subject to section 112(r)(3) of the Clean Air Act, the following condition will be placed on the draft renewed permit (S-723-0-4) as a mechanism to ensure compliance with the requirements of this subpart:

43. Should the facility, as defined in 40 CFR 68.3, become subject to part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 CFR 68.10. The facility shall certify compliance as part of the annual certification as required by 40 CFR Part 70. [40 CFR Part 68, Subpart G] Y

E. 40 CFR Part 82, Subparts B, Stratospheric Ozone

These regulations apply to servicing motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC). 40 CFR 82, Subpart B was amended since the previous renewed TV permit was issued. However, the amendments to this subpart do not have any effect on existing permit requirements. Condition 28 of S-723-0-4 assure compliance with the requirements.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

The applicant is not requesting to use any model general permit templates for this Title V renewal project.

B. Requirements not Addressed by Model General Permit Templates

Chalk Cliff Limited is not requesting any new permit shields within this Title V renewal project. In addition, Chalk Cliff Limited is not requesting any changes to the existing permit shields already included in their Title V operating permits. Therefore, all of the existing permit shields will be maintained on the revised permits for this renewal project.

C. Obsolete Permit Shields From Existing Permit Requirements

There are no obsolete permit shield conditions to be removed from the permits.

X. PERMIT CONDITIONS

See Attachment A - Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List

ATTACHMENT A

Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-723-0-4

EXPIRATION DATE: 12/31/2019

FACILITY-WIDE REQUIREMENTS

1. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0] Federally Enforceable Through Title V Permit
3. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CHALK CLIFF LIMITED

Location: HEAVY OIL WESTERN, 29041 HIGHWAY 33, MARICOPA, CA 93252

S-723-0-4 : Sep 14 2020 12:07PM -- RINALDIR

10. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation) [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. {4400} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. On December 31, 2002, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. Should the facility, as defined in 40 CFR 68.3, become subject to part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 CFR 68.10. The facility shall certify compliance as part of the annual certification as required by 40 CFR Part 70. [40 CFR Part 68, Subpart G] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-723-1-11

EXPIRATION DATE: 12/31/2019

SECTION: 31 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:

49 MW G.T.E. COGENERATION UNIT WITH STEAM INJECTION AND SELECTIVE CATALYTIC REDUCTION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Gas-fired turbine engine shall be equipped with a selective catalyst reduction (SCR) NOx control system utilizing ammonia as reducing agent. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Unfired heat recovery steam generator shall not be designed for supplementary firing. [District Rule 2010] Federally Enforceable Through Title V Permit
3. Gas-fired turbine engine shall be equipped with continuously recording emission monitors for NOx, CO, and O2 which conform to District Rule 1080 (as amended December 17, 1992) specifications. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Adequate provisions shall be made for testing exhaust stack for air contaminants, i.e., capped sampling ports in accessible location of uniform flow. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be fired exclusively on PUC regulated quality natural gas. [District Rules 2201, 4201, and 40 CFR 60.333] Federally Enforceable Through Title V Permit
6. Gas turbine engine steam injection rate shall be maintained at a steam to fuel ratio expected to result in compliance with emission limits, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
8. Gas turbine engine shall not be operated unless steam injection and SCR system are operating, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Inlet gas temperature to catalyst bed shall be maintained within the range recommended by catalyst manufacturer except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Gas turbine engine shall not burn more than 10.04 MM scf/day of natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
11. All gas turbine engine exhaust shall flow through SCR catalyst bed. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Gas turbine lube oil tank atmospheric vent shall be equipped with mist eliminator. If visible vent emissions exceed 0% opacity, Chalk Cliff Ltd. shall perform testing to demonstrate compliance with lube oil vent VOC emissions limit. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. Failure of catalyst to perform as required because of catalyst poisoning or fouling, except as the result of an unforeseeable breakdown, shall not be recognized as basis for Rule 1100 enforcement exemption. [District Rule 1100] Federally Enforceable Through Title V Permit
14. Chalk Cliff Limited shall comply in full with applicable Rule 4001 (New Source Performance Standards) requirements including notification, record keeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
15. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR Title 40, Part 60, Appendix B. [District Rule 1080] Federally Enforceable Through Title V Permit
16. Audits of continuous emissions monitors shall be conducted quarterly by independent laboratory in accordance with EPA guidelines, witnessed by District, and reports shall be submitted to the District within 30 days of such audit. [District Rule 1080 and 40 CFR 60, Appendix F, Section 5.1] Federally Enforceable Through Title V Permit
17. Chalk Cliff Limited shall make continuous emissions monitoring printouts readily available for District inspection upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
18. Chalk Cliff Limited shall maintain accurate records of gas turbine engine daily fuel consumption and shall make such records readily available for District inspection for a period of 5 years. [District Rule 1080 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
19. Maximum PM10 emission rate shall not exceed 140.64 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Maximum sulfur compound emissions rate (as SO₂) shall not exceed 6.72 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Maximum emission concentration of nitrogen oxides (as NO₂) shall not exceed 5 ppmv dry calculated to 15% O₂ averaged over a three hour period, except during periods of startup and shutdown. [District Rule 2201 and Rule 4703, 5.1] Federally Enforceable Through Title V Permit
22. Nitrogen oxide emissions (as NO₂) shall not exceed 190.80 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Maximum VOC emissions rate shall not exceed 5.23 lbs/hr except during periods of startup and shutdown, and shall not exceed 126.44 lbs/day. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Maximum VOC emissions rate from turbine lube oil cooler atmospheric vents shall not exceed 19 pounds per day. Compliance will be assured by visible emissions checks. [District Rule 2201 and Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. Maximum carbon monoxide emission concentration shall not exceed 55 ppmv dry calculated to 15% O₂ averaged over a three hour period, except during periods of startup or shutdown. [District Rule 2201 and Rule 4703, 5.1] Federally Enforceable Through Title V Permit
26. Carbon monoxide emissions shall not exceed 1278.24 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Compliance with NO_x (ppmv), CO (ppmv), turbine exhaust VOC (hourly), and ammonia (ppmv) emissions limits and turbine lube oil cooler atmospheric vent opacity shall be demonstrated by District witnessed sample collection and observation by independent testing laboratory annually. [District Rule 1081] Federally Enforceable Through Title V Permit
28. Official test results and field data collected during source testing shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
29. A written record of startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District Rule 2201 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of three hours and one hour, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
31. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) which continuously measures and records the exhaust gas NO_x and O₂ concentrations. [40 CFR 60.334(b) and District Rule 4703, 6.2.1] Federally Enforceable Through Title V Permit
32. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
33. The NO_x and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specifications 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and, District Rule 1080, 6.3, 6.5, 6.6, & 7.2] Federally Enforceable Through Title V Permit
34. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
35. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
36. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
37. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NO_x concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO_x or O₂ (or both). [40 CFR 60.334(J)(1)(iii)] Federally Enforceable Through Title V Permit
38. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
39. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b), District Rule 4201] Federally Enforceable Through Title V Permit
40. The owner or operator shall not operate the gas turbine under load conditions, excluding the thermal stabilization period or reduced load period, which results in the measured NO_x emissions concentration exceeding 5 ppmv @ 15% O₂. [40 CFR 60.332(a)(1), (a)(2) and District Rule 4703, 5.1.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall not operate the gas turbine under load conditions, excluding the thermal stabilization period or reduced load period, which results in the measured CO emissions concentration exceeding 200 ppmv @ 15% O₂. [District Rule 4703, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

42. The duration of each startup or shutdown shall not exceed two hours. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
43. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.26, 3.29, and 5.3] Federally Enforceable Through Title V Permit
44. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
45. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
46. The NO_x monitoring system shall meet EPA requirements as specified in 40 CFR Part 60 App. B, Spec. 2, 40 CFR Part 60 App. F, and 40 CFR Part 60.7 c, 60.7 (d) and 60.13. [District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
47. Source testing to determine compliance with the NO_x and CO rates (ppmvd @ 15% O₂) shall be conducted once every 12 months. [District Rules 2201 and 4703, 6.3.1, and CFR 60.335(a)] Federally Enforceable Through Title V Permit
48. Unit shall demonstrate compliance annually with NO_x and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [District Rule 4703, 6.3.1, 6.3.3, and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit
49. HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM D1826, or ASTM D1945. [District Rule 4703, 6.4.5, and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit
50. The following test methods shall be used: NO_x - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM₁₀ - EPA Method 5 (front half and back half) or 201 and 202a. NO_x test results shall be corrected to ISO standard conditions as defined in 40 CFR 60.335. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081 and 4703, 6.4, 40 CFR 60.335(a), and 40 CFR 60.335(b)(1)] Federally Enforceable Through Title V Permit
51. The owner or operator shall be required to conform to the sampling facilities and testing procedures described in District Rule 1081, 3.0, & 6.0 (as amended 12/16/93). [District Rule 1081, 3.0 & 6.0] Federally Enforceable Through Title V Permit
52. The District must be notified 30 days prior to any performance testing and a test plan shall be submitted for District approval 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
53. Performance testing shall be witnessed or authorized District personnel. Test results must be submitted to the District within 60 days of performance testing. [District Rule 1081] Federally Enforceable Through Title V Permit
54. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
56. Owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, type and quantity of fuel used. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit
57. The permittee shall maintain the following records: date and time, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, and maintenance of any continuous emission monitor. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit
58. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
59. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
60. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a)(1), (a)(2), 60.333 (b); 60.334(b) (b)(1), (b)(2), (h)(3), (j), (j)(1)(iii), and (j)(5), and 60.335(a), (b)(7), (b)(3), and District Rule 4703 (as amended 4/25/02), Sections 5.1.2.1, 5.2, 6.2.2, 6.2.6, 6.3, and 6.4. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
61. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.13, and District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 6.6, 7.1, 7.2, 7.3, 8.0, and 11.0; 1081(as amended 12/16/93), Sections 3.0, 6.0, 7.1, 7.2, and 7.3; and 4201 (as amended 12/17/92). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT B

Previous Title V Operating Permit

Permit to Operate

FACILITY: S-723

EXPIRATION DATE: 12/31/2019

LEGAL OWNER OR OPERATOR:

CHALK CLIFF LIMITED
34759 LENCIONI AVE STE A
BAKERSFIELD, CA 93308

MAILING ADDRESS:

FACILITY LOCATION:

HEAVY OIL WESTERN
29041 HIGHWAY 33
MARICOPA, CA 93252

FACILITY DESCRIPTION:

COGENERATION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley

Air Pollution Control District

FACILITY: S-723-0-3

EXPIRATION DATE: 12/31/2019

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CHALK CLIFF LIMITED

Location: HEAVY OIL WESTERN, 29041 HIGHWAY 33, MARICOPA, CA 93252

S-723-0-3 : Sep 14 2020 12:32PM -- RINALDIR

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. On December 31, 2002, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-723-1-10

EXPIRATION DATE: 12/31/2019

SECTION: 31 **TOWNSHIP:** 32S **RANGE:** 24E

EQUIPMENT DESCRIPTION:

49 MW G.T.E. COGENERATION UNIT WITH STEAM INJECTION AND SELECTIVE CATALYTIC REDUCTION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Gas-fired turbine engine shall be equipped with a selective catalyst reduction (SCR) NOx control system utilizing ammonia as reducing agent. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Unfired heat recovery steam generator shall not be designed for supplementary firing. [District Rule 2010] Federally Enforceable Through Title V Permit
3. Gas-fired turbine engine shall be equipped with continuously recording emission monitors for NOx, CO, and O2 which conform to District Rule 1080 (as amended December 17, 1992) specifications. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Adequate provisions shall be made for testing exhaust stack for air contaminants, i.e., capped sampling ports in accessible location of uniform flow. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be fired exclusively on PUC regulated quality natural gas. [District Rules 2201, 4201, and 40 CFR 60.333] Federally Enforceable Through Title V Permit
6. Gas turbine engine steam injection rate shall be maintained at a steam to fuel ratio expected to result in compliance with emission limits, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
8. Gas turbine engine shall not be operated unless steam injection and SCR system are operating, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Inlet gas temperature to catalyst bed shall be maintained within the range recommended by catalyst manufacturer except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Gas turbine engine shall not burn more than 10.04 MM scf/day of natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
11. All gas turbine engine exhaust shall flow through SCR catalyst bed. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Gas turbine lube oil tank atmospheric vent shall be equipped with mist eliminator. If visible vent emissions exceed 0% opacity, Chalk Cliff Ltd. shall perform testing to demonstrate compliance with lube oil vent VOC emissions limit. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. Failure of catalyst to perform as required because of catalyst poisoning or fouling, except as the result of an unforeseeable breakdown, shall not be recognized as basis for Rule 1100 enforcement exemption. [District Rule 1100] Federally Enforceable Through Title V Permit
14. Chalk Cliff Limited shall comply in full with applicable Rule 4001 (New Source Performance Standards) requirements including notification, record keeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
15. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR Title 40, Part 60, Appendix B. [District Rule 1080] Federally Enforceable Through Title V Permit
16. Audits of continuous emissions monitors shall be conducted quarterly by independent laboratory in accordance with EPA guidelines, witnessed by District, and reports shall be submitted to the District within 30 days of such audit. [District Rule 1080 and 40 CFR 60, Appendix F, Section 5.1] Federally Enforceable Through Title V Permit
17. Chalk Cliff Limited shall make continuous emissions monitoring printouts readily available for District inspection upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
18. Chalk Cliff Limited shall maintain accurate records of gas turbine engine daily fuel consumption and shall make such records readily available for District inspection for a period of 5 years. [District Rule 1080 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
19. Maximum PM10 emission rate shall not exceed 140.64 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Maximum sulfur compound emissions rate (as SO₂) shall not exceed 6.72 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Maximum emission concentration of nitrogen oxides (as NO₂) shall not exceed 5 ppmv dry calculated to 15% O₂ averaged over a three hour period, except during periods of startup and shutdown. [District Rule 2201 and Rule 4703, 5.1] Federally Enforceable Through Title V Permit
22. Nitrogen oxide emissions (as NO₂) shall not exceed 190.80 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Maximum VOC emissions rate shall not exceed 5.23 lbs/hr except during periods of startup and shutdown, and shall not exceed 126.44 lbs/day. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Maximum VOC emissions rate from turbine lube oil cooler atmospheric vents shall not exceed 19 pounds per day. Compliance will be assured by visible emissions checks. [District Rule 2201 and Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. Maximum carbon monoxide emission concentration shall not exceed 55 ppmv dry calculated to 15% O₂ averaged over a three hour period, except during periods of startup or shutdown. [District Rule 2201 and Rule 4703, 5.1] Federally Enforceable Through Title V Permit
26. Carbon monoxide emissions shall not exceed 1278.24 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Compliance with NO_x (ppmv), CO (ppmv), turbine exhaust VOC (hourly), and ammonia (ppmv) emissions limits and turbine lube oil cooler atmospheric vent opacity shall be demonstrated by District witnessed sample collection and observation by independent testing laboratory annually. [District Rule 1081] Federally Enforceable Through Title V Permit
28. Official test results and field data collected during source testing shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
29. A written record of startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District Rule 2201 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of three hours and one hour, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
31. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) which continuously measures and records the exhaust gas NO_x and O₂ concentrations. [40 CFR 60.334(b) and District Rule 4703, 6.2.1] Federally Enforceable Through Title V Permit
32. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
33. The NO_x and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specifications 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and, District Rule 1080, 6.3, 6.5, 6.6, & 7.2] Federally Enforceable Through Title V Permit
34. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
35. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
36. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
37. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NO_x concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO_x or O₂ (or both). [40 CFR 60.334(J)(1)(iii)] Federally Enforceable Through Title V Permit
38. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
39. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b), District Rule 4201, County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus County)] Federally Enforceable Through Title V Permit
40. The owner or operator shall not operate the gas turbine under load conditions, excluding the thermal stabilization period or reduced load period, which results in the measured NO_x emissions concentration exceeding 5 ppmv @ 15% O₂. [40 CFR 60.332(a)(1), (a)(2) and District Rule 4703, 5.1.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall not operate the gas turbine under load conditions, excluding the thermal stabilization period or reduced load period, which results in the measured CO emissions concentration exceeding 200 ppmv @ 15% O₂. [District Rule 4703, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

42. The duration of each startup or shutdown shall not exceed two hours. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
43. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.26, 3.29, and 5.3] Federally Enforceable Through Title V Permit
44. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
45. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
46. The NO_x monitoring system shall meet EPA requirements as specified in 40 CFR Part 60 App. B, Spec. 2, 40 CFR Part 60 App. F, and 40 CFR Part 60.7 c, 60.7 (d) and 60.13. [District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
47. Source testing to determine compliance with the NO_x and CO rates (ppmvd @ 15% O₂) shall be conducted once every 12 months. [District Rules 2201 and 4703, 6.3.1, and CFR 60.335(a)] Federally Enforceable Through Title V Permit
48. Unit shall demonstrate compliance annually with NO_x and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [District Rule 4703, 6.3.1, 6.3.3, and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit
49. HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM D1826, or ASTM D1945. [District Rule 4703, 6.4.5, and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit
50. The following test methods shall be used: NO_x - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM₁₀ - EPA Method 5 (front half and back half) or 201 and 202a. NO_x test results shall be corrected to ISO standard conditions as defined in 40 CFR 60.335. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081 and 4703, 6.4, 40 CFR 60.335(a), and 40 CFR 60.335(b)(1)] Federally Enforceable Through Title V Permit
51. The owner or operator shall be required to conform to the sampling facilities and testing procedures described in District Rule 1081, 3.0, & 6.0 (as amended 12/16/93). [District Rule 1081, 3.0 & 6.0] Federally Enforceable Through Title V Permit
52. The District must be notified 30 days prior to any performance testing and a test plan shall be submitted for District approval 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
53. Performance testing shall be witnessed or authorized District personnel. Test results must be submitted to the District within 60 days of performance testing. [District Rule 1081] Federally Enforceable Through Title V Permit
54. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
56. Owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, type and quantity of fuel used. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit
57. The permittee shall maintain the following records: date and time, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, and maintenance of any continuous emission monitor. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit
58. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
59. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
60. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a)(1), (a)(2), 60.333 (b); 60.334(b) (b)(1), (b)(2), (h)(3), (j), (j)(1)(iii), and (j)(5), and 60.335(a), (b)(7), (b)(3), and District Rule 4703 (as amended 4/25/02), Sections 5.1.2.1, 5.2, 6.2.2, 6.2.6, 6.3, and 6.4. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
61. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.13, and District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 6.6, 7.1, 7.2, 7.3, 8.0, and 11.0; 1081(as amended 12/16/93), Sections 3.0, 6.0, 7.1, 7.2, and 7.3; and 4201 (as amended 12/17/92). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

Detailed Facility Report

For Facility=723

Sorted by Facility Name and Permit Number

CHALK CLIFF LIMITED	FAC #	S 723	TYPE:	TitleV	EXPIRE ON:	12/31/2019
HEAVY OIL WESTERN	STATUS:	A	TOXIC ID:	50034	AREA:	83 /
29041 HIGHWAY 33	TELEPHONE:	8053936885			INSP. DATE:	03/21
MARICOPA, CA 93252						

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-723-1-10	49 MW	3020-08A G	1	12,254.00	12,254.00	A	49 MW G.T.E. COGENERATION UNIT WITH STEAM INJECTION AND SELECTIVE CATALYTIC REDUCTION SYSTEM

Number of Facilities Reported: 1