

February 17, 2021

Mr. Michael Tehada
Walnut Energy Center Authority
P.O. Box 949
Turlock, CA 95381

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: N-7172
Project Number: N-1191160

Dear Mr. Tehada:

The District has issued the Final Renewed Title V Permit for Walnut Energy Center Authority (see enclosure). The preliminary decision for this project was made on August 31, 2020.

The public notice for issuance of the Final Title V Permit will be posted on the District's website (www.valleyair.org).

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,



Brian Clements
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: Laura Yannayon, EPA (w/enclosure) via EPS

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

San Joaquin Valley

Air Pollution Control District

FACILITY: N-7172-0-3

EXPIRATION DATE: 09/30/2025

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: WALNUT ENERGY CENTER AUTHORITY
Location: 600 S WASHINGTON ROAD, TURLOCK, CA 95380
N-7172-0-3 : Dec 30 2020 4:48PM -- SRANK

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report beginning every November 1, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. Facilities N-2246 and N-7172 are included in the same stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley *Air Pollution Control District*

PERMIT UNIT: N-7172-1-5

EXPIRATION DATE: 09/30/2025

EQUIPMENT DESCRIPTION:

84 MW NOMINALLY RATED COMBINED-CYCLE POWER GENERATING SYSTEM #1 CONSISTING OF A 1,047 MMBTU/HR GENERAL ELECTRIC FRAME 7EA NATURAL GAS-FIRED COMBUSTION TURBINE GENERATOR WITH DRY LOW NOX COMBUSTOR, AN INLET AIR FILTRATION AND EVAPORATIVE COOLING SYSTEM, A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM, AN OXIDATION CATALYST, HEAT RECOVERY STEAM GENERATOR #1 (HRSG) AND A 100 MW NOMINALLY RATED STEAM TURBINE SHARED WITH PERMIT UNIT N-7172-2

PERMIT UNIT REQUIREMENTS

1. The gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in proper operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. The gas turbine engine shall be fired exclusively on natural gas with a sulfur content of no greater than 0.36 grain of sulfur compounds (as S) per 100 dry scf of natural gas. [District Rules 2201 and 4801 and 40 CFR Part 60.4330(a)(2), 40 CFR Part 60.4395 and 40 CFR Part 60.7)] Federally Enforceable Through Title V Permit
5. Testing to demonstrate compliance with the fuel sulfur content limit of this permit shall be conducted weekly. Once eight consecutive weekly tests show compliance, the fuel sulfur content testing frequency may be reduced to once every calendar quarter. If a quarterly test shows a violation of the sulfur content limit of this permit then weekly testing shall resume and continue until eight consecutive tests show compliance. Once compliance is shown on eight consecutive weekly tests then testing may return to quarterly. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The permittee shall monitor and record the fuel flow rate to the turbine, NO_x emission rate, the CO emission rate, the ammonia injection rate, the exhaust temperature both prior to and after the SCR unit, the exhaust oxygen content, and the exhaust flow rate. [District Rules 2201, 4001, and 4703] Federally Enforceable Through Title V Permit
7. The exhaust stack shall be equipped with a continuous emissions monitor (CEM) for NO_x, CO, and O₂. The CO CEM shall meet the requirements of 40 CFR parts 60 and the NO_x and O₂ CEMS shall be installed and certified in accordance with the requirements of 40 CFR Part 75. The CEMS shall be capable of monitoring emissions during startups and shutdowns as well as during normal operating conditions. Periods where the missing data substitution procedures in Part 75 Subpart D are applied shall be reported as monitor downtime in the District Quarterly CEMS Report. [District Rules 1080, 2201 and 4703 and 40 CFR Part 60.13(a), 40 CFR Part 60.4340(b), 40 CFR Part 60.4345(a) and 40 CFR Part 60.4350(d)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO_x, CO, and O₂ analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Source Emission Monitoring and Testing. [District Rule 1081] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
11. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour. [District Rule 1080, 40 CFR Part 60.13(e)(2), 40 CFR Part 60.13(h)(2), 40 CFR Part 60.4345(b) and 40 CFR Part 60.4350(a)] Federally Enforceable Through Title V Permit
12. Owners and operators of a CEMS installed in accordance with the provisions of 40 CFR Part 60 must check zero (or low level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span must at a minimum, be adjusted whenever either the 24-hour zero drift or the 24 -hour span drift exceed two times the limit of the applicable performance specification in Appendix B of 40 CFR Part 60. The system must allow the amount of excess zero and span drift to be recorded and quantified whenever specified. [40 CFR 60.13(d)(1)] Federally Enforceable Through Title V Permit
13. Owners and operators must develop and implement a Quality Control (QC) program. As a minimum, each QC program shall include written procedures that describe in detail, complete, step-by-step procedures and operations for calibration of CEMS, calibration drift determination and adjustment, CEMS preventative maintenance, data recording/calculations/reporting, accuracy audit procedures, and corrective action for malfunctioning CEMS. Whenever excessive inaccuracies occur for two consecutive quarters, the source owner or operator must revise the current written procedures or modify or replace the CEMS to correct the deficiency causing the excessive inaccuracies. These written procedures shall be kept on record and shall be made available for inspection by the enforcement agency. [40 CFR Part 60, Appendix F] Federally Enforceable Through Title V Permit
14. In accordance with 40 CFR, Part 60, Appendix F, 5.1, cylinder gas audits (CGA) or relative accuracy audits (RAA) of continuous emission monitors shall be conducted quarterly, except during quarters in which a relative accuracy test audit (RATA) is performed. Audit reports and an Out-of-Control Detail Report, pursuant to 40 CFR Part 60 Subpart F, shall be submitted along with quarterly compliance reports to the District. [District Rule 1080 and 40 CFR Part 60 Appendix F] Federally Enforceable Through Title V Permit
15. The owner/operator shall perform a relative accuracy test audit (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
16. In the event of a breakdown of monitoring equipment, the owner shall notify the District as soon as reasonably possible, but no later than 8 hours after its detection, unless the owner or operator demonstrates to the satisfaction of the APCO that a longer reporting period was necessary, and shall initiate repairs. The owner shall inform the District of the intent to shutdown any monitoring equipment at least 24 hours prior to the event. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. Startup is defined as the period beginning with turbine initial firing until the unit meets the ppmvd emission limits for steady state operation. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown events shall not exceed 296 hours per calendar year. Startup emissions must be counted toward each applicable emission limit (lb/day and lb/yr). [District Rule 2201] Federally Enforceable Through Title V Permit
18. The combined startup and shutdown period duration shall not exceed five hours in any one day, commencing at midnight. Emissions during startup and shutdown periods must be counted toward the applicable daily emission limitations. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
19. The unit shall comply with the New Source Review based NO_x and CO limits of this permit within 5 hours after initial start-up. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
20. The NO_x emissions during start-up and shutdown periods shall not exceed 119.0 lb/hour. [District Rule 2201] Federally Enforceable Through Title V Permit
21. The NO_x emissions during steady state operation shall not exceed 2.0 ppmvd @ 15% O₂ over a 1 hour average (clock hour basis). Steady-state period refers to any periods that is not a start-up or shut down period. A clock hour in a one hour average will commence at the top of the hour. [District Rules 2201 and 4703, 40 CFR Part 60.4320(a) and 40 CFR Part 60.4380(b)(1)] Federally Enforceable Through Title V Permit
22. The combined total NO_x emissions from start-up, shut down, and steady state operation shall not exceed 444.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Compliance with NO_x emission limitations during steady state operation shall not be required during short-term excursions limited to a cumulative total of 10 hours per rolling 12-month period. Short-term excursions are defined as 15 minute periods designated by the owner/operator (and approved by the APCO) that are the direct result of transient load conditions, not to exceed four consecutive 15-minute periods, when the 15-minute average NO_x concentration exceeds 2.0 ppmvd @ 15% O₂. The maximum 1-hour average NO_x concentration for periods that include short-term excursions shall not exceed 30 ppmvd @ 15% O₂. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Examples of transient load conditions include, but are not limited to the following: (1) Initiation/shutdown of combustion turbine inlet air cooling and (2) Rapid combustion turbine load changes. All emissions during short-term excursions shall accrue towards the hourly, daily, and annual emissions limitations of this permit and shall be included in all calculations of hourly, daily, and annual mass emission rates as required by this permit. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
25. The CO emissions during start-up and shutdown periods shall not exceed 129.0 lb/hour. [District Rule 2201] Federally Enforceable Through Title V Permit
26. The CO emissions during steady state operation shall not exceed 4.0 ppmvd @ 15% O₂ over a 3 hour rolling average. Steady-state period refers to any periods that is not a start-up or shut down period. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
27. The combined total CO emissions from start-up, shut down, and steady state operation shall not exceed 558.8 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The VOC emissions during start-up and shutdown periods shall not exceed 16.0 lb/hour. [District Rule 2201] Federally Enforceable Through Title V Permit
29. The VOC emissions during steady state operation shall not exceed 1.4 ppmvd @ 15% O₂ over a 3 hour rolling average. Steady-state period refers to any periods that is not a start-up or shut down period. [District Rule 2201] Federally Enforceable Through Title V Permit
30. The combined total VOC emissions from start-up, shut down, and steady state operation shall not exceed 83.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
31. The PM₁₀ emissions rate shall not exceed 7.0 lb/hour and 168.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. The SO_x emission rate shall not exceed 1.05 lb/hour and 25.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Ammonia (NH₃) emissions shall not exceed 10 ppmvd @ 15% O₂ over a 24 hour rolling average. [District Rule 2201] Federally Enforceable Through Title V Permit
34. Compliance with ammonia emission limit shall be demonstrated utilizing one of the following procedures: 1) calculate the daily ammonia emissions using the following equation: $(\text{ppmvd @ 15\% O}_2) = ((a - (b \times c / 1,000,000)) \times (1,000,000 / b)) \times d$, where a = ammonia injection rate (lb/hr) / (17 lb/lb mol), b = dry exhaust flow rate (lb/hr) / (29 lb/lb mol), c = change in measured NO_x concentration ppmvd @ 15% O₂ across the catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip; 2.) utilize another District-approved calculation method using measured surrogate parameters to determine the daily ammonia emissions in ppmvd @ 15% O₂. If this option is chosen, the permittee shall submit a detailed calculation protocol for District approval at least 60 days prior to commencement of operation; 3.) Alternatively, the permittee may utilize a continuous in-stack ammonia monitor to verify compliance with the ammonia emissions limit. If this option is chosen, the permittee shall submit a monitoring plan for District approval at least 60 days prior to commencement of operation. [District Rule 4102]
35. The annual emissions from this unit shall not exceed 99,991 lb/year for CO and 17,404 lb/year for VOC. [District Rule 2201] Federally Enforceable Through Title V Permit
36. The combined quarterly NO_x emissions from permit units N-7172-1 and N-7172-2 shall not exceed 35,000 lb/quarter. [District Rule 2201] Federally Enforceable Through Title V Permit
37. The combined annual NO_x emissions from permit units N-7172-1 and N-7172-2 shall not exceed 140,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
38. The combined quarterly CO emissions from permit units N-7172-1 and N-7172-2 shall not exceed 49,996 lb/quarter. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The combined annual CO emissions from permit units N-7172-1 and N-7172-2 shall not exceed 199,982 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Each one hour period shall commence on the hour. Each one hour period in a three hour rolling average will commence on the hour. The three hour average will be compiled from the three most recent one hour periods. Each one hour period in a twenty-four hour average for ammonia slip will commence on the hour. The twenty-four hour average will be calculated starting and ending at twelve-midnight. [District Rule 2201] Federally Enforceable Through Title V Permit
41. Daily emissions will be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve consecutive month rolling emissions total will commence at the beginning of the first day of the month. The twelve consecutive month rolling emissions total to determine compliance with annual emission limit will be compiled from the twelve most recent calendar months. [District Rule 2201] Federally Enforceable Through Title V Permit
42. Source testing to demonstrate compliance with the NO_x (ppmvd), CO (ppmvd), VOC (ppmvd), PM₁₀ (lb/hour), and NH₃ (ppmvd) emission limits shall be conducted at least once every twelve months. [District Rule 2201, 4001 and 4703] Federally Enforceable Through Title V Permit
43. Source testing to measure startup NO_x, CO, and VOC mass emission rates shall be conducted for one of the gas turbines (N-7172-1 or N-7172-2) at least once every seven years. CEM relative accuracy shall be determined during startup source testing in accordance with 40 CFR Part 60, Appendix B. If CEM data is not certified to determine compliance with NO_x and CO startup emission limits, then source testing to measure startup NO_x and CO mass emission rates shall be conducted at least once every 12 months. [District Rule 2201 and 4001] Federally Enforceable Through Title V Permit
44. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. Source testing shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
46. The results of each source test shall be received by the District no later than 60 days after the source test date. [District Rule 1081] Federally Enforceable Through Title V Permit
47. NOx emissions (referenced as NO2) shall be determined using EPA Method 7E, EPA Method 20, or CARB method 20. The test results shall be corrected to ISO standard conditions as defined in 40 CFR Part 60 Subpart GG Section 60.335. [District Rules 1081, 2201, 4001, and 4703] Federally Enforceable Through Title V Permit
48. VOC emissions (referenced as methane) shall be determined using EPA method 18 or EPA method 25. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
49. CO emissions shall be determined using EPA method 10 or EPA method 10B. [District Rules 1081, 2201, and 4703] Federally Enforceable Through Title V Permit
50. Source testing to measure concentrations of PM10 shall be conducted using EPA methods 201 and 202, or EPA methods 201A and 202, or CARB method 501 in conjunction with CARB method 5. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
51. Ammonia (NH3) emissions shall be determined using BAAQMD Method ST-1B. [District Rules 1081 and 4102]
52. Oxygen content of the exhaust gas shall be determined by using EPA method 3, EPA method 3A, or EPA method 20. [District Rules 1081, 2201, and 4703] Federally Enforceable Through Title V Permit
53. If necessary, testing for fuel sulfur content shall be conducted utilizing ASTM Method D 3246, ASTM Method D1072, ASTM Method D4468, ASTM Method D5504 or ASTM Method D3246. [District Rules 1081, 4001 and 40 CFR Part 75, Subpart D] Federally Enforceable Through Title V Permit
54. EPA approved alternative source testing methods will be allowed, upon District approval, provided it does not result in a relaxation of emission limitations. The request to utilize EPA approved alternative source testing methods must be submitted in writing and written approval received from the District prior to the submission of the source test plan. [District Rule 1081 and 4001] Federally Enforceable Through Title V Permit
55. A violation of NOx and CO emission standards measured and recorded by the CEMs shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
56. The permittee shall maintain the following records: the date, time and duration of any malfunction of the continuous monitoring equipment; dates of performance testing; dates of evaluations, calibrations, checks, and adjustments of the continuous monitoring equipment; date and time period which a continuous monitoring system or monitoring device was inoperative, maintenance of CEM's, and emission measurements. [District Rules 2201, 4703, 1080, 7.3 and 40 CFR Part 60 Subpart KKKK] Federally Enforceable Through Title V Permit
57. The permittee shall maintain a daily record that includes the actual turbine start-up and stop times (local time), total hours of operation, and the quantity and type of fuel used. [District Rule 4703] Federally Enforceable Through Title V Permit
58. The permittee shall maintain records of the date, time and duration of each bypass transition period and each primary re-ignition period. [District Rule 4703] Federally Enforceable Through Title V Permit
59. The permittee shall maintain records of the date and duration of each start-up and shutdown period. [District Rule 4703] Federally Enforceable Through Title V Permit
60. The permittee shall retain records of the cumulative annual NOx, CO, and VOC emissions. The record shall be updated monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
61. The permittee shall maintain hourly records of NOx, CO and ammonia concentrations (ppmv @ 15% O2). [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

62. The permittee shall submit a written report for each calendar quarter to the APCO. The report shall be received by the District within 30 days of the end of the quarter and shall include: time intervals and the magnitude of excess emissions, the nature and cause of excess emissions (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question; time and date of each period during which a continuous monitoring system was inoperative except for zero and span checks and the nature of system repairs and adjustments; a negative declaration when no excess emissions occurred. [District Rule 1080 and 40 CFR Part 60.4375(a), 40 CFR Part 60.4395 and 40 CFR Part 60.7(c-d)] Federally Enforceable Through Title V Permit
63. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
64. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR Part 72] Federally Enforceable Through Title V Permit
65. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75. [40 CFR Part 75] Federally Enforceable Through Title V Permit
66. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR Part 75] Federally Enforceable Through Title V Permit
67. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR Part 73] Federally Enforceable Through Title V Permit
68. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR Part 77] Federally Enforceable Through Title V Permit
69. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR Part 75, an affected unit under 40 CFR Part 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR Part 72 and 40 CFR Part 75] Federally Enforceable Through Title V Permit
70. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR Part 72] Federally Enforceable Through Title V Permit
71. An allowance shall not be deducted in order to comply with the requirements under 40 CFR Part 73, prior to the calendar year for which the allowance was allocated. [40 CFR Part 73] Federally Enforceable Through Title V Permit
72. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR Parts 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR Part 72] Federally Enforceable Through Title V Permit
73. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR Part 77] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

74. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR Part 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative. [40 CFR Part 72] Federally Enforceable Through Title V Permit
75. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR Part 75] Federally Enforceable Through Title V Permit
76. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR Part 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-7172-2-5

EXPIRATION DATE: 09/30/2025

EQUIPMENT DESCRIPTION:

84 MW NOMINALLY RATED COMBINED-CYCLE POWER GENERATING SYSTEM #2 CONSISTING OF A 1,047 MMBTU/HR GENERAL ELECTRIC FRAME 7EA NATURAL GAS-FIRED COMBUSTION TURBINE GENERATOR WITH DRY LOW NOX COMBUSTOR, AN INLET AIR FILTRATION AND EVAPORATIVE COOLING SYSTEM, A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM, AN OXIDATION CATALYST, HEAT RECOVERY STEAM GENERATOR #2 (HRSG) AND A 100 MW NOMINALLY RATED STEAM TURBINE SHARED WITH PERMIT UNIT N-7172-1

PERMIT UNIT REQUIREMENTS

1. The gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in proper operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. The gas turbine engine shall be fired exclusively on natural gas with a sulfur content of no greater than 0.36 grain of sulfur compounds (as S) per 100 dry scf of natural gas. [District Rules 2201 and 4801 and 40 CFR Part 60.4330(a)(2), 40 CFR Part 60.4395 and 40 CFR Part 60.7)] Federally Enforceable Through Title V Permit
5. Testing to demonstrate compliance with the fuel sulfur content limit of this permit shall be conducted weekly. Once eight consecutive weekly tests show compliance, the fuel sulfur content testing frequency may be reduced to once every calendar quarter. If a quarterly test shows a violation of the sulfur content limit of this permit then weekly testing shall resume and continue until eight consecutive tests show compliance. Once compliance is shown on eight consecutive weekly tests then testing may return to quarterly. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The permittee shall monitor and record the fuel flow rate to the turbine, NO_x emission rate, the CO emission rate, the ammonia injection rate, the exhaust temperature both prior to and after the SCR unit, the exhaust oxygen content, and the exhaust flow rate. [District Rules 2201, 4001, and 4703] Federally Enforceable Through Title V Permit
7. The exhaust stack shall be equipped with a continuous emissions monitor (CEM) for NO_x, CO, and O₂. The CO CEM shall meet the requirements of 40 CFR parts 60 and the NO_x and O₂ CEMS shall be installed and certified in accordance with the requirements of 40 CFR Part 75. The CEMS shall be capable of monitoring emissions during startups and shutdowns as well as during normal operating conditions. Periods where the missing data substitution procedures in Part 75 Subpart D are applied shall be reported as monitor downtime in the District Quarterly CEMS Report. [District Rules 1080, 2201 and 4703 and 40 CFR Part 60.13(a), 40 CFR Part 60.4340(b), 40 CFR Part 60.4345(a) and 40 CFR Part 60.4350(d)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO_x, CO, and O₂ analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Source Emission Monitoring and Testing. [District Rule 1081] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
11. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour. [District Rule 1080, 40 CFR Part 60.13(e)(2), 40 CFR Part 60.13(h)(2), 40 CFR Part 60.4345(b) and 40 CFR Part 60.4350(a)] Federally Enforceable Through Title V Permit
12. Owners and operators of a CEMS installed in accordance with the provisions of 40 CFR Part 60 must check zero (or low level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span must at a minimum, be adjusted whenever either the 24-hour zero drift or the 24 -hour span drift exceed two times the limit of the applicable performance specification in Appendix B of 40 CFR Part 60. The system must allow the amount of excess zero and span drift to be recorded and quantified whenever specified. [40 CFR 60.13(d)(1)] Federally Enforceable Through Title V Permit
13. Owners and operators must develop and implement a Quality Control (QC) program. As a minimum, each QC program shall include written procedures that describe in detail, complete, step-by-step procedures and operations for calibration of CEMS, calibration drift determination and adjustment, CEMS preventative maintenance, data recording/calculations/reporting, accuracy audit procedures, and corrective action for malfunctioning CEMS. Whenever excessive inaccuracies occur for two consecutive quarters, the source owner or operator must revise the current written procedures or modify or replace the CEMS to correct the deficiency causing the excessive inaccuracies. These written procedures shall be kept on record and shall be made available for inspection by the enforcement agency. [40 CFR Part 60, Appendix F] Federally Enforceable Through Title V Permit
14. In accordance with 40 CFR, Part 60, Appendix F, 5.1, cylinder gas audits (CGA) or relative accuracy audits (RAA) of continuous emission monitors shall be conducted quarterly, except during quarters in which a relative accuracy test audit (RATA) is performed. Audit reports and an Out-of-Control Detail Report, pursuant to 40 CFR Part 60 Subpart F, shall be submitted along with quarterly compliance reports to the District. [District Rule 1080 and 40 CFR Part 60 Appendix F] Federally Enforceable Through Title V Permit
15. The owner/operator shall perform a relative accuracy test audit (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
16. In the event of a breakdown of monitoring equipment, the owner shall notify the District as soon as reasonably possible, but no later than 8 hours after its detection, unless the owner or operator demonstrates to the satisfaction of the APCO that a longer reporting period was necessary, and shall initiate repairs. The owner shall inform the District of the intent to shutdown any monitoring equipment at least 24 hours prior to the event. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. Startup is defined as the period beginning with turbine initial firing until the unit meets the ppmvd emission limits for steady state operation. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown events shall not exceed 296 hours per calendar year. Startup emissions must be counted toward each applicable emission limit (lb/day and lb/yr). [District Rule 2201] Federally Enforceable Through Title V Permit
18. The combined startup and shutdown period duration shall not exceed five hours in any one day, commencing at midnight. Emissions during startup and shutdown periods must be counted toward the applicable daily emission limitations. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
19. The unit shall comply with the New Source Review based NO_x and CO limits of this permit within 5 hours after initial start-up. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
20. The NO_x emissions during start-up and shutdown periods shall not exceed 119.0 lb/hour. [District Rule 2201] Federally Enforceable Through Title V Permit
21. The NO_x emissions during steady state operation shall not exceed 2.0 ppmvd @ 15% O₂ over a 1 hour average (clock hour basis). Steady-state period refers to any periods that is not a start-up or shut down period. A clock hour in a one hour average will commence at the top of the hour. [District Rules 2201 and 4703, 40 CFR Part 60.4320(a) and 40 CFR Part 60.4380(b)(1)] Federally Enforceable Through Title V Permit
22. The combined total NO_x emissions from start-up, shut down, and steady state operation shall not exceed 444.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Compliance with NO_x emission limitations during steady state operation shall not be required during short-term excursions limited to a cumulative total of 10 hours per rolling 12-month period. Short-term excursions are defined as 15 minute periods designated by the owner/operator (and approved by the APCO) that are the direct result of transient load conditions, not to exceed four consecutive 15-minute periods, when the 15-minute average NO_x concentration exceeds 2.0 ppmvd @ 15% O₂. The maximum 1-hour average NO_x concentration for periods that include short-term excursions shall not exceed 30 ppmvd @ 15% O₂. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Examples of transient load conditions include, but are not limited to the following: (1) Initiation/shutdown of combustion turbine inlet air cooling and (2) Rapid combustion turbine load changes. All emissions during short-term excursions shall accrue towards the hourly, daily, and annual emissions limitations of this permit and shall be included in all calculations of hourly, daily, and annual mass emission rates as required by this permit. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
25. The CO emissions during start-up and shutdown periods shall not exceed 129.0 lb/hour. [District Rule 2201] Federally Enforceable Through Title V Permit
26. The CO emissions during steady state operation shall not exceed 4.0 ppmvd @ 15% O₂ over a 3 hour rolling average. Steady-state period refers to any periods that is not a start-up or shut down period. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
27. The combined total CO emissions from start-up, shut down, and steady state operation shall not exceed 558.8 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The VOC emissions during start-up and shutdown periods shall not exceed 16.0 lb/hour. [District Rule 2201] Federally Enforceable Through Title V Permit
29. The VOC emissions during steady state operation shall not exceed 1.4 ppmvd @ 15% O₂ over a 3 hour rolling average. Steady-state period refers to any periods that is not a start-up or shut down period. [District Rule 2201] Federally Enforceable Through Title V Permit
30. The combined total VOC emissions from start-up, shut down, and steady state operation shall not exceed 83.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
31. The PM₁₀ emissions rate shall not exceed 7.0 lb/hour and 168.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. The SO_x emission rate shall not exceed 1.05 lb/hour and 25.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Ammonia (NH₃) emissions shall not exceed 10 ppmvd @ 15% O₂ over a 24 hour rolling average. [District Rule 2201] Federally Enforceable Through Title V Permit
34. Compliance with ammonia emission limit shall be demonstrated utilizing one of the following procedures: 1) calculate the daily ammonia emissions using the following equation: $(\text{ppmvd @ 15\% O}_2) = ((a - (b \times c / 1,000,000)) \times (1,000,000 / b)) \times d$, where a = ammonia injection rate (lb/hr) / (17 lb/lb mol), b = dry exhaust flow rate (lb/hr) / (29 lb/lb mol), c = change in measured NO_x concentration ppmvd @ 15% O₂ across the catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip; 2.) utilize another District-approved calculation method using measured surrogate parameters to determine the daily ammonia emissions in ppmvd @ 15% O₂. If this option is chosen, the permittee shall submit a detailed calculation protocol for District approval at least 60 days prior to commencement of operation; 3.) Alternatively, the permittee may utilize a continuous in-stack ammonia monitor to verify compliance with the ammonia emissions limit. If this option is chosen, the permittee shall submit a monitoring plan for District approval at least 60 days prior to commencement of operation. [District Rule 4102]
35. The annual emissions from this unit shall not exceed 99,991 lb/year for CO and 17,404 lb/year for VOC. [District Rule 2201] Federally Enforceable Through Title V Permit
36. The combined quarterly NO_x emissions from permit units N-7172-1 and N-7172-2 shall not exceed 35,000 lb/quarter. [District Rule 2201] Federally Enforceable Through Title V Permit
37. The combined annual NO_x emissions from permit units N-7172-1 and N-7172-2 shall not exceed 140,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
38. The combined quarterly CO emissions from permit units N-7172-1 and N-7172-2 shall not exceed 49,996 lb/quarter. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The combined annual CO emissions from permit units N-7172-1 and N-7172-2 shall not exceed 199,982 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Each one hour period shall commence on the hour. Each one hour period in a three hour rolling average will commence on the hour. The three hour average will be compiled from the three most recent one hour periods. Each one hour period in a twenty-four hour average for ammonia slip will commence on the hour. The twenty-four hour average will be calculated starting and ending at twelve-midnight. [District Rule 2201] Federally Enforceable Through Title V Permit
41. Daily emissions will be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve consecutive month rolling emissions total will commence at the beginning of the first day of the month. The twelve consecutive month rolling emissions total to determine compliance with annual emission limit will be compiled from the twelve most recent calendar months. [District Rule 2201] Federally Enforceable Through Title V Permit
42. Source testing to demonstrate compliance with the NO_x (ppmvd), CO (ppmvd), VOC (ppmvd), PM₁₀ (lb/hour), and NH₃ (ppmvd) emission limits shall be conducted at least once every twelve months. [District Rule 2201, 4001 and 4703] Federally Enforceable Through Title V Permit
43. Source testing to measure startup NO_x, CO, and VOC mass emission rates shall be conducted for one of the gas turbines (N-7172-1 or N-7172-2) at least once every seven years. CEM relative accuracy shall be determined during startup source testing in accordance with 40 CFR Part 60, Appendix B. If CEM data is not certified to determine compliance with NO_x and CO startup emission limits, then source testing to measure startup NO_x and CO mass emission rates shall be conducted at least once every 12 months. [District Rule 2201 and 4001] Federally Enforceable Through Title V Permit
44. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. Source testing shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
46. The results of each source test shall be received by the District no later than 60 days after the source test date. [District Rule 1081] Federally Enforceable Through Title V Permit
47. NOx emissions (referenced as NO2) shall be determined using EPA Method 7E, EPA Method 20, or CARB method 20. The test results shall be corrected to ISO standard conditions as defined in 40 CFR Part 60 Subpart GG Section 60.335. [District Rules 1081, 2201, 4001, and 4703] Federally Enforceable Through Title V Permit
48. VOC emissions (referenced as methane) shall be determined using EPA method 18 or EPA method 25. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
49. CO emissions shall be determined using EPA method 10 or EPA method 10B. [District Rules 1081, 2201, and 4703] Federally Enforceable Through Title V Permit
50. Source testing to measure concentrations of PM10 shall be conducted using EPA methods 201 and 202, or EPA methods 201A and 202, or CARB method 501 in conjunction with CARB method 5. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
51. Ammonia (NH3) emissions shall be determined using BAAQMD Method ST-1B. [District Rules 1081 and 4102]
52. Oxygen content of the exhaust gas shall be determined by using EPA method 3, EPA method 3A, or EPA method 20. [District Rules 1081, 2201, and 4703] Federally Enforceable Through Title V Permit
53. If necessary, testing for fuel sulfur content shall be conducted utilizing ASTM Method D 3246, ASTM Method D1072, ASTM Method D4468, ASTM Method D5504 or ASTM Method D3246. [District Rules 1081, 4001 and 40 CFR Part 75, Subpart D] Federally Enforceable Through Title V Permit
54. EPA approved alternative source testing methods will be allowed, upon District approval, provided it does not result in a relaxation of emission limitations. The request to utilize EPA approved alternative source testing methods must be submitted in writing and written approval received from the District prior to the submission of the source test plan. [District Rule 1081 and 4001] Federally Enforceable Through Title V Permit
55. A violation of NOx and CO emission standards measured and recorded by the CEMs shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
56. The permittee shall maintain the following records: the date, time and duration of any malfunction of the continuous monitoring equipment; dates of performance testing; dates of evaluations, calibrations, checks, and adjustments of the continuous monitoring equipment; date and time period which a continuous monitoring system or monitoring device was inoperative, maintenance of CEM's, and emission measurements. [District Rules 2201, 4703, 1080, 7.3 and 40 CFR Part 60 Subpart KKKK] Federally Enforceable Through Title V Permit
57. The permittee shall maintain a daily record that includes the actual turbine start-up and stop times (local time), total hours of operation, and the quantity and type of fuel used. [District Rule 4703] Federally Enforceable Through Title V Permit
58. The permittee shall maintain records of the date, time and duration of each bypass transition period and each primary re-ignition period. [District Rule 4703] Federally Enforceable Through Title V Permit
59. The permittee shall maintain records of the date and duration of each start-up and shutdown period. [District Rule 4703] Federally Enforceable Through Title V Permit
60. The permittee shall retain records of the cumulative annual NOx, CO, and VOC emissions. The record shall be updated monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
61. The permittee shall maintain hourly records of NOx, CO and ammonia concentrations (ppmv @ 15% O2). [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

62. The permittee shall submit a written report for each calendar quarter to the APCO. The report shall be received by the District within 30 days of the end of the quarter and shall include: time intervals and the magnitude of excess emissions, the nature and cause of excess emissions (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question; time and date of each period during which a continuous monitoring system was inoperative except for zero and span checks and the nature of system repairs and adjustments; a negative declaration when no excess emissions occurred. [District Rule 1080 and 40 CFR Part 60.4375(a), 40 CFR Part 60.4395 and 40 CFR Part 60.7(c-d)] Federally Enforceable Through Title V Permit
63. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
64. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR Part 72] Federally Enforceable Through Title V Permit
65. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75. [40 CFR Part 75] Federally Enforceable Through Title V Permit
66. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR Part 75] Federally Enforceable Through Title V Permit
67. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR Part 73] Federally Enforceable Through Title V Permit
68. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR Part 77] Federally Enforceable Through Title V Permit
69. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR Part 75, an affected unit under 40 CFR Part 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR Part 72 and 40 CFR Part 75] Federally Enforceable Through Title V Permit
70. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR Part 72] Federally Enforceable Through Title V Permit
71. An allowance shall not be deducted in order to comply with the requirements under 40 CFR Part 73, prior to the calendar year for which the allowance was allocated. [40 CFR Part 73] Federally Enforceable Through Title V Permit
72. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR Parts 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR Part 72] Federally Enforceable Through Title V Permit
73. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR Part 77] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

74. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR Part 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative. [40 CFR Part 72] Federally Enforceable Through Title V Permit
75. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR Part 75] Federally Enforceable Through Title V Permit
76. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR Part 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

***San Joaquin Valley
Air Pollution Control District***

PERMIT UNIT: N-7172-3-3

EXPIRATION DATE: 09/30/2025

EQUIPMENT DESCRIPTION:

68,500 GPM MECHANICAL DRAFT COOLING TOWER WITH 5 CELLS SERVED BY A HIGH EFFICIENCY DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
3. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012] Federally Enforceable Through Title V Permit
4. Drift eliminator drift rate shall not exceed 0.0005%. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The PM10 emissions shall not exceed 30.8 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Compliance with the PM10 emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{Circulating Water Recirculation rate (gal/day)} \times 8.34 \text{ lb/gal} \times \text{Total Dissolved Solids Concentration in the blowdown water (ppm)} \times \text{Design Drift Rate (\%)}$. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Compliance with PM10 emission limit shall be determined by blowdown water sample analysis by independent laboratory every calendar quarter. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: N-7172-4-3

EXPIRATION DATE: 09/30/2025

EQUIPMENT DESCRIPTION:

300 HP JOHN DEERE COMPANY MODEL JW6H-UF40 DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIRE PUMP

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall not be fitted with a rain cap, or any other similar device, that impedes upward vertical exhaust flow. [District Rule 4102]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6625(f)] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be used. [District Rules 2201 and 4801, San Joaquin County Rule 407 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. The emissions from the engine shall not exceed any of the following: 5.2 grams NOx/hp-hr, 0.27 grams CO/hp-hr, or 0.15 grams VOC/hp-hr. [District Rule 2201 and 40 CFR Part 60.4205] Federally Enforceable Through Title V Permit
6. The PM10 emissions from the engine shall not exceed 0.09 grams/hp-hr based on U.S EPA certification testing using test procedure ISO 8178. [District Rules 2201 and 4102, 17 CCR 93115 and 40 CFR Part 60.4205] Federally Enforceable Through Title V Permit
7. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [District Rule 4702, 40 CFR Part 63.6605(b), 40 CFR Part 63.6625(e)(3), 40 CFR Part 63.6640(a) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
8. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rules 2201, 4701, 4702, 17 CCR 93115 and 40 CFR Part 63.6640(f)] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. The motor oil and the oil filter shall be changed at least every 500 hours of operation or annually, whichever comes first. Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement specified in Table 2d of this subpart. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. The facility operator shall report any failure to perform this management practice on the schedule required. The report shall include the federal, state or local law under which the risk was deemed unacceptable. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
11. The air cleaner shall be inspected at least every 1,000 hours of operation or annually, whichever comes first. The air filter shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. The facility operator shall report any failure to perform this management practice on the schedule required. The report shall include the federal, state or local law under which the risk was deemed unacceptable. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
12. All belts and hoses shall be inspected at least once every 500 hours of operation or annually, whichever comes first. The belts and hoses shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. The facility operator shall report any failure to perform this management practice on the schedule required. The report shall include the federal, state or local law under which the risk was deemed unacceptable. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
13. The permittee shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time, the emission standards applicable to all times other than startup in tables 1a, 2a, 2c and 2d of this subpart apply. [40 CFR Part 63.6625(h)] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of emergency and non-emergency operation and of the type of fuel used. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operation, the purpose of the operation (for example: weekly testing, etc.) and records of operational characteristics monitoring. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6655(f)] Federally Enforceable Through Title V Permit
15. The facility shall maintain records of all inspections and maintenance of the engine. [40 CFR Part 63.6655(e)(2)] Federally Enforceable Through Title V Permit
16. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Permit to Operate

FACILITY: N-7172

EXPIRATION DATE: 09/30/2025

LEGAL OWNER OR OPERATOR:

WALNUT ENERGY CENTER AUTHORITY

MAILING ADDRESS:

PO BOX 949
TURLOCK, CA 95381-0949

FACILITY LOCATION:

600 S WASHINGTON ROAD
TURLOCK, CA 95380

FACILITY DESCRIPTION:

POWER GENERATION FACILITY

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh
Executive Director / APCO

Brian Clements
Director of Permit Services