

**AVISO DE UNA DECISIÓN PRELIMINAR
PARA LA EMISIÓN DE UNA AUTORIDAD PARA CONSTRUIR Y
LA PROPUESTA MODIFICACIÓN SIGNIFICATIVA DE UN PERMISO PARA
OPERAR POR MANDATO FEDERAL**

POR EL PRESENTE SE NOTIFICA que el Distrito Unificado para el Control de la Contaminación del Aire del Valle de San Joaquín está solicitando comentarios públicos en la propuesta modificación significativa de Stockton RWCF en 2500 Navy Drive, Stockton, California. Este proyecto propone instalar un motor de reserva de emergencia Nivel 2 de 4332 bhp que proporciona energía a un generador eléctrico.

El análisis de los fundamentos jurídicos y fácticos de esta acción propuesta, Número del Proyecto # N-1212743, está disponible para la inspección del público en http://www.valleyair.org/notices/public_notices_idx.htm y en cualquiera de las oficinas del Distrito. El aumento de emisiones asociadas con este proyecto son de: 1,115 libras de NOx por año, 1 libras de SOx por año, 23 libras de PM10 por año, 23 libras de PM2.5 por año, 221 libras de CO por año y 123 libras de VOC por año. Esta será la única oportunidad para que el público haga comentarios en las condiciones especificadas de esta modificación. Si se solicita, el Distrito llevará a cabo una audiencia pública acerca de la emisión de esta modificación. Para más información en Español, por favor comuníquese con el Distrito al (209) 557-6400. Comentarios por escrito acerca de este proyecto deben ser sometidos o con matasellos antes del 12, de Mayo de 2022 a publicnotices@valleyair.org o a **BRIAN CLEMENTS, DIRECTOR DEL DEPARTAMENTO DE PERMISOS, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356.**

**NOTICE OF PRELIMINARY DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
THE PROPOSED SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed significant modification of Stockton RWCF at 2500 Navy Drive, Stockton, California. This project is proposing to install a 4,332 bhp Tier 2 emergency standby engine powering an electrical generator.

The District's analysis of the legal and factual basis for this proposed action, project #N-1212743, is available for public inspection at any District office and at http://www.valleyair.org/notices/public_notices_idx.htm. The emission increases

associated with this project are: 1,115 lb-NOx/year, 1 lb-SOx/year, 23 lb-PM10/year, 23 lb-PM2.5/year, 221 lb-CO/year and 123 lb-VOC/year. This will be the public's only opportunity to comment on the specific conditions of the modification. If requested, the District will hold a public hearing regarding issuance of this modification. For additional information, please contact the District at (209) 557-6400. Written comments on this project must be sent or postmarked by May 12, 2022 to publicnotices@valleyair.org or **BRIAN CLEMENTS, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356.**