



## COMPLIANCE ASSISTANCE BULLETIN

### February 2012

#### **MAY 31, 2012 DEADLINE TO REPLACE PRESSURE/VACUUM (P/V) VALVES ON GASOLINE DISPENSING SYSTEMS SERVED BY UNDERGROUND STORAGE TANKS**

On September 26, 2008, the California Air Resources Board (CARB) issued Approval Letter 08-04a that required every gasoline station in California with *underground storage tanks* to be equipped with Husky Model 5885 pressure/vacuum (P/V) vent valves by **May 31, 2012**.

What does this mean? It means if you have a *Husky 4885* or *OPW 623* P/V valve it needs to be replaced with a new certified valve by May 31, 2012. Currently, the Husky 5885 and the Franklin Fueling Systems PV-Zero are the only certified replacement P/V valves for your system and as of June 1<sup>st</sup> they will be the only ones allowed for use. **How can you tell which P/V valve you have?** Below are pictures of the Husky 5885 and PV-Zero. The Husky 5885 has a yellow sticker on the side that reads "EVR APPROVED". If your P/V valve does not look like one of the pictures below, then you need to replace your existing P/V valve **by May 31, 2012**. **Note: You must obtain an Authority to Construct from the District prior to installing an FFS PV-Zero valve.**



**Husky 5885**



**FFS PV-Zero**

If you do not have one of the above pictured P/V valves, please contact your gasoline equipment maintenance contractor to have your existing P/V valve replaced. If you have any questions about the information contained in this bulletin, please contact a gasoline vapor recovery staff member at one of the District's regional offices.

---

Northern Region Office  
4800 Enterprise Way  
Modesto, CA 95356-  
(209) 557-6400 ♦ FAX (209) 557-6475

Central Region Office  
1990 East Gettysburg Avenue  
Fresno, CA 93726-0244  
(559) 230-6000 ♦ FAX (559) 230-6062

Southern Region Office  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
(661) 392-5500 ♦ FAX (661) 392-5585