



July 7, 2026

Mr. William Holmes
Darling Ingredients, Inc.
PO Box 1608
Turlock, CA 95381

Re: Notice of Final Action – Title V Permit Renewal
Facility Number: N-2107
Project Number: N-1261178


Dear Mr. Holmes:

The District has issued the Final Renewed Title V Permit for Darling Ingredients, Inc. (see enclosure). The preliminary decision for this project was made on May 13, 2026. No comments were received from the public subsequent to the District's preliminary decision for this project. No comments were received from the EPA subsequent to the District's preliminary decision for this project.

The public notice for issuance of the Final Title V Permit will be posted on the District's website (<https://ww2.valleyair.org>).

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce, Permit Services Manager, at (209) 557-6400.

Sincerely,



Brian Clements
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: EPA Region 9 Air Permitting Manager (w/enclosure) via EPS

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585



Facility # N-2107
DARLING INGREDIENTS INC
P O BOX 1608
TURLOCK, CA 95381

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto: (209) 557-6446
Fresno: (559) 230-5888
Bakersfield: (661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

Permit to Operate

FACILITY: N-2107

EXPIRATION DATE: 08/31/2030

LEGAL OWNER OR OPERATOR:

DARLING INGREDIENTS INC

MAILING ADDRESS:

P O BOX 1608
TURLOCK, CA 95381

FACILITY LOCATION:

11946 CARPENTER RD
CROWS LANDING, CA 95313

FACILITY DESCRIPTION:

RENDERING

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh
Executive Director / APCO

Brian Clements
Director of Permit Services

San Joaquin Valley

Air Pollution Control District

FACILITY: N-2107-0-6

EXPIRATION DATE: 08/31/2030

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1 and Merced County Rule 109] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0 and Merced County Rule 109] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040]
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: DARLING INGREDIENTS INC
Location: 11946 CARPENTER RD, CROWS LANDING, CA 95313
N-2107-0-6 : 6/29/2026 8:34:40 AM -- KAHOLONJ

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, or repackage for use within the District; or supply, sell, market or offer for sale within the District; or solicit for application or apply within the District any architectural coating or colorant with a VOC content in excess of the corresponding limit specified in Table 1 or Table 2 of District Rule 4601 (4/16/20), after the specified effective dates in Table 1 or Table 2 of District Rule 4601. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All architectural coating containers and containers of any VOC-containing materials subject to Rule 4601 (4/16/20) shall be closed when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601, sections 6.1 and 6.3 (4/16/20). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (9/21/2003) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Merced), Rule 109 (Merced), and Rule 202 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. On November 30, 2004, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin December 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. Facility-wide PM₁₀ emissions shall not exceed 29,200 lb/year. Permittee shall maintain annual fuel-use records for all combustion devices and applicable records for other PM₁₀ emitting devices to show compliance with this emissions limit. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: N-2107-5-11

EXPIRATION DATE: 08/31/2030

EQUIPMENT DESCRIPTION:

A RAW MATERIAL RECEIVING OPERATION EQUIPPED WITH OUTDOOR RAW MATERIAL RECEIVING CONCRETE SLABS, GRINDING SYSTEM, AND PRIMARY AND SECONDARY WASTEWATER TREATMENT SYSTEM WITH DAF UNIT AND AN OUTDOOR WASTEWATER LAGOON SYSTEM (PERMIT EXEMPT LOW EMITTING UNIT)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained and operated according to the specifications and plans contained in the permit application except as otherwise specified herein. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The Air Pollution Control District shall be immediately notified of any breakdown or malfunction that reduces or disrupts the normal processing of odors required by this permit. [District Rules 1100 and 4102] Federally Enforceable Through Title V Permit
3. The District shall have authority to investigate possible odors alleged to originate from the facility and to make a determination of whether or not a nuisance exists, either in response to a complaint or on its own initiative. [District Rules 1070 and 4102] Federally Enforceable Through Title V Permit
4. The APCO or any authorized representative shall have access to inspect any equipment, operation, records, method required in this permit, to sample emissions from the source or require samples to be taken, or perform any other actions to assure compliance with the requirements of this permit and all District rules and regulations. [District Rule 1070] Federally Enforceable Through Title V Permit
5. The premises of the plant except for raw material receiving and storage areas and their associated pits and bins shall be kept clean and free from spillage of raw or finished materials, refuse, and standing pools of water which may present a nuisance condition. All raw material spills shall be cleaned up immediately. [District Rule 4102]
6. The delivery truck holding time shall not exceed 48 hours and the animal mortality holding time shall not exceed 96 hours from the time the raw materials enter the property. [District Rule 4102]
7. No storage of raw materials outside of the pits, bins, or open slab areas is permitted. [District NSR Rule and Rule 4102] Federally Enforceable Through Title V Permit
8. Raw material receiving areas (pits/bins and open slabs) not currently holding raw material for processing shall be cleaned daily. [District Rule 4102]
9. Trucks waiting their turn to unload within the 48 or 96 hour unload time limitation are not considered storage outside of the pit/slab area. [District Rule 4102]
10. All trucks and truck tires delivering raw material shall be washed clean of raw material and raw material residue prior to exiting the facility premises in order to minimize trackout of raw material and raw material residue. [District Rule 4102]
11. All raw material trucks shall be maintained in condition to prevent leakage of any solid or liquid material. [District Rule 4102]
12. The rendering plant shall not be operated unless the odor control system is operating and in full use. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. Total facility raw material process rate shall not exceed 1,650,000 pounds (825 tons) per day or 602,250,000 pounds (301,125 tons) per year. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
14. Except during periods of equipment breakdown as determined by the District under Rule 1100, all raw material received shall be processed within 24 hours of entering the receiving pits and in compliance with other conditions in this permit. Raw material shall be monitored to ensure that processing is performed within this time limit using plant processing records. [District Rules 1100 and 4102]
15. If raw material cannot be processed within the time constraints of this permit, raw material shall be diverted to other facilities. No further deliveries shall be received until a 48 (or 96) hour turnaround for raw material is achievable. [District Rule 4102]
16. The owner and/or operator shall comply with all the provisions of District Rule 4102, Nuisance. [District Rule 4102]
17. Permittee shall keep daily and annual records of the amount of raw material received. [District Rule 2201] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: N-2107-9-23

EXPIRATION DATE: 08/31/2030

EQUIPMENT DESCRIPTION:

FOOD PROCESSING BYPRODUCT RECYCLING OPERATION INCLUDING THREE DUPPS PRE-HEAT COOKERS, A HAARSLEV 2564 COOKER AND AIR COOLED CONDENSER SERVED BY A SHARED 3.0 MMBTU/HR NATURAL GAS-FIRED GULF COAST ENVIRONMENTAL REGENERATIVE THERMAL OXIDIZER (RTO) WITH A VENTURI SCRUBBER PRIOR TO THE RTO (CONTROLS SHARED WITH N-2107-14)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. [District Rules 2520, 9.3.2, 4801 and Stanislaus County Rule 407] Federally Enforceable Through Title V Permit
3. Tallow and yellow grease storage tanks shall be kept in good operating condition. These tanks shall not contribute to a nuisance condition. [District Rule 4102]
4. The shared RTO shall only be fired on PUC-regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The total facility raw material process rate shall not exceed 1,650,000 pounds (825 tons) per day or 602,250,000 pounds (301,125 tons) per year from the combined units N-2107-9 and N-2107-14. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Combined emissions from the process lines (N-2107-9 and N-2107-14) served by the RTO shall not exceed any of the following: 0.98 lb-NO_x/MMBtu, 0.15 lb-SO_x/ton of raw material processed, 0.097 lb-PM₁₀/ton of raw material processed, 1.12 lb-CO/MMBtu, and 0.03 lb-VOC/ton of raw material processed. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Source testing to measure the VOC emissions from the shared RTO exhaust shall be conducted at least once every 24 months. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Source testing shall be performed while processing raw material under normal operating conditions or another load previously approved by the District in writing. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Source testing to measure the VOC emissions shall be conducted using EPA Methods 18, 25, 25A, or 25B or CARB Method 100. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The shared RTO shall be operated with a combustion chamber temperature of no less than 1400 degrees F and the retention time shall be no less than one second. A continuous temperature monitoring and recording device shall be used and kept in good working order. [District Rules 2201 and 4104, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
13. The shared RTO shall be heated to proper operating temperature prior to any contaminated process air entering the oxidizer. [District Rules 2201 and 4104] Federally Enforceable Through Title V Permit
14. The shared RTO shall continue to operate after the shut-down of the rendering processes until all contaminated process air is incinerated. [District Rules 2201 and 4104] Federally Enforceable Through Title V Permit
15. Permittee shall keep a record of the shared RTO combustion chamber temperature readings. [District Rule 2201 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
16. Permittee shall keep a daily record of the combined quantity of raw material processed by units N-2107-9 and N-2107-14. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Facility-wide PM10 emissions shall not exceed 29,200 lbs per year. Operator shall maintain copies of all natural gas fuel invoices, and records of hours of operation of the shared RTO in order to show compliance with this emissions limit. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. All records shall be retained for a minimum of five years, and shall be made readily available for District inspection upon request. [District Rules 1070, 2201, and 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-2107-12-9

EXPIRATION DATE: 08/31/2030

EQUIPMENT DESCRIPTION:

PROTEIN MEAL FINISHING AND LOADOUT OPERATION WITH ONE DRAG LINE CONVEYOR, ONE 104 TON STORAGE/LOADOUT BIN, THREE 84 TON STORAGE/LOADOUT BINS, ONE 450 TON STORAGE/LOADOUT BIN, CRAX RECEIVING, THREE HAMMERMILLS, THREE SCREENS, AND A LOADOUT BUILDING WITH VERTILOK STORAGE/LOADOUT BINS; ANOTHER ENCLOSED MECHANICAL CONVEYANCE LINE CONVEYOR WITH A CURING BIN, A HAMMERMILL AND SCREEN SYSTEM SERVED BY AN ASPIRATOR CONNECTED TO A CYCLONE DISCHARGE ROUTED THROUGH A BAG FILTER INSIDE THE BUILDING, BUCKET ELEVATOR, A 400-TON STORAGE/LOADOUT BIN WITH BIN VENT FILTRATION SYSTEM, AND A LOADOUT BUILDING.

PERMIT UNIT REQUIREMENTS

1. All loadout material trucks shall be maintained in condition to prevent leakage of solid or liquid material. [District Rule 4102]
2. Equipment shall be operated in such a manner as to not constitute a nuisance or annoyance to a considerable number of people. [District Rule 4102]
3. The District shall have authority to investigate possible odors alleged to originate from the facility and to make a determination of whether or not a nuisance exists, either in response to a complaint or on its own initiative. [District Rule 4102]
4. The District shall have access to the facility at any time to inspect operations, review records or perform other actions to assure compliance. [District Rule 1070] Federally Enforceable Through Title V Permit
5. The combined total quantity of protein meal loaded into trucks/containers for shipping through both the old (existing) and new loadout areas shall not exceed 1,200 tons per day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. PM10 emissions from the protein meal finishing and loadout operation shall not exceed 0.00333 pounds per ton of protein meal loaded out. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall keep a daily record of the combined quantity of protein meal loaded out. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All records shall be maintained and retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: N-2107-13-11

EXPIRATION DATE: 08/31/2030

EQUIPMENT DESCRIPTION:

76.93 MMBTU/HR NEBRASKA MODEL NS-E-57 WATER-TUBE NATURAL GAS-FIRED BOILER EQUIPPED WITH A FLUE GAS RECIRCULATION (FGR) SYSTEM AND AMMONIA SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The unit shall only be fired on PUC-regulated natural gas. [District Rules 2201 and 4320, and 40 CFR 60.48c(d)] Federally Enforceable Through Title V Permit
4. The boiler shall be equipped with a non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit. [40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
5. Emissions from the natural gas-fired unit shall not exceed any of the following limits: 7 ppmvd NO_x @ 3% O₂ or 0.008 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.003 lb-PM₁₀/MMBtu, 100 ppmvd CO @ 3% O₂ or 0.073 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. The ammonia emission rate shall not exceed 10.0 ppmvd @ 3% O₂ over a 15 minute averaging period. [District Rule 4102]
7. Source testing to measure natural gas combustion NO_x, CO, and NH₃ emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests when unit is fired on natural gas, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4102, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 1081] Federally Enforceable Through Title V Permit
15. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rule 4320] Federally Enforceable Through Title V Permit
16. Fuel sulfur content shall be determined using EPA Method 11 or EPA Method 15 or District, CARB and EPA approved alternative methods. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃ and O₂ at least once during each month in which source testing is not performed. NO_x, CO and O₂ monitoring shall be conducted utilizing a portable analyzer that meets District specifications. NH₃ monitoring shall be conducted utilizing gas detection tubes (Dräger brand or District approved equivalent). Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
19. The ammonia (NH₃) flow rate range shall be established during required source tests. [40 CFR Part 64] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the ammonia (NH₃) flow rate at least once during each day. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit. [40 CFR Part 64] Federally Enforceable Through Title V Permit
21. If either the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels the permittee shall return the emissions to compliant levels as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer or the ammonia monitoring equipment continue to show emission limit violations after 1 hour of operation following detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation that is subject to enforcement action has occurred. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
22. All NO_x, CO, O₂ and NH₃ emission readings and NH₃ flow rate readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Ammonia emission readings shall be conducted at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃ and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
26. The permittee shall record and maintain records of the amount of fuel combusted during each calendar month. The record shall be updated on at least a monthly basis. [40 CFR 60.48c(g)(2)] Federally Enforceable Through Title V Permit
27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320 , 40 CFR Part 64, and 40 CFR 60.48c(i)] Federally Enforceable Through Title V Permit
28. Pursuant to Rule 4320, beginning January 1, 2025 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in the December 17, 2020 version of Rule 4320. [District Rule 4320]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: N-2107-14-6

EXPIRATION DATE: 08/31/2030

EQUIPMENT DESCRIPTION:

FEATHER RECYCLING OPERATION CONSISTING OF AN INDOOR FEATHER RECEIVING HOPPER, A STEAM-FIRED CONTINUOUS FEATHER HYDROLYZER, A FEATHER PRESS, A STEAM-FIRED FEATHER DRYER, A BLOOD STAGING TANK, BLOOD CENTRIFUGE, SPRAY CHAMBER AND AIR COOLED CONDENSER SERVED BY A SHARED 3.0 MMBTU/HR NATURAL GAS-FIRED GULF COAST ENVIRONMENTAL REGENERATIVE THERMAL OXIDIZER (RTO) WITH A VENTURI SCRUBBER PRIOR TO THE RTO (CONTROLS SHARED WITH N-2107-9)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. [District Rules 2520, 9.3.2, 4801 and Stanislaus County Rule 407] Federally Enforceable Through Title V Permit
3. The shared RTO shall only be fired on PUC-regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The total facility raw material process rate shall not exceed 1,650,000 pounds (825 tons) per day or 602,250,000 pounds (301,125 tons) per year from the combined units N-2107-9 and N-2107-14. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Combined emissions from the process lines (N-2107-9 and N-2107-14) served by the RTO shall not exceed any of the following: 0.98 lb-NO_x/MMBtu, 0.15 lb-SO_x/ton of raw material processed, 0.097 lb-PM₁₀/ton of raw material processed, 1.12 lb-CO/MMBtu, and 0.03 lb-VOC/ton of raw material processed. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Source testing to measure the VOC emissions from the shared RTO shall be conducted at least once every 24 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Source testing shall be performed while processing raw material under normal operating conditions or another load previously approved by the District in writing. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Source testing to measure the VOC emissions shall be conducted using EPA Methods 18, 25, 25A, or 25B or CARB Method 100. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
10. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
11. The shared RTO shall be operated with a combustion chamber temperature of no less than 1400 degrees F and the retention time shall be no less than one second. A continuous temperature monitoring and recording device shall be used and kept in good working order. [District Rules 2201 and 4104, and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The shared RTO shall be heated to proper operating temperature prior to any contaminated process air entering the oxidizer. [District Rules 2201 and 4104] Federally Enforceable Through Title V Permit
13. The shared RTO shall continue to operate after the shut-down of the rendering processes until all contaminated process air is incinerated. [District Rules 2201 and 4104] Federally Enforceable Through Title V Permit
14. Permittee shall keep a record of the shared RTO combustion chamber temperature readings. [District Rule 2201 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
15. Permittee shall keep a daily record of the combined quantity of material processed by units N-2107-9 and N-2107-14. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Facility-wide PM10 emissions shall not exceed 29,200 lbs per year. Operator shall maintain copies of all natural gas fuel invoices, and records of hours of operation of the shared regenerative thermal oxidizer in order to show compliance with this emissions limit. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. All records shall be retained for a minimum of five years, and shall be made readily available for District inspection upon request. [District Rules 1070, 2201, and 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: N-2107-15-5

EXPIRATION DATE: 08/31/2030

EQUIPMENT DESCRIPTION:

48 MMBTU/HR BABCOCK & WILCOX MODEL FMO-40 WATER-TUBE NATURAL GAS-FIRED BOILER WITH A TODD MODEL V4851GO LOW-NOX BURNER, A FLUE GAS RECIRCULATION SYSTEM (FGR), AND A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320; and 40 CFR 60.42c(d)] Federally Enforceable Through Title V Permit
3. The boiler shall be equipped with a non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit. [District Rule 2201 and 40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
4. Except during start-up and shutdown, emissions from natural gas combustion shall not exceed any of the following limits: 6 ppmvd NO_x @ 3% O₂ or 0.0073 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.003 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from natural gas combustion shall not exceed any of the following limits: 30 ppmvd NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.003 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. The total duration of startup and shutdown time shall not exceed any of the following limits: 2.0 hours startup per day, 2.0 hours shutdown per day, or 730 hours total startup and shutdown time per year. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. The ammonia (NH₃) emission rate shall not exceed 10.0 ppmvd @ 3% O₂ over a 15 minute averaging period. [District Rule 4102]
8. Source testing to measure natural gas combustion NO_x, CO, and NH₃ emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests when unit is fired on natural gas, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4102, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
12. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rule 4320] Federally Enforceable Through Title V Permit
17. Fuel sulfur content shall be determined using EPA Method 11 or EPA Method 15 or District, CARB and EPA approved alternative methods. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃ and O₂ at least once during each month in which source testing is not performed. NO_x, CO and O₂ monitoring shall be conducted utilizing a portable analyzer that meets District specifications. NH₃ monitoring shall be conducted utilizing gas detection tubes (Dräger brand or District approved equivalent). Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
20. The ammonia (NH₃) flow rate range shall be established during required source tests. [40 CFR Part 64] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the ammonia (NH₃) flow rate at least once during each day. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit. [40 CFR Part 64] Federally Enforceable Through Title V Permit
22. If either the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels the permittee shall return the emissions to compliant levels as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer or the ammonia monitoring equipment continue to show emission limit violations after 1 hour of operation following detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation that is subject to enforcement action has occurred. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
23. All NO_x, CO, O₂ and NH₃ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. Ammonia emissions readings shall be conducted at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rule 4102]
26. Daily and annual records of start-up and shutdown durations and number of occurrences of each shall be kept. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃ and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 4305, 4306, and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. The permittee shall record and maintain records of the amount of fuel combusted during each calendar month. The record shall be updated on at least a monthly basis. [40 CFR 60.48c(g)(2)] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320; and 40 CFR 60.48c(i)] Federally Enforceable Through Title V Permit
30. Pursuant to Rule 4320, beginning January 1, 2025 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in the December 17, 2020 version of Rule 4320. [District Rule 4320]

These terms and conditions are part of the Facility-wide Permit to Operate.