

**AVISO DE UNA DECISIÓN PRELIMINAR  
PARA LA PROPUESTA EMISIÓN DE  
UNA AUTORIDAD PARA CONSTRUIR**

POR EL PRESENTE SE NOTIFICA que El Distrito Unificado para el Control de la Contaminación del Aire del Valle de San Joaquín (el Distrito del Aire) está solicitando comentarios públicos en la propuesta emisión de una Autoridad para Construir a Mercy Hospital para la instalación de una caldera de gas natural de 10.206 MMBtu/hr equipada con Cleaver-Brooks quemadores de NOx ultra bajo que proporcionará agua caliente al edificio y la instalación de un motor de combustión interna de diésel de 2,218 caballos de fuerza que es certificado Nivel 2 para apoderar un generador eléctrico durante apagones eléctricos , en 400 Old River Road, Bakersfield, CA 93311.

El análisis de la base regulatoria para esta acción propuesta, Número del Proyecto # S-1213068, está disponible para la inspección pública en [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) y en cualquiera de las oficinas del Distrito. Para más información en Español, por favor comuníquese con el Distrito al (559) 230-6000. Comentarios por escrito acerca de este proyecto deben ser sometidos o con matasellos antes del 7 de Marzo de 2022 a [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) o a **BRIAN CLEMENTS, DIRECTOR DEL DEPARTAMENTO DE PERMISOS, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**NOTICE OF PRELIMINARY DECISION  
FOR THE PROPOSED ISSUANCE OF  
AN AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Authority to Construct to Mercy Hospital for the installation of a 10.206 MMBtu/hr natural gas-fired boiler equipped with a Cleaver-Brooks ultra-low NOx burner that will provide heated water to the building and installation of a 2,218 horsepower Tier 2 certified diesel-fired emergency standby internal combustion (IC) engine to provide emergency power in the event of an electrical outage, at 400 Old River Road, Bakersfield, CA 93311.

The analysis of the regulatory basis for this proposed action, Project # S-1213068, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and at any District office. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be sent or postmarked by March 7, 2022 to [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) or **BRIAN CLEMENTS, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**