

July 24, 2023

Ms. Deedee Antypas
Stockton RWCF
2500 Navy Dr
Stockton, CA 95206

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: N-811
Project Number: N-1230145

Dear Ms. Antypas:

The District has issued the Final Renewed Title V Permit for Stockton RWCF (see enclosure). The preliminary decision for this project was made on June 8, 2023. No comments were received following the District's preliminary decision on this project.

The public notice for issuance of the Final Title V Permit will be posted on the District's website (www.valleyair.org).

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce, Permit Services Manager, at (209) 557-6400.

Sincerely,



Brian Clements
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: Gerardo Rios, EPA (w/enclosure) via EPS

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

San Joaquin Valley Air Pollution Control District

FACILITY: N-811-0-6

EXPIRATION DATE: 11/30/2027

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (San Joaquin)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (San Joaquin)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040]
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: STOCKTON RWCF
Location: 2500 NAVY DR, STOCKTON, CA 95206
N-811-0-6 : Jul 24 2023 8:43AM -- YOSHIMUJ

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and San Joaquin County Rule 401] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, or repackage for use within the District; or supply, sell, market, or offer for sale within the District; or solicit for application or apply within the District any architectural coating or colorant with a VOC content in excess of the corresponding limit specified in Table 1 or Table 2, after the specified effective date in Table 1 or Table 2 of District Rule 4601 (4/16/20). [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the applicable administrative requirements specified Section 6.0 of District Rule 4601. [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (San Joaquin), Rule 110 (San Joaquin), and Rule 202 (San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. On September 23, 1999, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin October 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-11-7

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

450 HP CATERPILLAR MODEL 3406 DITA, S/N 75Z1640, PORTABLE EMERGENCY STANDBY DIESEL-FIRED IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6625(f)] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rule 4801 and San Joaquin County Rule 407, 17 CCR 93115, and 40 CFR Part 63.6604(b)] Federally Enforceable Through Title V Permit
5. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [40 CFR Parts 63.6605(b) and 63.6625(e)(3) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6640(f)] Federally Enforceable Through Title V Permit
7. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. The motor oil and the oil filter shall be changed at least every 500 hours of operation or annually, whichever comes first. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
11. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)] Federally Enforceable Through Title V Permit
12. The air cleaner shall be inspected at least every 1,000 hours of operation or annually, whichever comes first. The air filter shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
13. All belts and hoses shall be inspected at least once every 500 hours of operation or annually, whichever comes first. The belts and hoses shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
14. The owner or operator shall maintain monthly records of emergency and non-emergency operation and of the type of fuel used. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6655(f)] Federally Enforceable Through Title V Permit
15. The owner or operator shall maintain records of all inspections and maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63.6655(e)(2)] Federally Enforceable Through Title V Permit
16. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 1070, 2520, 4701, 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201(amended 12/17/92), and San Joaquin County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-12-7

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

450 HP CATERPILLAR MODEL 3406TA, S/N 75Z01455, PORTABLE EMERGENCY STANDBY DIESEL-FIRED IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6625(f)] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rule 4801 and San Joaquin County Rule 407, 17 CCR 93115, and 40 CFR Part 63.6604(b)] Federally Enforceable Through Title V Permit
5. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [40 CFR Parts 63.6605(b) and 63.6625(e)(3) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6640(f)] Federally Enforceable Through Title V Permit
7. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. The motor oil and the oil filter shall be changed at least every 500 hours of operation or annually, whichever comes first. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
11. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)] Federally Enforceable Through Title V Permit
12. The air cleaner shall be inspected at least every 1,000 hours of operation or annually, whichever comes first. The air filter shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
13. All belts and hoses shall be inspected at least once every 500 hours of operation or annually, whichever comes first. The belts and hoses shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
14. The owner or operator shall maintain monthly records of emergency and non-emergency operation and of the type of fuel used. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6655(f)] Federally Enforceable Through Title V Permit
15. The owner or operator shall maintain records of all inspections and maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63.6655(e)(2)] Federally Enforceable Through Title V Permit
16. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 1070, 2520, 4701, 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201(amended 12/17/92), and San Joaquin County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-13-8

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

GASOLINE DISPENSING OPERATION WITH ONE 2,000 GALLON CONVAULT ABOVEGROUND STORAGE TANK SERVED BY MORRISON BROTHERS EVR PHASE I VAPOR RECOVERY SYSTEM (VR-402-B), STANDING LOSS CONTROL (VR-301-E), AND 1 FUELING POINT WITH 1 GASOLINE DISPENSING NOZZLE SERVED BY BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-116-B)

PERMIT UNIT REQUIREMENTS

1. The Phase I, Phase II, and Standing Loss Control Vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621 and 4622 and CH&SC 41950] Federally Enforceable Through Title V Permit
2. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 4622] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The storage container(s) shall be installed, maintained, and operated such that they are leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
5. The Phase I and Phase II vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
6. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
7. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
8. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Upon identification of any major defects, the permittee shall tag "Out-of-Order" all dispensing equipment for which vapor recovery has been impaired. Tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defective equipment has been repaired, replaced, or adjusted, as necessary. In the case of defects identified by the District, tagged equipment shall be rendered inoperable, and the tag shall not be removed until the District has been notified of the repairs, and the District has either reinspected the system or authorized the tagged equipment for use. [District Rule 4622] Federally Enforceable Through Title V Permit
10. The permittee shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with the requirements of this permit. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) copies of all vapor recovery performance tests; 2) all applicable ARB Executive Orders, Approval Letters, and District Permits; 3) the manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 4) system and/or component testing requirements, including test schedules and passing criteria for each of the standard tests required by this permit (the owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements), and 5) additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622] Federally Enforceable Through Title V Permit
11. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
12. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit
13. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 2) the hoses are not torn, flattened or crimped; 3) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 4) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622] Federally Enforceable Through Title V Permit
14. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622] Federally Enforceable Through Title V Permit
15. The gasoline throughput for this permit unit shall not exceed 657,000 gallons in any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. The permittee shall perform and pass a Static Leak Test "Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Tanks" in accordance with the Executive Order specified in this permit for the Phase I Vapor Recovery System at least once every 12 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
18. For certified Phase II vapor recovery systems with liquid removal devices, the permittee shall perform and pass an ARB TP-201.6C Liquid Removal Test whenever the liquid in the vapor path exceeds 100 ml of liquid, or as required by the applicable ARB Executive Order. The amount of liquid in the vapor path shall be measured by lowering the gasoline dispensing nozzle into a container until such time that no more liquid drains from the nozzle. The amount of liquid drained into the container shall be measured using a graduated cylinder or graduated beaker. The vapor path shall be inspected according to the monitoring frequency as determined by monthly gasoline throughput. [District Rule 4622] Federally Enforceable Through Title V Permit
19. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
20. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
21. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
22. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
23. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rule 4622] Federally Enforceable Through Title V Permit
24. The permittee shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name and applicable certification numbers of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622] Federally Enforceable Through Title V Permit
25. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622] Federally Enforceable Through Title V Permit
26. The permittee shall maintain monthly and annual gasoline throughput records. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
27. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4621 (as amended December 19, 2013). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-18-9

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

36 MMBTU/HR JOHN ZINK MODEL ZTOF DIGESTER GAS FIRED EMERGENCY FLARE

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The NOx emission concentration shall not exceed 0.06 lb/mmbtu of heat input. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The CO emission concentration shall not exceed 0.3 lb/mmbtu of heat input. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The VOC emission concentration shall not exceed 0.03 lb/mmbtu of heat input. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The SOx emission concentration shall not exceed 0.08 lb/mmbtu of heat input. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The PM10 emission concentration shall not exceed 0.02 lb/mmbtu of heat input. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operation of the flare for maintenance and testing purposes shall not exceed 200 hours per year. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
9. Operation of the flare, for other than maintenance purposes, shall be limited to emergency use. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
10. The flare shall utilize a natural gas or LPG fired pilot. [District NSR Rule] Federally Enforceable Through Title V Permit
11. The flare shall operate with smokeless combustion. [District NSR Rule] Federally Enforceable Through Title V Permit
12. The flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
13. The outlet shall be equipped with an automatic ignition system, or shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311, 5.3] Federally Enforceable Through Title V Permit
14. Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

15. Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
16. Flaring is prohibited unless it is consistent with an approved flare minimization plan (FMP), pursuant to Section 6.5, and all commitments listed in that plan have been met. This standard does not apply if the APCO determines that the flaring is caused by an emergency as defined by Section 3.7 and is necessary to prevent an accident, hazard or release of vent gas directly to the atmosphere. [District Rule 4311] Federally Enforceable Through Title V Permit
17. Every five years after the initial FMP submittal, the operator shall submit an updated FMP for each flare to the APCO for approval. The current FMP shall remain in effect until the updated FMP is approved by the APCO. If the operator fails to submit an updated FMP as required by this section, the existing FMP shall no longer be considered an approved plan. [District Rule 4311] Federally Enforceable Through Title V Permit
18. An updated FMP shall be submitted by the operator pursuant to Section 6.5 addressing new or modified equipment, prior to installing the equipment. Updated FMP submittals are only required if: (1) The equipment change would require an authority to construct (ATC) and would impact the emissions from the flare, and (2) The ATC is deemed complete after June 18, 2009, and (3) The modification is not solely the removal or decommissioning of equipment that is listed in the FMP, and has no associated increase in flare emissions. [District Rule 4311] Federally Enforceable Through Title V Permit
19. The operator of a flare subject to flare minimization plans pursuant to Section 5.8 of this rule shall notify the APCO of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, which ever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311] Federally Enforceable Through Title V Permit
20. The operator of a flare subject to flare minimization plans pursuant to Section 5.8 shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. The report shall include, but is not limited to all of the following: the results of an investigation to determine the primary cause and contributing factors of the flaring event; any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; if appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and the date, time, and duration of the flaring event. [District Rule 4311] Federally Enforceable Through Title V Permit
21. The operator of a flare subject to flare monitoring requirements pursuant to Section 5.10 shall submit an annual report to the APCO within 30 days following the end of each 12 month period. The report shall include the following: the total volumetric flow of vent gas in standard cubic feet for each day; if the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; a flow verification report which shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311] Federally Enforceable Through Title V Permit
22. For purposes of the flow verification report required by Section 6.2.3.8, vent gas flow shall be determined using one or more of the following methods, or by any alternative method approved by the APCO, ARB, and EPA: EPA Methods 1 and 2; a verification method recommended by the manufacturer of the flow monitoring equipment installed pursuant to Section 5.10; tracer gas dilution or velocity; other flow monitors or process monitors that can provide comparison data on a vent stream that is being directed past the ultrasonic flow meter. [District Rule 4311] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the vent gas flow to the flare with a flow measuring device or other parameters as specified in the Permit to Operate. [District Rule 4311] Federally Enforceable Through Title V Permit
24. Records of the annual hours of emergency and non-emergency operation, and the nature of the emergency situation shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Permittee shall maintain the following records: a copy of the source testing result conducted pursuant to Section 6.4.2; a copy of the approved flare minimization plan pursuant to Section 6.5; a copy of annual reports submitted to the APCO pursuant to Section 6.2. [District Rule 4311] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. Permittee shall maintain records of the following when the flare is used during an emergency: duration of flare operation, amount of gas burned, and the nature of the emergency situation. The records shall be kept separately for each emergency episode. [District Rule 4311] Federally Enforceable Through Title V Permit
27. All records shall be retained for a minimum of five years, and shall be made available for District inspection upon request. [District Rules 1070, 2201 and 4311] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-21-13

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

1,408 HP WAUKESHA MODEL L7042GLD DIGESTER GAS/NATURAL GAS-FIRED LEAN BURN PRECOMBUSTION CHAMBER TYPE IC ENGINE WITH SILOXANE SCRUBBER POWERING AN ELECTRICAL GENERATOR (DUAL SILOXANE FILTER SYSTEM (SCRUBBER) USED TO SCRUB THE DIGESTER GAS PRIOR TO COMBUSTION IN ENGINES N-811-21-2, -22-2, & -23-2).

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
9. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine monthly fuel usage. [District Rule 4702] Federally Enforceable Through Title V Permit
10. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [40 CFR Parts 63.6605(b) and 63.6625(e)(6) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
11. The NOx emissions shall not exceed 65 ppmv @ 15% O2. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The CO emissions shall not exceed 2.65 grams/bhp-hr. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
13. The VOC emissions shall not exceed 0.75 grams/bhp-hr. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
14. The SOx emissions shall not exceed 0.036 grams/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The PM10 emissions shall not exceed 0.1 grams/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The fuel sulfur content shall not exceed 5 grains of total sulfur per 100 standard cubic feet. [District Rule 4702] Federally Enforceable Through Title V Permit
17. Source testing to demonstrate compliance with the NOx, CO, VOC, SOx and PM10 limits of this permit shall be conducted at least once every 24 months. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
18. The fuel sulfur content shall be determined on an annual basis utilizing EPA Method 11 or EPA Method 15 as appropriate. Records of the fuel analyses shall be kept and provided to the District upon request. [District Rule 4702] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Sampling facilities for source testing shall be provided in accordance with the provisions of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Source testing for NOx shall be conducted utilizing CARB method 100 or EPA method 7E. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. Source testing for CO shall be conducted utilizing CARB method 100 or EPA method 10. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. Source testing for VOC emission concentration shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. Source testing for SOx shall be conducted utilizing EPA method 8 or ARB method 100. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
26. Source testing for PM10 emissions shall be conducted utilizing CARB method 501 in conjunction with CARB method 5, EPA methods 201 and 202 or EPA methods 201A and 202. If the facility agrees that the PM10 emissions are equal to the total particulate matter emissions then source testing for PM10 may be conducted utilizing CARB method 5 including the back half or CARB method 17 including the back half. [District Rule 2201] Federally Enforceable Through Title V Permit
27. The permittee shall monitor the hydrogen sulfide influent concentration on a daily basis with the use of a Draeger tube or District approved equivalent method. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

29. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
31. The motor oil and the motor oil filter shall be changed at least every 2,160 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
32. The spark plugs shall be inspected at least every 2,160 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
33. All belts and hoses shall be inspected at least once every 2,160 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
34. The facility operator shall reevaluate the Remote Stationary RICE status of this unit at least once every 12 months. If the evaluation shows that the unit no longer meets the definition of Remote Stationary Rice in this subpart, the operator shall comply with all of the requirements that apply to this unit within 1 year of the evaluation [40 CFR Part 63.6603(f)] Federally Enforceable Through Title V Permit
35. The facility operator shall keep records of the initial and annual evaluation of the Remote Stationary RICE status of the engine. [40 CFR Part 63.6603(f)] Federally Enforceable Through Title V Permit
36. The owner or operator shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions limits with the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
37. Records of the quantity and type of fuel burned, in BTUs, the influent hydrogen sulfide concentration, and of the annual SO_x emissions shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
38. The owner or operator shall maintain records of all inspections and maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63.6655(e)(3)] Federally Enforceable Through Title V Permit
39. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 1070, 2520, 4701, 4702, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-22-13

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

1,408 HP WAUKESHA MODEL L7042GLD DIGESTER GAS/NATURAL GAS-FIRED LEAN BURN PRECOMBUSTION CHAMBER TYPE IC ENGINE WITH SILOXANE SCRUBBER POWERING AN ELECTRICAL GENERATOR (DUAL SILOXANE FILTER SYSTEM (SCRUBBER) USED TO SCRUB THE DIGESTER GAS PRIOR TO COMBUSTION IN ENGINES N-811-21-2, -22-2, & -23-2).

PERMIT UNIT REQUIREMENTS

1. While dormant, both digester gas and natural gas fuel lines shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
9. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine monthly fuel usage. [District Rule 4702] Federally Enforceable Through Title V Permit
10. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [40 CFR Parts 63.6605(b) and 63.6625(e)(6) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
11. The NOx emissions shall not exceed 65 ppmv @ 15% O2. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The CO emissions shall not exceed 2.65 grams/bhp-hr. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
13. The VOC emissions shall not exceed 0.75 grams/bhp-hr. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
14. The SOx emissions shall not exceed 0.036 grams/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The PM10 emissions shall not exceed 0.1 grams/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The fuel sulfur content shall not exceed 5 grains of total sulfur per 100 standard cubic feet. [District Rule 4702] Federally Enforceable Through Title V Permit
17. Source testing to demonstrate compliance with the NOx, CO, VOC, SOx and PM10 limits of this permit shall be conducted at least once every 24 months. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
18. The fuel sulfur content shall be determined on an annual basis utilizing EPA Method 11 or EPA Method 15 as appropriate. Records of the fuel analyses shall be kept and provided to the District upon request. [District Rule 4702] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Sampling facilities for source testing shall be provided in accordance with the provisions of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Source testing for NOx shall be conducted utilizing CARB method 100 or EPA method 7E. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. Source testing for CO shall be conducted utilizing CARB method 100 or EPA method 10. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. Source testing for VOC emission concentration shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. Source testing for SOx shall be conducted utilizing EPA method 8 or ARB method 100. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
26. Source testing for PM10 emissions shall be conducted utilizing CARB method 501 in conjunction with CARB method 5, EPA methods 201 and 202 or EPA methods 201A and 202. If the facility agrees that the PM10 emissions are equal to the total particulate matter emissions then source testing for PM10 may be conducted utilizing CARB method 5 including the back half or CARB method 17 including the back half. [District Rule 2201] Federally Enforceable Through Title V Permit
27. The permittee shall monitor the hydrogen sulfide influent concentration on a daily basis with the use of a Draeger tube or District approved equivalent method. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

29. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
31. The motor oil and the motor oil filter shall be changed at least every 2,160 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
32. The spark plugs shall be inspected at least every 2,160 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
33. All belts and hoses shall be inspected at least once every 2,160 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
34. The facility operator shall reevaluate the Remote Stationary RICE status of this unit at least once every 12 months. If the evaluation shows that the unit no longer meets the definition of Remote Stationary Rice in this subpart, the operator shall comply with all of the requirements that apply to this unit within 1 year of the evaluation [40 CFR Part 63.6603(f)] Federally Enforceable Through Title V Permit
35. The facility operator shall keep records of the initial and annual evaluation of the Remote Stationary RICE status of the engine. [40 CFR Part 63.6603(f)] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of O₂ and NO_x measurements, (2) the O₂ and NO_x concentration in percent, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions limits with the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
37. Records of the quantity and type of fuel burned, in BTUs, the influent hydrogen sulfide concentration, and of the annual SO_x emissions shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
38. The owner or operator shall maintain records of all inspections and maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63.6655(e)(3)] Federally Enforceable Through Title V Permit
39. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 1070, 2520, 4701, 4702, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-23-12

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

1,408 HP WAUKESHA MODEL L7042GLD DIGESTER GAS/NATURAL GAS-FIRED LEAN BURN PRECOMBUSTION CHAMBER TYPE IC ENGINE WITH SILOXANE SCRUBBER POWERING AN ELECTRICAL GENERATOR (DUAL SILOXANE FILTER SYSTEM (SCRUBBER) USED TO SCRUB THE DIGESTER GAS PRIOR TO COMBUSTION IN ENGINES N-811-21, -22, & -23).

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
9. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine monthly fuel usage. [District Rule 4702] Federally Enforceable Through Title V Permit
10. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [40 CFR Parts 63.6605(b) and 63.6625(e)(6) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
11. The NO_x emissions shall not exceed 65 ppmv @ 15% O₂. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The CO emissions shall not exceed 2.65 grams/bhp-hr. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
13. The VOC emissions shall not exceed 0.75 grams/bhp-hr. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
14. The SOx emissions shall not exceed 0.036 grams/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The PM10 emissions shall not exceed 0.1 grams/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The fuel sulfur content shall not exceed 5 grains of total sulfur per 100 standard cubic feet. [District Rule 4702] Federally Enforceable Through Title V Permit
17. Source testing to demonstrate compliance with the NOx, CO, VOC, SOx and PM10 limits of this permit shall be conducted at least once every 24 months. [District Rules 2201, 4701 and 4702] Federally Enforceable Through Title V Permit
18. The fuel sulfur content shall be determined on an annual basis utilizing EPA Method 11 or EPA Method 15 as appropriate. Records of the fuel analyses shall be kept and provided to the District upon request. [District Rule 4702] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Sampling facilities for source testing shall be provided in accordance with the provisions of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Source testing for NOx shall be conducted utilizing CARB method 100 or EPA method 7E. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. Source testing for CO shall be conducted utilizing CARB method 100 or EPA method 10. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. Source testing for VOC emission concentration shall be conducted utilizing EPA method 25 or EPA method 18, referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. Source testing for SOx shall be conducted utilizing EPA method 8 or ARB method 100. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
26. Source testing for PM10 emissions shall be conducted utilizing CARB method 501 in conjunction with CARB method 5, EPA methods 201 and 202 or EPA methods 201A and 202. If the facility agrees that the PM10 emissions are equal to the total particulate matter emissions then source testing for PM10 may be conducted utilizing CARB method 5 including the back half or CARB method 17 including the back half. [District Rule 2201] Federally Enforceable Through Title V Permit
27. The permittee shall monitor the hydrogen sulfide influent concentration on a daily basis with the use of a Draeger tube or District approved equivalent method. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

29. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
31. The motor oil and the motor oil filter shall be changed at least every 2,160 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
32. The spark plugs shall be inspected at least every 2,160 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
33. All belts and hoses shall be inspected at least once every 2,160 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
34. The facility operator shall reevaluate the Remote Stationary RICE status of this unit at least once every 12 months. If the evaluation shows that the unit no longer meets the definition of Remote Stationary Rice in this subpart, the operator shall comply with all of the requirements that apply to this unit within 1 year of the evaluation. [40 CFR Part 63.6603(f)] Federally Enforceable Through Title V Permit
35. The facility operator shall keep records of the initial and annual evaluation of the Remote Stationary RICE status of the engine. [40 CFR Part 63.6603(f)] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of O₂ and NO_x measurements, (2) the O₂ and NO_x concentration in percent, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions limits with the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
37. Records of the quantity and type of fuel burned, in BTUs, the influent hydrogen sulfide concentration, and of the annual SO_x emissions shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
38. The owner or operator shall maintain records of all inspections and maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63.6655(e)(3)] Federally Enforceable Through Title V Permit
39. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 1070, 2520, 4701, 4702, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-25-5

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

2,550 HP DETROIT DIESEL MODEL T1637K16 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING A 1750 KW ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District NSR Rule] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63.6625(f)] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. Emissions from this IC engine shall not exceed any of the following limits: 6.2 g-NOx/bhp-hr, 0.34 g-CO/bhp-hr, or 0.33 g-VOC/bhp-hr. [District Rule 2201, 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. Emissions from this IC engine shall not exceed 0.09 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. The engine shall be operated and maintained in accordance with manufacturer's emission related written instructions and in a manner consistent with safety and good air pollution control practice for minimizing emissions. Alternatively, the facility may develop a plan that provides maintenance that is consistent with good air pollution control practice for minimizing emissions. [40 CFR Parts 63.6605(b) and 63.6625(e)(3) and 40 CFR Part 63 Subpart ZZZZ Table 6] Federally Enforceable Through Title V Permit
10. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rules 4701 and 4702, 17 CCR 93115 and 40 CFR Part 63.6640(f)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
14. The motor oil and the oil filter shall be changed at least every 500 hours of operation or annually, whichever comes first. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
15. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63.6625(i)] Federally Enforceable Through Title V Permit
16. The air cleaner shall be inspected at least every 1,000 hours of operation or annually, whichever comes first. The air filter shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
17. All belts and hoses shall be inspected at least once every 500 hours of operation or annually, whichever comes first. The belts and hoses shall be replaced as necessary. If this deadline passes while the unit is operating for an emergency, the maintenance or inspection may be delayed until the emergency is over. [District Rule 40 CFR Part 63 Subpart ZZZZ - Table 2d] Federally Enforceable Through Title V Permit
18. The owner or operator shall maintain monthly records of emergency and non-emergency operation and of the type of fuel used. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701 and 4702, 17 CCR 93115 and 40 CFR Part 63.6655(f)] Federally Enforceable Through Title V Permit
19. The owner or operator shall maintain records of all inspections and maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63.6655(e)(2)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. All records shall be maintained for a period of at least 5 years and shall be made available to the District, EPA or CARB upon request. [District Rules 1070, 2520, 4701, 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201(amended 12/17/92), and San Joaquin County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-811-26-5

EXPIRATION DATE: 11/30/2027

EQUIPMENT DESCRIPTION:

HEADWORKS FACILITY WITH EMISSIONS CONTROLLED BY TWO CUSTOM HARRINGTON ENVIRONMENTAL ENGINEERING BIOSCRUBBERS (55,000 CFM COMBINED RATING)

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Volatile Organic Compound (VOC) emissions, from each biofilter controlling the headworks, shall not exceed 2,657 ppbv (as CH₄). [District Rule 2201] Federally Enforceable Through Title V Permit
4. Sulfur Compound emissions (including Hydrogen Sulfide emissions), from each biofilter controlling the headworks, shall not exceed 708 ppbv (as SO₂). [District Rule 2201] Federally Enforceable Through Title V Permit
5. Ammonia emissions, from each biofilter controlling the headworks, shall not exceed 1 ppmv. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Hydrogen Sulfide emissions, from each biofilter controlling the headworks, shall not exceed 524 ppbv (as SO₂). [District Rule 2201 and 40 CFR 64] Federally Enforceable Through Title V Permit
7. The permittee shall monitor the hydrogen sulfide effluent concentration at the exit of each biofilter on a daily basis. The hydrogen sulfide concentration shall be determined via the use of a portable analyzer, Draeger tube, or District approved equivalent method. [District Rule 2201 and 40 CFR 64] Federally Enforceable Through Title V Permit
8. The permittee shall maintain a daily record of the hydrogen sulfide effluent concentration at each biofilters exhaust. [District Rule 2520, 9.3.2 and 40 CFR 64] Federally Enforceable Through Title V Permit
9. The permittee shall monitor the VOC concentration at the exit of each biofilter on a quarterly basis. The VOC concentration shall be determined via the use of a portable analyzer or District approved equivalent method. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. This unit shall be tested for compliance with the Ammonia (NH₃) emissions limit at least once every 12 months. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Ammonia (NH₃) emissions for source test purposes shall be determined using BAAQMD ST-1B or District approved equivalent method. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

14. All records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.